



Entergy Operations, Inc.
P.O. Box B
Killona, LA 70066
Tel 504 739 6242

Early C. Ewing, III
Director
Nuclear Safety & Regulatory Affairs
Waterford 3

W3F1-97-0160
A4.05
PR

June 23, 1997

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

Subject: Waterford 3 SES
Docket No. 50-382
License No. NPF-38
Withdrawal of Technical Specification Change Request NPF-38-167

Gentlemen:

By letter dated July 26, 1995, Waterford 3 submitted the subject Technical Specification Change Request to revise Technical Specification 3.9.4. This change would have allowed the containment personnel airlock and equipment doors in the containment building to be open under strict administrative controls during core alterations or movement of irradiated fuel.

Waterford 3 hereby requests that Technical Specification Change Request NPF-38-167 be withdrawn in its entirety. The request will be revised to conform to current industry practice and will be resubmitted at a later date.

Handwritten: A001/0

9706260288 970623
PDR ADOCK 05000382
P PDR



260015

Withdrawal of Technical Specification Change Request NPF-38-167


W3F1-97-0160

Page 2

June 23, 1997

Should you have any questions or comments concerning this request, please contact Mr. Paul Caropino at (504) 739-6692.

Very truly yours,



E.C. Ewing
Director
Nuclear Safety and Regulatory Affairs

ECE/ELL/ssf

cc: E.W. Merschoff, NRC Region IV
C.P. Patel, NRC-NRR
J. Smith
N.S. Reynolds
NRC Resident Inspectors Office
Administrator Radiation Protection Division
(State of Louisiana)
American Nuclear Insurers