

**Public Service
Company of Colorado**

P.O. Box 840
Denver, CO 80201-0840

March 29, 1988
Fort St. Vrain
Unit No. 1
P-88051

R.O. WILLIAMS, JR.
VICE PRESIDENT
NUCLEAR OPERATIONS

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Attention: Mr. Jose A. Calvo
Director, Project Directorate IV

Docket No. 50-267

SUBJECT: Proposed Technical Specification
Change - Dewpoint Moisture
Monitor Limiting Conditions for
Operation

Dear Mr. Calvo:

This amendment request to the Fort St. Vrain Technical Specifications deletes the requirement to monitor the ambient temperature in instrument penetrations housing the flow sensors for the Dewpoint Moisture Monitor system. Data has been recorded for over ten years which demonstrates that adequate thermal margin exists and the design basis assumption is valid. Attachment 1 is a Summary of the Proposed Change to the existing license. Attachment 2 is the Proposed Change to the existing license. Attachment 3 is the Safety Evaluation for the proposed change. Attachment 4 is the Significant Hazards Consideration for the proposed change.

In accordance with the provisions of 10CFR170, an application fee for \$150.00 is enclosed

AOO 1
||
w/ check \$150
#054596

P-88051

-2-

March 29, 1988

If you have any questions or comments concerning the enclosed information, please call Mr. M. H. Holmes at (303) 480-6960.

Very truly yours,



R. O. Williams, Jr.
Vice President
Nuclear Operations

ROW/JAC/lmb

Attachments:

cc: Regional Administrator, Region IV
ATTN: Mr. T. F. Westerman, Chief
Projects Section B

Mr. Robert Farrell
Senior Resident Inspector
Fort St. Vrain


Albert J. Hazle
Colorado Department of Health

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter)
)
Public Service Company of Colorado) Docket No. 50-267
Fort St. Vrain Unit No. 1)

AFFIDAVIT

R. O. Williams, Jr., being first duly sworn, deposes and says: That he is Vice President, Nuclear Operations, of Public Service Company of Colorado, the Licensee herein, that he has read the foregoing Application of Amendment to Appendix A of Facility Operating License and knows the contents thereof, and that the statements and matters set forth therein are true and correct to the best of his knowledge, information and belief.



R. O. Williams, Jr.
Vice President
Nuclear Operations

STATE OF Colorado)
)
COUNTY OF Weld)

Subscribe and sworn to before me, a Notary Public on this
29th day of March, 1988.



Notary Public

My commission expires November 29, ¹⁹⁹¹~~198~~.