



# THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 97 ■ PERRY, OHIO 44081 ■ TELEPHONE (216) 259-3737 ■ ADDRESS-10 CENTER ROAD

*Serving The Best Location in the Nation*  
PERRY NUCLEAR POWER PLANT

Al Kaplan

VICE PRESIDENT  
NUCLEAR GROUP

March 31, 1988  
PY-CEI/NRR-0828 L

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Perry Nuclear Power Plant  
Docket No. 50-440 and 50-441  
Response to NRC Bulletin 88-01

Dear Sir:

This letter provides The Cleveland Electric Illuminating Company's response to NRC Bulletin 88-01 "Defects In Westinghouse Circuit Breakers."

Westinghouse DS series circuit breakers are not presently used at the Perry Nuclear Power Plant. In order to control future use of DS-206, DSL-206, DS-416, DSL-416 and DS-420 circuit breakers, these breakers have been added to the PNPP Restricted List to prohibit their procurement as presently constructed.

If there are any questions, please feel free to call.

Very truly yours,

Al Kaplan  
Vice President  
Nuclear Group

AK:cab

cc: K. Connaughton  
T. Colburn  
A. Bert Davis, Regional Administrator

8804070235 880331  
PDR ADOCK 05000440  
Q PDR


JEH  
11

Alvin Kaplan who, being duly sworn, deposed and said that (1) he is Vice President, Nuclear Group of The Cleveland Electric Illuminating Company, (2) he is duly authorized to execute and file this report on behalf of The Cleveland Electric Illuminating Company and as duly authorized agent for Duquesne Light Company, Ohio Edison Company, Pennsylvania Power Company and the Toledo Edison Company, and (3) the statements set forth therein are true and correct to the best of his knowledge, information and belief.



Alvin Kaplan

Sworn to and subscribed before me, this 31<sup>st</sup> day of March, 1988.



JANE E. MOTT

Notary Public, State of Ohio

My Commission Expires February 20, 1990  
(Recorded in Lake County)