



**Duquesne Light**

Nuclear Division  
P.O. Box 4  
Shippingport, PA 15077-0004

Telephone (412) 393-6000  
April 8, 1988  
ND3SPM:0203

Beaver Valley Power Station, Unit No. 1  
Docket No. 50-334, License No. DPR-66  
Special Report

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555

Gentlemen:

In accordance with Technical Specification 3.7.14.3, the following Special Report is submitted.

On March 9, 1988 during a review of a recently performed CO2 Fire Protection System test, it was noted that the test did not verify manual and automatic operation of three CO2 Fire Dampers as required by Technical Specification 4.7.14.3.b.1. These dampers were [VS-D-180], [VS-D-168] and [VS-D-361]. [VS-D-180] separates the West Cable Vault and MCC Room, [VS-D-168] separates the East Cable Vault and the Purge Duct Room and [VS-D-361] separates the West Cable Vault and 722 ft. Safeguards area.

A continuous fire watch was posted immediately for all the effected areas. The fire dampers were added to the CO2 Fire Protection System test and all dampers were tested satisfactorily on March 11, 1988.

Very truly yours,

T. P. Noonan,  
Plant Manager

8804140166 880408  
PDR ADDCK 05000334  
S DCD

IF22  
10

April 8, 1988  
ND3SPM:0203  
Page two

cc: Mr. William T. Russell  
Regional Administrator  
United States Nuclear Regulatory Commission  
Region 1  
King of Prussia, PA 19406

C. A. Roteck, Ohio Edison

Mr. Peter Tam, BVPS Licensing Project Manager  
United States Nuclear Regulatory Commission  
Washington, DC 20555

J. Beall, Nuclear Regulatory Commission,  
BVPS Senior Resident Inspector

Mr. Alex Timme, CAPCO Nuclear Projects Coordinator  
Toledo Edison

INPO Records Center  
Suite 1500  
1100 Circle 75 Parkway  
Atlanta, GA 30339

G. E. Muckle, Factory Mutual Engineering, Pittsburgh

Mr. J. N. Steinmetz, Operating Plant Projects Manager  
Mid Atlantic Area  
Westinghouse Electric Corporation  
Energy Systems Service Division  
Box 355  
Pittsburgh, PA 15230

American Nuclear Insurers  
c/o Dottie Sherman, ANI Library  
The Exchange Suite 245  
270 Farmington Avenue  
Farmington, CT 06032

Mr. Richard Janati  
Department of Environmental Resources  
P. O. Box 2063  
16th Floor, Fulton Building  
Harrisburg, PA 17120