

April 11, 1988

Docket Nos.: 50-369/370

MEMORANDUM FOR: Sholly Coordinator

FROM: Darl Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects I/II

SUBJECT: REQUEST FOR PUBLICATION IN BI-WEEKLY FR NOTICE - NOTICE OF
ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC 67202/67203)

Duke Power Company, Docket Nos. 50-369 and 50-370, McGuire Nuclear Station,

Units 1 and 2, Mecklenburg County, North Carolina

Date of application for amendments: February 5, 1988

Brief description of amendments: The amendments corrected Technical
Specifications 3.1.2.5 and 3.1.2.6 by increasing the minimum volume of borated
water to be maintained in the Boric Acid Storage System.

Date of issuance: April 11, 1988

Effective date: April 11, 1988

Amendment Nos.: 80 and 61

Facility Operating License Nos. NPF-9 and NPF-17. Amendments revised the
Technical Specifications.

Date of initial notice in Federal Register: March 9, 1988 (53 FR)

The Commission's related evaluation of the amendments is contained in a Safety
Evaluation dated April 11, 1988.

No significant hazards consideration comments received: No

Local Public Document Room location: Atkins Library, University of North
Carolina, Charlotte (UNCC Station), North Carolina 28242

Original signed by:

Darl Hood, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

8804150104 880411
PDR ADOCK 05000369
P PDK

PD I/II-3
MRood
3/3/88

DSH
PD I/II-3
DHood:pw
3/2/88

DSH
PD I/II-3
Acting PD
3/2/88

MC
4/11/88