



Northern States Power Company

414 Nicollet Mall
Minneapolis, Minnesota 55401
Telephone (612) 330-5500

January 28, 1988

Technical Specification
4.12.E.1

Director
Office of Nuclear Reactor Regulation
U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Steam Generator Tube Plugging

In accordance with Technical Specification 4.12.E.1, the following steam generator tube plugging information is provided for the information of the NRC Staff.

Following the recent inservice inspection of Unit 2 steam generators, tubes were plugged as follows:

- Steam Generator 21 - 2 tubes plugged
total of 59 now plugged (1.7%)
- Steam Generator 22 - 3 tubes plugged
total of 130 now plugged (3.8%)

Detailed information related to the inservice inspection and the tube plugging will be provided in an Inservice Inspection Summary Report which will be submitted within 90 days of the completion of the inspection. Also, Table 4.3-13 of the Prairie Island Updated Safety Analysis Report will be updated with this information in the next revision. Please contact us if you have any questions related to this information. us.

David Musolf
David Musolf
Manager Nuclear Support Services

- c: Regional Administrator III, NRC
- Sr Resident Inspector, NRC
- NRR Project Manager, NRC
- MPCA
- Attn: Dr J W Ferman
- G Charnoff

8802020289 880128
PDR ADOCK 05000282
Q PDR

A047
/0