

ENCLOSURE 1

NOTICE OF VIOLATION

Georgia Power Company
Plant Vogtle

Docket No. 50-424
License Nos. NPF-61

During the Nuclear Regulatory Commission (NRC) inspection conducted on December 7-11, 1987, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1988), the violation is listed below:

Technical Specification 6.7.1.b requires the licensee to implement established procedures. Chemistry procedures 35611-C, Remote Analysis with the Post Accident Sampling System, 35625-C, Calibration of the Post Accident Sampling System Dissolved Oxygen Monitor, and 35629-C, Recalibration of the Post Accident System Ion Chromatograph, require that certain tests be performed at monthly intervals but not to exceed 45 days.

Contrary to the above, a review of licensee records indicated that required procedural actions had not been performed for periods in excess of 45 days. These were (a) Procedure 35611-C, system testing was not performed between June 15, 1987 and August 17, 1987, an interval of two months plus two days; (b) Procedure 35625-C, calibration of the dissolved oxygen monitor was not performed between March 10, 1987 and July 14, 1987, an interval of four months plus four days; and (c) Procedure 35629-C, recalibration of the ion chromatograph was not performed between June 10, 1987 and August 16, 1987, an interval of two months plus six days.

This is a Severity Level V violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Georgia Power is hereby required to submit a written statement or explanation to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555, with a copy to the Regional Administrator, Region II, and a copy to the NRC Resident Inspector, within 30 days of the date of the letter transmitting this Notice. This reply should be clearly marked as a "Reply to a Notice of Violation" and should include: (1) admission or denial of the violation, (2) the reason for the violation if admitted, (3) the corrective steps which have been taken and the results achieved, (4) the corrective steps which will be taken to avoid further violations, and (5) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time. If an adequate reply is not received within the time specified in this Notice, an

Georgia Power
Vogtle

2

Docket No. 50-424
License No. NPF-61

order may be issued to show cause why the license should not be modified, suspended, or revoked or why such other action as may be proper should not be taken.

FOR THE NUCLEAR REGULATORY COMMISSION

Douglas M. Collins

Douglas M. Collins, Chief
Emergency Preparedness and
Radiological Protection Branch
Division of Radiation Safety
and Safeguards

Dated at Atlanta, Georgia
this 20th day of January 1988