

Document Transmittal #: 63035

Date: 6/30/97

To: NRC (DC DESK)  
Destination:

MAC: N/A  
Description:

Document:	Revision:	Comment:	Copy #	Copy Totals		
				INFO	CNTL	MSTR
AR0701	16	EFFECTIVE 06/28/97	24	1	0	0

*0/1 A001*


Instructions to the Addressee:

Please verify the document(s) received agrees with the above information.

Operations department must attach old document(s) or portions of document(s) superseded by the above to this transmittal.

The signature indicates acknowledgment of receipt of the above document(s) and that documents have been updated. Return signed and dated transmittal to Document Control within 15 working days of transmittal date to mail code:

\_\_\_\_ NA1C  
 \_\_\_\_\_ Florida Power Corporation  
 Document Control, NA1C  
 Crystal River Energy Complex  
 15760 W. Power Line St.  
 Crystal River, FL 34428-6708



Signature of Addressee: \_\_\_\_\_ Date: \_\_\_\_\_

9707080294 970628  
 PDR ADOCK 05000302  
 F PDR

Rev. 16

Effective Date 6-28-97

# INFORMATION ONLY

ANNUNCIATOR RESPONSE

AR-701

FLORIDA POWER CORPORATION

CRYSTAL RIVER UNIT 3

SSF P ANNUNCIATOR RESPONSE

APPROVED BY: Interpretation Contact

Michael A. Winschips for C.W.B.

DATE: 06/28/97

INTERPRETATION CONTACT: Manager, Nuclear Plant Operations  
Support



TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 <u>PURPOSE</u> . . . . .	1
2.0 <u>REFERENCES</u> . . . . .	1
2.1 <u>IMPLEMENTING REFERENCES</u> . . . . .	1
2.2 <u>DEVELOPMENTAL REFERENCES</u> . . . . .	1
3.0 <u>PERSONNEL INDOCTRINATION</u> . . . . .	1
4.0 <u>INSTRUCTIONS</u> . . . . .	2
5.0 <u>FOLLOW-UP ACTIONS</u> . . . . .	2
 <u>ENCLOSURE</u>	
1 Annunciator Response. . . . .	3

## 1.0 PURPOSE

- 1.1 Establish a reference document for each Annunciator Window on the SFF-A1 Lampbox.
- 1.2 Establish operator actions for valid Annunciator alarms on the SSF-A1 Lampbox.
- 1.3 Establish a reference to other procedures which address operator actions for valid Annunciator alarms on the SSF-A1 Lampbox.

## 2.0 REFERENCES

### 2.1 IMPLEMENTING REFERENCES

- 2.1.1 EOP, Emergency Operating Procedure
- 2.1.2 OP-305, Operation of Pressurizer
- 2.1.3 AP-770, Emergency Diesel Generator Actuation
- 2.1.4 AP-545, Plant Runback
- 2.1.5 OP-700B, 480 Volt AC Motor Control Centers
- 2.1.6 OP-700D, 120 Volt AC Vital Busses
- 2.1.7 OP-703, Plant Distribution
- 2.1.8 OP-705, Emergency Power DC System

### 2.2 DEVELOPMENTAL REFERENCES

- 2.2.1 INPO 90-021, Good Practice OP-217, Alarm Response Procedures
- 2.2.2 Annunciator Window Engraving Drawing E-224-049

## 3.0 PERSONNEL INDOCTRINATION

- 3.1 The Annunciator System is powered from VBDP-5 Breaker 28.

4.0 INSTRUCTIONS

4.1 Respond to alarms on the SSF-A1 Lampbox as indicated on Enclosure 1, Annunciator Response.

5.0 FOLLOW-UP ACTIONS

None



















































































SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-02-09	P-02-09
-----------------------------	--------------	---------


**480 V  
MCC BREAKER  
OPEN**

**EVENT POINT 0639**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"><li><input type="radio"/> BREAKER 3363 IS OPEN AND RACKED IN.</li></ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"><li><input type="radio"/> GREEN LIGHT IS ON, LOCATED ON THE LOCAL INDICATION AT 480V TURBINE AUX BUS 3A UNIT 3D.</li></ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"><li><input type="radio"/> STABILIZE PLANT.</li><li><input type="radio"/> REFER TO OP-700B FOR LOADS ON VENTILATION MCC 3A.</li></ul>
<p>DISCUSSION:</p> <p style="text-align: center;">THIS IS INDICATIVE OF A POSSIBLE FAULT ON THE MOTOR CONTROL CENTER, RESTORATION OF POWER SHOULD BE IN ACCORDANCE WITH OP-703.</p>
<p>REFERENCES: DRAWING 208-040 SHEET MT-060</p>
<p>SENSING ELEMENT: BREAKER CONTACT R/b</p>



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-02-09	P-02-09
-----------------------------	--------------	---------


**480 V  
MCC BREAKER  
OPEN**

EVENT POINT 0675

**INDICATED CONDITION:**

- BREAKER 3365 IS OPEN AND RACKED IN.

---

**REDUNDANT INDICATION WHICH WILL VERIFY ALARM:**

- GREEN LIGHT IS ON, LOCATED ON THE LOCAL INDICATION AT "A" 480V REACTOR AUX BUS, UNIT 3C.

---

**OPERATOR ACTIONS FOR A VALID ALARM:**

- STABILIZE PLANT.
- REFER TO OP-700B FOR LOADS ON REACTOR MCC 3A2.

---

**DISCUSSION:**

THIS IS INDICATIVE OF A POSSIBLE FAULT ON THE MOTOR CONTROL CENTER, RESTORATION OF POWER SHOULD BE IN ACCORDANCE WITH OP-703.

---

**REFERENCES:** DRAWING 208-040 SHEET MT-062

---

**SENSING ELEMENT:** BREAKER CONTACT R/b















SSF ANNUNCIATOR RESPONSE	SSF-A1-03-01	P-03-01
--------------------------	--------------	---------


**6.9 KV  
BUS B  
DEAD**

**EVENT POINT 0643**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li>○ 6900V REACTOR AUX BUS 3B UNDER VOLTAGE DEVICE IS ACTUATED ON TWO OUT OF THREE PHASES SENSING &lt; 4000 VOLTS AC AS SENSED BY THE FOLLOWING: RELAY 27X-A, RELAY 27X-B, RELAY 27X-C</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li>○ 6900v REACTOR AUX BUS 3B-VOLTAGE ON MCB</li> <li>○ 6900v REACTOR AUX BUS 3B-VOLTAGE IN SWITCHGEAR ROOM</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li>○ VERIFY RCP-1B TRIPPED</li> <li>○ VERIFY RCP-1D TRIPPED</li> <li>○ REFER TO EOP</li> </ul>
<p>DISCUSSION:</p> <p>THIS INDICATES THE UNDERVOLTAGE RELAYING FOR THE BUS HAS ACTUATED. UNDERVOLTAGE RELAYING SHOULD STRIP THE LOAD BREAKERS FROM THE BUS.</p>
<p>REFERENCES: DRAWING 208-040 SHEET MT-63, EC-206-021</p>
<p>SENSING ELEMENT: 27X RELAY, 27Y RELAY</p>





















SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-03-08	P-03-08
-----------------------------	--------------	---------


**480V  
XFMR TEMP  
HIGH**

**EVENT POINT 0702**

INDICATED CONDITION:

- REACTOR AUX BUS 3A TRANSFORMER TEMPERATURE IS >200°C AS SENSED BY HOT SPOT TEMP. SW.2.

---

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- HIGH TEMPERATURE ON MTSW-3C TRANSFORMER TEMPERATURE MONITOR.

---

OPERATOR ACTIONS FOR A VALID ALARM:

- ENSURE THAT THE TRANSFORMER FANS HAVE STARTED.

---

DISCUSSION:

THE ALARM INDICATES THAT THE TRANSFORMER DOES NOT HAVE ADEQUATE COOLING. TRANSFORMER LOAD SHOULD BE REDUCED AS MUCH AS POSSIBLE. THIS IS AN EXPECTED ALARM WHEN BUS IS DE-ENERGIZED.

---

REFERENCES: DRAWING 208-040 SHEET MT-029

---

SENSING ELEMENT: SW-2

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-03-08	P-03-08
-----------------------------	--------------	---------


**480V  
XFMR TEMP  
HIGH**

**EVENT POINT 0703**

INDICATED CONDITION: <ul style="list-style-type: none"><li>○ REACTOR AUX BUS 3B TRANSFORMER TEMPERATURE IS <math>&gt;200^{\circ}\text{C}</math> AS SENSED BY HOT SPOT TEMP. SW.2.</li></ul>
REDUNDANT INDICATION WHICH WILL VERIFY ALARM: <ul style="list-style-type: none"><li>○ HIGH TEMPERATURE ON MTSW-3D TRANSFORMER TEMPERATURE MONITOR.</li></ul>
OPERATOR ACTIONS FOR A VALID ALARM: <ul style="list-style-type: none"><li>○ ENSURE THAT THE TRANSFORMER FANS HAVE STARTED.</li></ul>
DISCUSSION: <p>THE ALARM INDICATES THAT THE TRANSFORMER DOES NOT HAVE ADEQUATE COOLING. TRANSFORMER LOAD SHOULD BE REDUCED AS MUCH AS POSSIBLE. THIS IS AN EXPECTED ALARM WHEN BUS IS DE-ENERGIZED.</p>
REFERENCES: DRAWING 208-040 SHEET MT-030
SENSING ELEMENT: SW-2



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-03-08	P-03-08
-----------------------------	--------------	---------


480V  
XFMR TEMP  
HIGH

EVENT POINT 0704

INDICATED CONDITION:

- INTAKE AUX BUS 3A TRANSFORMER TEMPERATURE IS  $>90^{\circ}\text{C}$  AS SENSED BY HOT SPOT TEMPERATURE SW.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- HIGH TEMPERATURE ON MTSW-3H A TRANSFORMER TEMPERATURE MONITOR.

OPERATOR ACTIONS FOR A VALID ALARM:

- ENSURE THAT THE TRANSFORMER FANS HAVE STARTED.

DISCUSSION:

THE ALARM INDICATES THAT THE TRANSFORMER DOES NOT HAVE ADEQUATE COOLING. TRANSFORMER LOAD SHOULD BE REDUCED AS MUCH AS POSSIBLE.

REFERENCES: DRAWING 208-040 SHEET MT-031

SENSING ELEMENT: TRANS TEMP SW

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-03-08	P-03-08
-----------------------------	--------------	---------


**480V  
XFMR TEMP  
HIGH**

**EVENT POINT 0705**

INDICATED CONDITION: <ul style="list-style-type: none"><li>○ INTAKE AUX BUS 3B TRANSFORMER TEMPERATURE IS &gt;90°C AS SENSED BY HOT SPOT TEMPERATURE SW.</li></ul>
REDUNDANT INDICATION WHICH WILL VERIFY ALARM: <ul style="list-style-type: none"><li>○ HIGH TEMPERATURE ON MTSW-3H B TRANSFORMER TEMPERATURE MONITOR.</li></ul>
OPERATOR ACTIONS FOR A VALID ALARM: <ul style="list-style-type: none"><li>○ ENSURE THAT THE TRANSFORMER FANS HAVE STARTED.</li></ul>
DISCUSSION: <p>THE ALARM INDICATES THAT THE TRANSFORMER DOES NOT HAVE ADEQUATE COOLING. TRANSFORMER LOAD SHOULD BE REDUCED AS MUCH AS POSSIBLE.</p>
REFERENCES: DRAWING 208-040 SHEET MT-032
SENSING ELEMENT: TRANS TEMP SW





SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-03-08	P-03-08
-----------------------------	--------------	---------


**480V  
XFMR TEMP  
HIGH**

**EVENT POINT 0708**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"><li><input type="checkbox"/> ES 480V "B" TRANSFORMER TEMPERATURE IS &gt;200°C AS SENSED BY HOT SPOT TEMP. SW.2.</li></ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"><li><input type="checkbox"/> HIGH TEMPERATURE ON MTSW-3G TRANSFORMER TEMPERATURE MONITOR.</li></ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"><li><input type="checkbox"/> ENSURE THAT THE TRANSFORMER FANS HAVE STARTED.</li></ul>
<p>DISCUSSION:</p> <p style="padding-left: 40px;">THE ALARM INDICATES THAT THE TRANSFORMER DOES NOT HAVE ADEQUATE COOLING. TRANSFORMER LOAD SHOULD BE REDUCED AS MUCH AS POSSIBLE.</p>
<p>REFERENCES: DRAWING 208-040 SHEET MT-133</p>
<p>SENSING ELEMENT: SW-2</p>











SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-04-01	P-04-01
-----------------------------	--------------	---------


**INVERTER A  
FAILURE**

**EVENT POINT 0159**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li>○ LOSS OF INVERTER AC INPUT &lt;365 VAC AND A LOSS OF DC INPUT &lt; 105 VDC</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li>○ INVERTER POWER STATUS INDICATOR LIGHT IS OUT, LOCATED ON THE MCB.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li>○ ENSURE THAT VBXS-1A HAS TRANSFERRED TO ALTERNATE SOURCE AND THAT VBDP-3 IS ENERGIZED.</li> <li>○ ENSURE THAT VBXS-3A HAS TRANSFERRED TO ALTERNATE SOURCE AND THAT VBDP-8 IS ENERGIZED.</li> <li>○ REFER TO OP-703.</li> </ul>
<p>DISCUSSION:</p> <p style="margin-left: 40px;">THIS IS INDICATIVE OF A FAILURE OF THE INVERTER, THE VITAL BUS SHOULD REMAIN ENERGIZED VIA THE TRANSFORMERS.</p> <p style="margin-left: 40px;">REFER TO STS FOR THE PROPER ADMINISTRATIVE REQUIREMENTS.</p>
<p>REFERENCES: 209-058 VB-01 AND 20-102649</p>
<p>SENSING ELEMENT: X21</p>



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-04-02	P-04-02
-----------------------------	--------------	---------


**INVERTER A  
TROUBLE**

**EVENT POINT 0164**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li><input type="radio"/> INVERTER DC INPUT VOLTAGE IS &lt; 135 VDC AS SENSED BY X7.</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li><input type="radio"/> BATTERY SUPPLYING LOAD RED INDICATING LIGHT IS ON, LOCATED ON THE INVERTER.</li> <li><input type="radio"/> BATTERY SOURCE INPUT METER INDICATING &gt; 50 AMPS ON THE INVERTER.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li><input type="radio"/> INVESTIGATE THE LOSS OF AC INPUT TO THE INVERTER.</li> <li><input type="radio"/> REESTABLISH AC INPUT TO THE INVERTER.</li> </ul>
<p>DISCUSSION:</p> <p>THIS IS AN INDICATION OF THE DC INPUT SUPPORTING THE INVERTER OUTPUT. THE CAUSE COULD BE INTERNAL TO THE INVERTER, OR POSSIBLY A LOSS OFF AC INPUT TO INVERTER.</p> <p>REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.</p>
<p>REFERENCES: 209-058 VB-01 AND 20-102649</p>
<p>SENSING ELEMENT: X-7</p>

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-04-02	P-04-02
-----------------------------	--------------	---------


**INVERTER A  
 TROUBLE**

**EVENT POINT 0169**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li><input type="radio"/> DC INPUT TO INVERTER IS &gt; 200 AMPS DC AS SENSED BY X48.</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li><input type="radio"/> BATTERY SOURCE INPUT METER INDICATING &gt; 200 AMPS ON THE INVERTER.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li><input type="radio"/> INVESTIGATE THE CAUSE OF THE HIGH LOAD ON THE INVERTER.</li> <li><input type="radio"/> REFER TO JP-700D.</li> </ul>
<p>DISCUSSION:</p> <ul style="list-style-type: none"> <li><input type="radio"/> THIS IS INDICATIVE OF A PROBLEM WITH THE INVERTER, CONSIDERATION SHOULD BE GIVEN TO BYPASSING THE INVERTER. REFER TO OP-703.</li> </ul>
<p>REFERENCES: 209-058 VB-01 AND 20-102649</p>
<p>SENSING ELEMENT: X48</p>

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-04-02	P-04-02
-----------------------------	--------------	---------


**INVERTER A  
TROUBLE**

**EVENT POINT 0174**

INDICATED CONDITION:

- DC INPUT VOLTAGE FROM BATTERY IS <105 VDC AS SENSED BY RELAY X6.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- BATTERY INPUT BREAKER TRIPPED LOCALLY.

OPERATOR ACTIONS FOR A VALID ALARM:

- INVESTIGATE CAUSE OF LOW INPUT VOLTAGE.
- RECLOSE DC INPUT BREAKER AFTER VOLTAGE IS RECOVERED.

DISCUSSION:

WITH A LOSS OF DC INPUT VOLTAGE THE INVERTER IS NOT ABLE TO FUNCTION DURING A LOSS OF AC INPUT POWER.

REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.

REFERENCES: 209-058 VB-01 AND 20-102649

SENSING ELEMENT: X6



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-04-02	P-04-02
-----------------------------	--------------	---------


**INVERTER A  
TROUBLE**

**EVENT POINT 0179**

<p><b>INDICATED CONDITION:</b></p> <ul style="list-style-type: none"> <li>○ DC INPUT VOLTAGE TO INVERTER IS &gt;140 VDC AS SENSED BY X16.</li> </ul>
<p><b>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</b></p> <ul style="list-style-type: none"> <li>○ HIGH OUTPUT VOLTAGE ON BATTERY CHARGERS.</li> </ul>
<p><b>OPERATOR ACTIONS FOR A VALID ALARM:</b></p> <ul style="list-style-type: none"> <li>○ INVESTIGATE CAUSE FOR VOLTAGE PROBLEMS.</li> </ul>
<p><b>DISCUSSION:</b></p> <p style="margin-left: 40px;">THIS CONDITION MAY CAUSE PROBLEMS WITH INVERTER RELIABILITY. REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.</p>
<p><b>REFERENCES:</b> 209-058 VB-01 AND 20-102649</p>
<p><b>SENSING ELEMENT:</b> X16</p>









SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-05-02	P-05-02
-----------------------------	--------------	---------


INVERTER B  
TROUBLE

**EVENT POINT 0165**

INDICATED CONDITION:

- INVERTER DC INPUT AMPERAGE IS > 50 AMPS AS SENSED BY RL2.

---

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- BATTERY SOURCE INPUT RED INDICATING LIGHT IS ON, LOCATED ON THE INVERTER.
- BATTERY SOURCE INPUT METER VB-002-III1 INDICATING > 50 AMPS ON THE INVERTER.

---

OPERATOR ACTIONS FOR A VALID ALARM:

- INVESTIGATE THE LOSS OF AC INPUT TO THE INVERTER.
- REESTABLISH AC INPUT TO THE INVERTER.

---

DISCUSSION:

THIS IS AN INDICATION OF THE DC INPUT SUPPORTING THE INVERTER OUTPUT. THE CAUSE COULD BE INTERNAL TO THE INVERTER, OR POSSIBLY A LOSS OF AC INPUT TO INVERTER.

REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.

---

REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA

---

SENSING ELEMENT: RL2

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-05-02	P-05-02
-----------------------------	--------------	---------


**INVERTER B  
TROUBLE**

**EVENT POINT 0170**

**INDICATED CONDITION:**

- DC INPUT TO INVERTER IS > 168 AMPS DC AS SENSED BY RL3.

---

**REDUNDANT INDICATION WHICH WILL VERIFY ALARM:**

- BATTERY SOURCE INPUT METER VB-002-II: INDICATING >168 AMPS LOCALLY.

---

**OPERATOR ACTIONS FOR A VALID ALARM:**

- INVESTIGATE THE CAUSE OF THE HIGH LOAD ON THE INVERTER.
- REFER TO OP-700D.

---

**DISCUSSION:**

THIS IS INDICATIVE OF A PROBLEM WITH THE INVERTER, CONSIDERATION SHOULD BE GIVEN TO BYPASSING THE INVERTER. REFER TO OP-703.

---

**REFERENCES:** DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA

---

**SENSING ELEMENT:** RL3



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-05-02	P-05-02
-----------------------------	--------------	---------


INVERTER B  
TROUBLE

**EVENT POINT 0175**

INDICATED CONDITION:

- DC INPUT VOLTAGE FROM BATTERY IS <105 VDC AS SENSED BY RELAY RL6.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- BATTERY INPUT BREAKER TRIPPED LOCALLY.

OPERATOR ACTIONS FOR A VALID ALARM:

- INVESTIGATE CAUSE OF LOW INPUT VOLTAGE.
- RECLOSE DC INPUT BREAKER AFTER VOLTAGE IS RECOVERED.

DISCUSSION:

WITH A LOSS OF DC INPUT VOLTAGE THE INVERTER IS NOT ABLE TO FUNCTION DURING A LOSS OF AC INPUT POWER.

REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.

REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA

SENSING ELEMENT: RL6

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-05-02	P-05-02
-----------------------------	--------------	---------


**INVERTER B  
TROUBLE**

**EVENT POINT 0180**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> DC INPUT VOLTAGE TO INVERTER IS &gt;140 VDC AS SENSED BY RL7.</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> HIGH OUTPUT VOLTAGE ON BATTERY CHARGERS.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li><input type="checkbox"/> INVESTIGATE CAUSE FOR VOLTAGE PROBLEMS.</li> </ul>
<p>DISCUSSION:</p> <p style="margin-left: 20px;">THIS CONDITION MAY CAUSE PROBLEMS WITH INVERTER RELIABILITY. REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.</p>
<p>REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA</p>
<p>SENSING ELEMENT: RL7</p>

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-05-02	P-05-02
-----------------------------	--------------	---------


**INVERTER B  
TROUBLE**

**EVENT POINT 0190**

INDICATED CONDITION:

- INVERTER AC OUTPUT VOLTAGE IS < 114 VAC AS SENSED BY RELAY RL1.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- VOLTAGE INDICATOR VB-006-II ON INVERTER FACE INDICATING < 114 VAC.

OPERATOR ACTIONS FOR A VALID ALARM:

- TRANSFER VITAL BUS TO ALTERNATE SOURCE IF AVAILABLE.
- REFER TO OP-703.

DISCUSSION:

LOW OUTPUT VOLTAGE RESULTS FROM EITHER EXCESSIVE LOAD ON THE INVERTER, OR FROM LOW INPUT VOLTAGE. THE INVERTER SHOULD TRANSFER TO THE ALTERNATE SOURCE ON A LOW VOLTAGE.

REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA

SENSING ELEMENT: RL1





SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-06-02	P-06-02
-----------------------------	--------------	---------


**INVERTER C  
TROUBLE**

**EVENT POINT 0166**

INDICATED CONDITION:

- INVERTER DC INPUT VOLTAGE IS < 135 VDC AS SENSED BY X7.

---

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- BATTERY SUPPLYING LOAD RED INDICATING LIGHT IS ON, LOCATED ON THE INVERTER.
- BATTERY SOURCE INPUT METER INDICATING > 50 AMPS ON THE INVERTER.

---

OPERATOR ACTIONS FOR A VALID ALARM:

- INVESTIGATE THE LOSS OF AC INPUT TO THE INVERTER.
- REESTABLISH AC INPUT TO THE INVERTER.

---

DISCUSSION:

THIS IS AN INDICATION OF THE DC INPUT SUPPORTING THE INVERTER OUTPUT. THE CAUSE COULD BE INTERNAL TO THE INVERTER, OR POSSIBLY A LOSS OFF AC INPUT TO INVERTER. REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.

---

REFERENCES: 209-058 VB-03 AND 20-102649

---

SENSING ELEMENT: X7













SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-06-02	P-06-02
-----------------------------	--------------	---------


**INVERTER C  
TROUBLE**

**EVENT POINT 1599**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"><li>○ "C" INVERTER FAN FAILURE</li></ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"><li>○ "C" INVERTER CABINET COOLING FAN(S) NOT RUNNING</li></ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"><li>○ CHECK TEMPERATURE OF "C" INVERTER</li><li>○ NOTIFY ELECTRIC SHOP</li></ul>
<p>DISCUSSION:</p> <p>EXCESSIVE TEMPERATURE COULD CAUSE LOSS OF INVERTER, CONSIDERATION SHOULD BE GIVEN TO SUPPLYING VITAL BUS POWER FROM ALTERNATE SOURCE PER OP-703</p>
<p>REFERENCES: 209-058 VB-03 AND 20-102649</p>
<p>SENSING ELEMENT: Y9</p>







SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-06-03	P-06-03
-----------------------------	--------------	---------


**INVERTER  
BYPASSED**

**EVENT POINT 1596**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"><li>○ VBXS-1C AND/OR VBXS-3C SUPPLYING "C" VITAL BUS POWER FROM ALTERNATE SOURCE.</li></ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"><li>○ ON THE AFFECTED VBXS: EITHER THE ALTERNATE SOURCE SUPPLYING LOAD RED INDICATING LIGHT IS ON, OR THE MANUAL TRANSFER SWITCH IS SELECTED TO ALTERNATE SOURCE.</li></ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"><li>○ REFER TO OP-700D FOR AFFECTED LOADS.</li></ul>
<p>DISCUSSION:</p> <p>THIS INDICATES THAT VBDP-5 AND/OR VBDP-9 ARE BEING SUPPLIED FROM THE ALTERNATE SOURCE. THE STATUS OF THE TRANSFER SWITCH MAY NOT BE OBVIOUS AS THE ISOLATION REQUIRES THE ALTERNATE SOURCE INPUT BREAKER TO BE OPEN WHEN TRANSFER IS COMPLETE TO PREVENT BACKFEED TO THE INVERTER.</p>
<p>REFERENCES: DRAWING 209-058 SHEETS VB-06, AND VB-11, VEND DWG 015C18517,</p>
<p>SENSING ELEMENT: RELAY 1102 INTERNAL TO VBXS</p>

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-06-03	P-06-03
-----------------------------	--------------	---------


**INVERTER  
BYPASSED**

**EVENT POINT 1597**

INDICATED CONDITION:

- VBXS-1D AND/OR VBXS-3D SUPPLYING "D" VITAL BUS POWER FROM ALTERNATE SOURCE.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- ON THE AFFECTED VBXS: EITHER THE ALTERNATE SOURCE SUPPLYING LOAD RED INDICATING LIGHT IS ON, OR THE MANUAL TRANSFER SWITCH IS SELECTED TO ALTERNATE SOURCE.

OPERATOR ACTIONS FOR A VALID ALARM:

- REFER TO OP-700D FOR AFFECTED LOADS.

DISCUSSION:

THIS INDICATES THAT VBDP-6 AND/OR VBDP-11 ARE BEING SUPPLIED FROM THE ALTERNATE SOURCE. THE STATUS OF THE TRANSFER SWITCH MAY NOT BE OBVIOUS AS THE ISOLATION REQUIRES THE ALTERNATE SOURCE INPUT BREAKER TO BE OPEN WHEN TRANSFER IS COMPLETE TO PREVENT BACKFEED TO THE INVERTER.

REFERENCES: DRAWING 209-058 SHEETS VB-06, AND VB-11, VEND DWG 015C18517

SENSING ELEMENT: RELAY 1102 INTERNAL TO VBXS

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-06-03	P-06-03
-----------------------------	--------------	---------


**INVERTER  
BYPASSED**

**EVENT POINT 1598**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"><li>○ VBXS-1E IS SUPPLYING LOADS WITH ALTERNATE SOURCE.</li></ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"><li>○ NORMAL POWER SOURCE BREAKER IS OFF AND ALTERNATE POWER SOURCE BREAKER IS ON, LOCATED ON THE MANUAL TRANSFER SWITCH.</li></ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"><li>○ REFER TO OP-700D FOR AFFECTED LOADS.</li></ul>
<p>DISCUSSION:</p> <p>THIS INDICATES THAT VBDP-7 IS BEING SUPPLIED FROM THE ALTERNATE SOURCE.</p>
<p>REFERENCES: DRAWING 209-058 SHEET VB-06</p>
<p>SENSING ELEMENT: AUXILIARY CONTACTS ON BREAKER</p>













SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-02	P-07-02
-----------------------------	--------------	---------


INVERTER D  
TROUBLE

**EVENT POINT 0172**

INDICATED CONDITION:

- DC INPUT TO INVERTER IS > 168 AMPS DC AS SENSED BY RL3.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- BATTERY SOURCE INPUT METER VB-003-III1 INDICATING >168 AMPS LOCALLY ON THE INVERTER.

OPERATOR ACTIONS FOR A VALID ALARM:

- INVESTIGATE THE CAUSE OF THE HIGH LOAD ON THE INVERTER.
- REFER TO OP-700D.

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE INVERTER, CONSIDERATION SHOULD BE GIVEN TO BYPASSING THE INVERTER. REFER TO OP-703.

REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA

SENSING ELEMENT: RL3

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-02	P-07-02
-----------------------------	--------------	---------


**INVERTER D  
TROUBLE**

**EVENT POINT 0177**

INDICATED CONDITION:

- DC INPUT VOLTAGE FROM BATTERY IS <105 VDC AS SENSED BY RELAY RL6.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- BATTERY INPUT BREAKER TRIPPED LOCALLY.

OPERATOR ACTIONS FOR A VALID ALARM:

- INVESTIGATE CAUSE OF LOW INPUT VOLTAGE.
- RECLOSE DC INPUT BREAKER AFTER VOLTAGE IS RECOVERED.

DISCUSSION:

WITH A LOSS OF DC INPUT VOLTAGE THE INVERTER IS NOT ABLE TO FUNCTION DURING A LOSS OF AC INPUT POWER.

REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.

REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA

SENSING ELEMENT: RL6







SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-06	P-07-06
-----------------------------	--------------	---------


**BATTERY B  
DISCHARGE  
HIGH**

**EVENT POINT 1946**

INDICATED CONDITION:

- DPBA-1B1 IS DISCHARGING CURRENT >50 AMPS AS SENSED BY AMMETER 1 BUS 2 ALARM RELAY.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- DPDP-1B LOCAL CURRENT METER.

OPERATOR ACTIONS FOR A VALID ALARM:

- VERIFY BATTERY CHARGER IS ALIGNED TO THE BUS AND OPERATIONAL.

DISCUSSION:

LOSS OF A BATTERY CHARGER OR DC LOADS ON BUS WITH >50 AMPS BEING SUPPLIED FROM THE BATTERY WILL CAUSE THIS ALARM TO OPERATE.

REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.

REFERENCES: DRAWING 209-023 SHEET DP-07

SENSING ELEMENT: AMMETER ALARM RELAY 1



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-06	P-07-06
-----------------------------	--------------	---------


BATTERY B  
DISCHARGE  
HIGH

**EVENT POINT 1947**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li>○ DPBA-1B2 IS DISCHARGING CURRENT &gt;50 AMPS AS SENSED BY AMMETER 2 BUS 2 ALARM RELAY.</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li>○ DPDP-1B LOCAL CURRENT METER.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li>○ VERIFY BATTERY CHARGER IS ALIGNED TO THE BUS AND OPERATIONAL.</li> </ul>
<p>DISCUSSION:</p> <p>LOSS OF A BATTERY CHARGER OR DC LOADS ON BUS WITH &gt;50 AMPS BEING SUPPLIED FORM THE BATTERY WILL CAUSE THIS ALARM TO OPERATE.</p> <p>REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.</p>
<p>REFERENCES: DRAWING 209-023 SHEET DP-07</p>
<p>SENSING ELEMENT: AMMETER ALARM RELAY 2</p>



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1570**

INDICATED CONDITION:

- DPBC-1A AC VOLTAGE IS < 108 VAC AS SENSED BY K1 RELAY ON ACPFAR CARD.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- COMPUTER POINT E-037.
- VOLTAGE INDICATED ON 480V ES BUS 3A < 430 VAC.

OPERATOR ACTIONS FOR A VALID ALARM:

- PLACE STANDBY CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE POWER FEED TO THE CHARGER. A LOW BUS VOLTAGE ON THE AC POWER INPUT TO THE CHARGER MAY BE THE PROBLEM. IF THIS IS NOT THE PROBLEM THEN THE SWING CHARGER SHOULD BE PLACED IN SERVICE UNTIL THE PROBLEM CAN BE RESOLVED.

REFERENCES: VENDOR DRAWING KBC-2475-130, PM-141, C&D MANUAL #33

SENSING ELEMENT: ACPFAR-K1 RELAY





SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1572**

INDICATED CONDITION:

- DPBC-1C AC VOLTAGE IS < 108 VAC AS SENSED BY K1 RELAY ON ACPFAR CARD.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- COMPUTER POINT E-039.
- VOLTAGE INDICATED ON 480V ES BUS 3A < 430 VAC.

OPERATOR ACTIONS FOR A VALID ALARM:

- PLACE STANDBY CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE POWER FEED TO THE CHARGER. A LOW BUS VOLTAGE ON THE AC POWER INPUT TO THE CHARGER MAY BE THE PROBLEM. IF THIS IS NOT THE PROBLEM THEN THE SWING CHARGER SHOULD BE PLACED IN SERVICE UNTIL THE PROBLEM CAN BE RESOLVED.

REFERENCES: VENDOR DRAWING KBC-2475-130, PM-141, C&D MANUAL #33

SENSING ELEMENT: ACPFAR-K1 RELAY

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


BATTERY  
CHARGER  
TROUBLE

**EVENT POINT 1573**

INDICATED CONDITION:

- DPBC-1D AC VOLTAGE IS < 108 VAC AS SENSED BY K1 RELAY ON ACPFAR CARD.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- COMPUTER POINT E-040.
- VOLTAGE INDICATED ON 480V ES BUS 3B < 430 VAC.

OPERATOR ACTIONS FOR A VALID ALARM:

- PLACE STANDBY CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE POWER FEED TO THE CHARGER. A LOW BUS VOLTAGE ON THE AC POWER INPUT TO THE CHARGER MAY BE THE PROBLEM. IF THIS IS NOT THE PROBLEM THEN THE SWING CHARGER SHOULD BE PLACED IN SERVICE UNTIL THE PROBLEM CAN BE RESOLVED.

REFERENCES: VENDOR DRAWING KBC-2475-130, PM-141, C&D MANUAL #33

SENSING ELEMENT: ACPFAR-K1 RELAY













SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1578**

INDICATED CONDITION:

- DPBC-1C DC VOLTAGE < 124.4 VDC AS SENSED BY K5L RELAY ON THE LVA w/TD CONTROL BOARD

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- VOLTAGE INDICATED ON DPBC-1C < 130 VDC.

OPERATOR ACTIONS FOR A VALID ALARM:

- RAISE BUS VOLTAGE.
- PLACE STANDBY CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.
- NOTIFY ELECTRICAL SHOP SUPERVISOR

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE OUTPUT OF THE CHARGER. IF RAISING INPUT VOLTAGE TO THE CHARGER DOES NOT CORRECT THE PROBLEM THE SWING CHARGER SHOULD BE PLACED IN SERVICE.

REFERENCES: VENDOR DRAWING MBC-4766, PM-141, C&D MANUAL #33

SENSING ELEMENT: LVA w/TD BOARD, K5L RELAY

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1579**

**INDICATED CONDITION:**

- DPBC-1D DC VOLTAGE < 124.4 VDC AS SENSED BY K5L RELAY ON THE LVA w/TD CONTROL BOARD

**REDUNDANT INDICATION WHICH WILL VERIFY ALARM:**

- VOLTAGE INDICATED ON DPBC-1D < 130 VDC.

**OPERATOR ACTIONS FOR A VALID ALARM:**

- RAISE BUS VOLTAGE.
- PLACE STANDBY CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.
- NOTIFY ELECTRICAL SHOP SUPERVISOR.

**DISCUSSION:**

THIS IS INDICATIVE OF A PROBLEM WITH THE OUTPUT OF THE CHARGER. IF RAISING INPUT VOLTAGE TO THE CHARGER DOES NOT CORRECT THE PROBLEM THE SWING CHARGER SHOULD BE PLACED IN SERVICE.

**REFERENCES: VENDOR DRAWING MBC-4766, PM-141, C&D MANUAL #33**

**SENSING ELEMENT: LVA w/TD BOARD, K5L RELAY**





SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1581**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li>○ DPBC-1F DC VOLTAGE &lt; 124.4 VDC AS SENSED BY K5L RELAY ON THE LVA w/TD CONTROL BOARD</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li>○ VOLTAGE INDICATED ON DPBC-1F &lt; 130 VDC.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li>○ RAISE BUS VOLTAGE.</li> <li>○ RETURN NORMAL CHARGER TO SERVICE IF AVAILABLE.</li> <li>○ REFER TO OP-705.</li> <li>○ NOTIFY ELECTRICAL SHOP SUPERVISOR.</li> </ul>
<p>DISCUSSION:</p> <p style="text-align: center;">THIS IS INDICATIVE OF A PROBLEM WITH THE OUTPUT OF THE CHARGER.</p>
<p>REFERENCES: VENDOR DRAWING MBC-4766, PM-141, C&amp;D MANUAL #33</p>
<p>SENSING ELEMENT: LVA w/TD BOARD, K5L RELAY</p>

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1790**

INDICATED CONDITION:

- DPBC-1G AC VOLTAGE IS < 108 VAC AS SENSED BY K1 RELAY ON ACPFAR CARD.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- VOLTAGE INDICATED ON 480V REACTOR AUX BUS 3A < 430 VAC.

OPERATOR ACTIONS FOR A VALID ALARM:

- PLACE STANDBY CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE POWER FEED TO THE CHARGER. A LOW BUS VOLTAGE ON THE AC POWER INPUT TO THE CHARGER MAY BE THE PROBLEM. IF THIS IS NOT THE PROBLEM THEN THE SWING CHARGER SHOULD BE PLACED IN SERVICE UNTIL THE PROBLEM CAN BE RESOLVED.

REFERENCES: DRAWING 209-023 SHEET DP-10, KBC-2475-130, C&D MANUAL #33

SENSING ELEMENT: ACPFAR-K1 RELAY



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1793**

INDICATED CONDITION:

- DPBC-1H AC VOLTAGE IS <108 VAC AS SENSED BY K1 RELAY ON ACPFAR CARD.

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- COMPUTER POINT E-043.
- VOLTAGE INDICATED ON 480V ES BUS 3B < 430 VAC.

OPERATOR ACTIONS FOR A VALID ALARM:

- PLACE STANDBY CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE POWER FEED TO THE CHARGER. A LOW BUS VOLTAGE ON THE AC POWER INPUT TO THE CHARGER MAY BE THE PROBLEM. IF THIS IS NOT THE PROBLEM THEN THE SWING CHARGER SHOULD BE PLACED IN SERVICE UNTIL THE PROBLEM CAN BE RESOLVED.

REFERENCES: VENDOR DRAWING KBC-2475-130, C&D MANUAL #33

SENSING ELEMENT: ACPFAR-K1 RELAY



SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1939**

INDICATED CONDITION:

- DPBC-1B DC VOLTAGE > 139.6 VDC AS SENSED BY K5H RELAY ON THE HVA w/TD CONTROL BOARD

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- DPBC-1B DC OUTPUT VOLTAGE > 139 VDC.

OPERATOR ACTIONS FOR A VALID ALARM:

- LOWER BUS VOLTAGE.
- ✓ PLACE THE SWING CHARGER IN SERVICE IF AVAILABLE.
- REFER TO OP-705.
- NOTIFY ELECTRICAL SHOP SUPERVISOR

DISCUSSION:

THIS IS INDICATIVE OF A PROBLEM WITH THE OUTPUT OF THE CHARGER. IF LOWERING INPUT VOLTAGE TO THE CHARGER DOES NOT CORRECT THE PROBLEM THE SWING CHARGER SHOULD BE PLACED IN SERVICE. IF VOLTAGE REMAINS HIGH OR CONTINUES TO INCREASE THE CHARGER MAY EXPERIENCE A HIGH VOLTAGE SHUTDOWN.

REFERENCES: VENDOR DRAWING MBC-4766, PM-141, C&D MANUAL #33

SENSING ELEMENT: HVA w/TD BOARD, K5H RELAY





SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1941**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"><li>○ DPBC-1D DC VOLTAGE &gt; 139.6 VDC AS SENSED BY K5H RELAY ON THE HVA w/TD CONTROL BOARD</li></ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"><li>○ DPBC-1D DC OUTPUT VOLTAGE &gt; 139 VDC.</li></ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"><li>○ LOWER BUS VOLTAGE.</li><li>○ PLACE THE SWING CHARGER IN SERVICE IF AVAILABLE.</li><li>○ REFER TO OP-705.</li><li>○ NOTIFY ELECTRICAL SHOP SUPERVISOR.</li></ul>
<p>DISCUSSION:</p> <p>THIS IS INDICATIVE OF A PROBLEM WITH THE OUTPUT OF THE CHARGER. IF LOWERING INPUT VOLTAGE TO THE CHARGER DOES NOT CORRECT THE PROBLEM THE SWING CHARGER SHOULD BE PLACED IN SERVICE. IF VOLTAGE REMAINS HIGH OR CONTINUES TO INCREASE THE CHARGER MAY EXPERIENCE A HIGH VOLTAGE SHUTDOWN.</p>
<p>REFERENCES: VENDOR DRAWING MBC-4766, PM-141, C&amp;D MANUAL #33</p>
<p>SENSING ELEMENT: HVA w/TD BOARD, K5H RELAY</p>

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-07-08	P-07-08
-----------------------------	--------------	---------


**BATTERY  
CHARGER  
TROUBLE**

**EVENT POINT 1942**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li>○ DPBC-1E DC VOLTAGE &gt; 139.6 VDC AS SENSED BY K5H RELAY ON THE HVA w/TD CONTROL BOARD</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li>○ DPBC-1E DC OUTPUT VOLTAGE &gt; 139 VDC.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li>○ LOWER BUS VOLTAGE.</li> <li>○ RETURN THE NORMAL CHARGER TO SERVICE IF AVAILABLE.</li> <li>○ REFER TO OP-705.</li> <li>○ NOTIFY THE ELECTRICAL SHOP SUPERVISOR</li> </ul>
<p>DISCUSSION:</p> <p style="margin-left: 40px;">THIS IS INDICATIVE OF A PROBLEM WITH THE OUTPUT OF THE CHARGER. IF LOWERING INPUT VOLTAGE TO THE CHARGER DOES NOT CORRECT THE PROBLEM THE NORMAL CHARGER SHOULD BE RETURNED TO SERVICE. IF VOLTAGE REMAINS HIGH OR CONTINUES TO INCREASE THE CHARGER MAY EXPERIENCE A HIGH VOLTAGE SHUTDOWN.</p>
<p>REFERENCES: VENDOR DRAWING MBC-4766, PM-141, C&amp;D MANUAL #33</p>
<p>SENSING ELEMENT: HVA w/TD BOARD, K5H RELAY</p>





























SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-08-01	P-08-01
-----------------------------	--------------	---------


**INVERTER E  
FAILURE**

**EVENT POINT 0163**

<p>INDICATED CONDITION:</p> <ul style="list-style-type: none"> <li>LOSS OF INVERTER AC INPUT &lt; 365 VAC AND A LOSS OF DC INPUT &lt; 105 VDC</li> </ul>
<p>REDUNDANT INDICATION WHICH WILL VERIFY ALARM:</p> <ul style="list-style-type: none"> <li>PLANT COMPUTER DEENERGIZED.</li> </ul>
<p>OPERATOR ACTIONS FOR A VALID ALARM:</p> <ul style="list-style-type: none"> <li>MANUALLY TRANSFER VBDP-7 TO ALTERNATE POWER SOURCE.</li> <li>REFER TO OP-703.</li> </ul>
<p>DISCUSSION:</p> <p>LOSS OF THE INVERTER WILL CAUSE ALARMS ON THE ICS PANEL DUE TO THE NNI-Y ALTERNATE POWER SOURCE BEING FROM VBDP-7, AND THE TRANSFER SWITCH BEING A MANUAL TRANSFER SWITCH.</p>
<p>REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA</p>
<p>SENSING ELEMENT: RL11</p>

SSF-A1 ANNUNCIATOR RESPONSE	SSF-A1-08-02	P-08-02
-----------------------------	--------------	---------


**INVERTER E  
TROUBLE**

**EVENT POINT 0168**

INDICATED CONDITION:

- INVERTER DC INPUT AMPERAGE IS > 50 AMPS AS SENSED BY RL2.

---

REDUNDANT INDICATION WHICH WILL VERIFY ALARM:

- BATTERY SOURCE INPUT, RED INDICATING LIGHT ON LOCALLY.
- BATTERY SOURCE INPUT METER VB-005-III1 INDICATING > 50 AMPS LOCALLY.

---

OPERATOR ACTIONS FOR A VALID ALARM:

- INVESTIGATE THE LOSS OF AC INPUT TO THE INVERTER.
- REESTABLISH AC INPUT TO THE INVERTER.

---

DISCUSSION:

THIS IS AN INDICATION OF THE DC INPUT SUPPORTING THE INVERTER OUTPUT. THE CAUSE COULD BE INTERNAL TO THE INVERTER, OR POSSIBLY A LOSS OF AC INPUT TO INVERTER.

REFER TO STS FOR ADMINISTRATIVE REQUIREMENTS.

---

REFERENCES: DRAWING 204-058 SHEET A, 2D6589 30 KVA, AND 2D6590 15 KVA

---

SENSING ELEMENT: RL2















