

THE CINCINNATI GAS & ELECTRIC COMPANY

CINCINNATI, OHIO 45201



TEBA
2nd response

E. A. BORGMANN
VICE PRESIDENT-ENGINEERING

November 9, 1978
QA-1033

U.S. Nuclear Regulatory Commission
Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Attention: Mr. R. F. Heishman, Chief
Reactor Construction & Engineering
Support Branch

RE: WM. H. ZIMMER NUCLEAR POWER STATION - UNIT I
IE INSPECTION REPORT #78-16, DOCKET NO. 50-358,
CONSTRUCTION PERMIT NO. CPPR-88, W.O. #57300-
957, JOB E-5590

Gentlemen:

We wish to supplement our formal reply, letter QA-1021, dated October 17, 1978, to the subject inspection report with the following additional information. It is our opinion that nothing in this letter is of a proprietary nature.

Reference is made to Appendix "A" of Inspection Report #78-16.

Item A (1) - Required Evidence that ESF Motors are Capable of
Certain Starting and Torque Characteristics

The supporting auxiliary system motors for the ESF motors consist of the Reactor Building Closed Cooling Water Pump Motors, the Service Water Pump Motors and other system fan and pump motors which were not addressed in our letter QA-1021.

We are presently in the process of identifying all of the supporting auxiliary system motors for the ESF motors so that certifications may be obtained from the motor manufacturers stating that these motors were designed and built with the minimum starting voltage and breakdown torque characteristics as previously stated in our letter QA-1021. We expect to have this additional information prior to December 31, 1978.

Item C - Inspection Personnel to be in Compliance with
ANSI N45.2.6 - 1973

In addition to the inspection and test personnel from the HVAC Contractor and Cincinnati Gas & Electric Company Electric Operating Test Department,

7812060016

NOV 17 1978

Q

the Quality Assurance and Standards Section will require all contractors involved with essential services or components to have their Inspection and Test personnel comply with the intent of ANSI N45.2.6 - 1973,


Periodic audit will be conducted to assure compliance with this requirement.

We trust this additional information will provide an adequate response to your IE Inspection Report #78-16.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By



E. A. BORGMANN
Vice President, Engineering Services
and Electric Production

RPE:pa