

ATTACHMENT IV
PROPOSED TECHNICAL SPECIFICATION CHANGES

9707100342 970703
PDR ADOCK 05000482
P PDR

DEFINITIONS

CONTAINMENT INTEGRITY

1.7 CONTAINMENT INTEGRITY shall exist when:

- a. All penetrations required to be closed during accident conditions are either:
 - 1) Capable of being closed by an OPERABLE containment automatic isolation valve system, or
 - 2) Closed by manual valves, blind flanges, or deactivated automatic valves secured in their closed positions, except as provided in Table 3.6-1 of Specification 3.6.3.
- b. All equipment hatches are closed and sealed,
- c. Each air lock is in compliance with the requirements of Specification 3.6.1.3,
- d. The sealing mechanism associated with each penetration (e.g., welds, bellows, or O-rings) is OPERABLE, and
- e. The containment leakage rates determined by Specification 4.6.1.1.c are within the limits.

CONTROLLED LEAKAGE

1.8 CONTROLLED LEAKAGE shall be that seal ~~val~~ ~~ve~~ flow from the reactor coolant pump seals.

CORE ALTERATION

1.9 CORE ALTERATION shall be the movement of **any fuel, sources, or reactivity control components**, ~~or manipulation of any component~~ within the reactor vessel with the vessel head removed and fuel in the vessel. Suspension of CORE ALTERATION shall not preclude completion of movement of a component to a safe ~~conservative~~ position.

CORE OPERATING LIMITS REPORT

1.10 The CORE OPERATING LIMITS REPORT (COLR) is the unit-specific document that provides core operating limits for the current operating reload cycle. These cycle-specific core operating limits shall be determined for each reload cycle in accordance with Specification 6.9.1.9. Plant operation within these operating limits is addressed in individual Specifications.