

HOPE CREEK GENERATING STATION
FACILITY OPERATING LICENSE NPF-57
DOCKET NO. 50-354
ADDITIONS TO THE PRIMARY CONTAINMENT ISOLATION VALVE TABLE

TECHNICAL SPECIFICATION PAGES WITH PROPOSED CHANGES

The following Technical Specifications for Facility Operating License No. NPF-57 are affected by this change request:

<u>Technical Specification</u>	<u>Page</u>
Table 3.6.3-1	3/4 6-23 & 3/4 6-28

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

VALVE FUNCTION AND NUMBER	PENETRATION NUMBER	MAXIMUM ISOLATION TIME (Seconds)	NOTE(S)	P&ID
8. Group 8 - Torus Water Cleanup (TWC) System				
(a) TWC Suction Isolation Valves				
Outside:				
HV-4680 (EE-V003)	P223	45	4	M-53-1
HV-4681 (EE-V004)	P223	45	4	
(b) TWC Return Isolation Valves				
Outside:				
HV-4652 (EE-V002)	P222	45	4	M-53-1
HV-4679 (EE-V001)	P222	45	4	
9. Group 9 - Drywell Sumps				
(a) Drywell Floor Drain Sump Discharge Isolation Valves				
Inside: HV-F003 (HB-V005)	P25	30	3	M-61-1
Outside: HV-F004 (HB-V006)	P25	30	3	
Inside: 1HBPSV-11701	P25	NA	3	
(b) Drywell Equipment Drain Sump Discharge Isolation Valves				
Inside: HV-F019 (HB-V045)	P26	30	3	M-61-1
Outside: HV-F020 (HB-V046)	P26	30	3	
Inside: 1HBPSV-11702	P26	NA	3	
10. Group 10 - Drywell Coolers				
(a) Chilled Water to Drywell Coolers Isolation Valves				
Inside:				
Loop A: HV-9531B1 (GB-V081)	P8B	60	3	M-87-1
Loop B: HV-9531B3 (GB-V083)	P38A	60	3	

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

VALVE FUNCTION AND NUMBER	PENETRATION NUMBER	MAXIMUM ISOLATION TIME (Seconds)	NOTE(S)	P&ID
16. Group 16 - Reactor Auxiliaries Cooling System (RACS)				
(a) RACS Supply Isolation Valves				
Inside: HV-2554 (ED-V020)	P29	45	3	M-13-1
Outside: HV-2553 (ED-V019)	P29	45	3	
Inside: IEDPSV-11699	P29	NA	3	
(b) RACS Return Isolation Valves				
Inside: HV-2556 (ED-V022)	P30	45	3	M-13-1
Outside: HV-2555 (ED-V021)	P30	45	3	
Inside: IEDPSV-11700	P30	NA	3	
17. Group 17 - Traversing In-core Probe (TIP) System				
(a) TIP Probe Guide Tube Isolation Valves				
Outside:				
SV-J004A-1 (SE-V026)	P34A	15	3	M-59-1
SV-J004A-2 (SE-V027)	P34B	15	3	
SV-J004A-3 (SE-V028)	P34C	15	3	
SV-J004A-4 (SE-V029)	P34D	15	3	
SV-J004A-5 (SE-V030)	P34E	15	3	
(b) TIP Purge System Isolation Valve				
Outside:				
HV-5161 (SE-V004)	P34F	15	3	M-59-1
18. Group 18 - Reactor Coolant Pressure Boundary (RCPB) Leakage Detection System				
(a) Drywell Leak Detection Radiation Monitoring System (DLD-RMS) Inlet Isolation Valves				
Outside:				
HV-5018 (SK-V005)	J8C	45	3	M-25-1
HV-4953 (SK-V006)	J8C	45	3	