

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241

ComEd

ESK-97-140

July 7, 1997

U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Document Control Desk

Subject: Quad Cities Nuclear Power Station Unit 2
Response to Deferral from Requested Actions of NRC Bulletin 96-03
Docket Number 50-265

Reference: (a) R. M. Pulsifer (NRC) letter of April 29, 1997, to I. Johnson (ComEd)
Deferral from the Requested Actions of NRC Bulletin 96-03 for Quad
Cities Nuclear Power Station Unit 2.

The purpose of this letter is to confirm the completion of the commitments and requested actions of reference (a) for Quad Cities Unit 2.

The torus was desludged during the recently completed refueling outage (Q2R14). We installed larger Emergency Core Cooling System suction strainers of the stacked disk design, removed approximately 95% of the fibrous insulation on piping and valves within the drywell and performed a multi-pump test to verify the absence of neutrally buoyant fiber material in the torus water.

The torus and drywell were also confirmed to be clear of foreign material, including the containment vents and downcomers.

Insulation was inspected by engineering and maintenance at all levels in the drywell and damaged insulation was repaired. The remaining insulation was verified to be properly installed and secured.

1/0

Ie73

9707110374 970707
PDR ADOCK 05000265
G PDR


110052



July 7, 1997

If you have any questions concerning this letter, please contact Mr. Charles Peterson, Regulatory Affairs Manager, at (309) 654-2241, extension 3609.

Respectfully,


E. S. Kraft, Jr.
Site Vice President
Quad Cities Station

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center
Office of Nuclear Facility Safety, IDNS
DCD License (both electronic and hard copies)
M. E. Wagner, Licensing, ComEd