

PHILADELPHIA ELECTRIC COMPANY

2301 MARKET STREET

P.O. BOX 8699

PHILADELPHIA, PA. 19101

(215) 841-4500

JOHN S. KEMPER
SENIOR VICE-PRESIDENT - NUCLEAR

FEB 01 1988

Mr. William T. Russell
Administrator, Region I
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Docket No.: 50-353

Attention: Document Control Desk

SUBJECT: Additional Information related to Systematic
Assessment of Licensee Performance (SALP) for
Limerick Generating Station, Unit 2
Report Number 50-353/86-99
Assessment Period: January 1, 1986 - July 31, 1987

FILE: GOVT 1-1 (NRC)

Dear Mr. Russell:

This letter provides the additional information regarding testing of Limtorque Motor-operators and Preventive Maintenance Program which the NRC requested during the December 7, 1987, SALP Report meeting and that Philadelphia Electric Company (PECo) committed to provide in its SALP response letter dated January 6, 1988.

Testing of Limtorque Motor-Operators

All Limerick Unit 2 Limtorque motor-operators (468 total) are being MOVATS tested. To date, this testing is 80% complete. Much of the MOVATS testing was performed in a shop environment in conjunction with the Limtorque Rework Program which is 95% complete. The hydraulic locking concern is being addressed as part of this rework program. The remaining 20% of Limerick Unit 2 MOVATS testing will be conducted with the motor operators installed in the plant. The Limerick Unit 2 MOVATS testing is scheduled for completion by April 30, 1988.

Preventive Maintenance


In regard to the status of the efforts to assure the proper implementation of the Preventive Maintenance (PM) and equipment storage programs, site personnel have provided the requested information directly to the NRC Resident Inspector.

8802080210 880201
PDR ADOCK 05000353
PDR

IE40
1/0

Should you have any questions or require additional information,
please contact us.

Very truly yours,



J. S. Kemper
Senior Vice-President

RLB/vvg/01288801

Copy to: W. T. Russell, Regional Administrator USNRC Region I
R. A. Gram, Limerick Generating Station Unit 2
USNRC Resident Inspector