

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61242-9740
Tel 309-654-2241



ESK-97-139

July 8, 1997

United States Nuclear Regulatory Commission
Washington, DC 20555

Attention: Document Control Desk

Subject: Quad Cities Station Unit 2
Completion of Commitments Associated with Unit 2
Cycle 14 (Q2R14) Refuel Outage
NRC Docket No. 50-265

On June 22, 1997, ComEd returned Quad Cities Station Unit 2 to service following the unit's fourteenth refuel outage (Q2R14). In the course of that outage, ComEd completed actions related to various NRC commitments. This letter provides a summary of those actions.

The following NRC commitments were completed during this outage:

- a) Repair of the Unit 2 Reactor Head Flange (Commitment made in an NRC and Station Management meeting).
- b) Removal of the furmanite clamp and repair of the Recirculation Pump leak (Commitment made in ESK Letter 96-197, dated October 30, 1996).
- c) Inspection of the Unit 2 Core Shroud modification (Commitment made in ESK Letter 96-032, dated March 15, 1996).
- d) Maintenance on the 2B Residual Heat Removal Heat Exchanger (Commitment made in ESK Letter 96-197, dated October 30, 1996).
- e) Restoration of the Control Room Emergency Ventilation System Train B to full conformance (Commitment made in ESK Letter 97-058, dated March 21, 1997).
- f) Installation of new design Emergency Core Cooling System Suction Strainers and reduction of fibrous material in the Torus. (Commitment made in response to NRC Bulletin 96-03).

9707140444 970708
PDR ADOCK 05000265
P PDR

A Unicom Company




July 8, 1997

- g) Performed inspections of various snubbers throughout the plant (Commitment made in ESK Letter 96-077 dated May 20, 1996).
- h) Completed required testing of Safety Related Contacts (Generic Letter 96-01) for Unit 2. (Commitment made in J. Hosmer letter dated January 28, 1997).

If you have any questions concerning this letter, please contact Mr. Charles Peterson, Regulatory Affairs Manager, at (309) 654-2241, extension 3609.

Respectfully,


E. S. Kraft, Jr.
Site Vice President
Quad Cities Station

cc: A. B. Beach, Regional Administrator, Region III
R. M. Pulsifer, Project Manager, NRR
C. G. Miller, Senior Resident Inspector, Quad Cities
W. D. Leech, MidAmerican Energy Company
D. C. Tubbs, MidAmerican Energy Company
F. A. Spangenberg, Regulatory Affairs Manager, Dresden
INPO Records Center
Office of Nuclear Facility Safety, IDNS
DCD License (both electronic and hard copies)
M. E. Wagner, Licensing, ComEd