PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-IV-88-09

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region IV staff on this date.

FACILITY:	Nebraska Public Power District Cooper Nuclear Station	Licensee Emergency Classification Notification of Unusual Event		
	Brownville, Nebraska	Alert		
	DN: 50-298	Site Area Emergency		
		General Emergency		
		V Not Applicable		

SUBJECT: SHUTDOWN IN EXCESS OF 48 HOURS

On January 28, 1988, a reactor scram occurred from 45 percent power because of a speed control problem with the B reactor recirculation pump motor generator. After the scram, the licensee discovered a ground in the B residual heat removal (RHR) pump motor. Although the licensee has corrected and is testing the reactor recirculation pump motor generator, the plant remains in cold shutdown while the licensee investigates the RHR pump motor ground. The plant is scheduled to begin a 2-month refueling outage on February 22, 1988. The senior resident is monitoring licensee actions.

There have been no news media inquires regarding this matter.

Neither the licensee nor the NRC plans to issue a press release.

Region IV received notification of the licensee's progress by telephone call from the senior resident inspector at 7:50 a.m. on February 1, 1988.

CONTACT: E. J. Holler, FTS 728-8287 DISTRIBUTION:

H. St. Chairman Zech	MNBB	E/W	Willste_ NMSS	DCS (Original) DOT: (Trans only)	
Comm. Roberts Comm. Bernthal Comm. Carr Comm. Rogers ACRS SECY	PA OGC MPA ARM	OI VIB		FAX: INPO NSAC RRI NRC OC	
CA PDR OGC-H GPA	PhillipsNRR	— AirRights SLITP	7	LICENSEE: (Reactor Licensee)	
ACRS PDR	Nicholson Lane RES Regional Offices		Transmitted via 5520 @2:05 - 2/1/88.		
RIV:DRP & LJCallan:gb 1/88	RAW RDMartin 71)/88			34	
8802080287	980201			6.0	

8802080287 880201 PDR I&E PND-IV-88-009 PDR 1234