

Ms. Cindy Gagne  
510 West First Street South  
Fulton, NY 13069

July 10, 1997

Ms. Linda Downing  
107 Albright Road  
Mexico, NY 13114

Dear Ms. Gagne and Ms. Downing:

In accordance with Mr. Steven A. Varga's letter to you dated June 10, 1997, I am enclosing copies of the July 2, 1997, application for license amendment that has been submitted by Niagara Mohawk Power Corporation. The proposed amendment would revise the reactor coolant chemistry limits in the Technical Specifications for Nine Mile Point Nuclear Station, Unit No. 1, in response to the NRC staff's letter of May 8, 1997, regarding the weld cracks in the core shroud.

I currently anticipate that the notice of proposed license amendment will be published in the Federal Register on July 30, 1997. As was discussed in detail in Mr. Varga's letter, that notice will offer the opportunity to provide comments or request an adjudicatory hearing on the proposed amendment.

Sincerely,

/s/

Darl S. Hood, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure: As Stated

DF01  
11

DOCUMENT NAME: G:\NMP1\GAGNE4

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	PM:PDI-1	LA:PDI-1	D:PDI-1			
NAME	DHood/rs1 DSA	SLittle	ADromerick(A)			
DATE	07/10/97	07/10/97	07/10/97			

Official Record Copy

**DISTRIBUTION:**

Docket File 50-220  
(Reference GT 970364)

PUBLIC  
PDI-1 R/F  
B. Boger  
J. Zwolinski  
A. Dromerick

C. Norsworthy  
S. Little  
K. Bohrer  
D. Hood

9707150043 970710  
PDR ADOCK 05000220  
H PDR

FILE CENTER COPY





UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

July 10, 1997

Ms. Cindy Gagne  
510 West First Street South  
Fulton, NY 13069

Ms. Linda Downing  
107 Albright Road  
Mexico, NY 13114

Dear Ms. Gagne and Ms. Downing:

In accordance with Mr. Steven A. Varga's letter to you dated June 10, 1997, I am enclosing copies of the July 2, 1997, application for license amendment that has been submitted by Niagara Mohawk Power Corporation. The proposed amendment would revise the reactor coolant chemistry limits in the Technical Specifications for Nine Mile Point Nuclear Station, Unit No. 1, in response to the NRC staff's letter of May 8, 1997, regarding the weld cracks in the core shroud.


I currently anticipate that the notice of proposed license amendment will be published in the Federal Register on July 30, 1997. As was discussed in detail in Mr. Varga's letter, that notice will offer the opportunity to provide comments or request an adjudicatory hearing on the proposed amendment.

Sincerely,

*Darl Hood*

Darl S. Hood, Senior Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Enclosure: As Stated



NIAGARA MOHAWK

GENERATION  
BUSINESS GROUP

NUCLEAR LEARNING CENTER, 450 LAKE ROAD, OSWEGO, NY 13126/TELEPHONE (315) 349-2882

B. RALPH SYLVIA  
Executive Vice President  
Electric Generation  
Chief Nuclear Officer

July 2, 1997  
NMP1L 1232

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

RE:           Nine Mile Point Unit 1  
              Docket No. 50-220  
              DPR-63

Gentlemen:

During the 1997 refueling outage at Nine Mile Point Unit 1 (NMP1), inspection of the core shroud vertical welds revealed cracks in excess of the screening criteria. By letter dated April 8, 1997, Niagara Mohawk Power Corporation (NMPC) provided design documentation and evaluations to demonstrate the acceptability of the as-found vertical weld cracking in the NMP1 core shroud for at least 10,600 hours of hot (above 200 degrees F) operation. By letter dated May 8, 1997, the NRC issued a Safety Evaluation approving the restart of NMP1 contingent on: 1) maintaining reactor coolant chemistry within the guidelines set forth in the Electric Power Research Institute (EPRI) technical report TR-103515-R1 (BWRVIP-29), "BWR Water Chemistry Guidelines - 1996 Revision," and 2) the requirement that NMPC submit an application for a license amendment to address the difference between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates. The NRC approved the NMPC analysis predicated on the condition that NMP1 is operated in accordance with the BWR water chemistry guidelines. This application for amendment is being submitted to address the NRC's second contingency.


NMPC hereby transmits an Application for Amendment to NMP1 Operating License DPR-63. Also enclosed as Attachment A is the proposed change to the Technical Specifications (TS) set forth in Appendix A to the above mentioned license. Supporting information and analyses which demonstrate that the proposed change involves no significant hazards consideration pursuant to 10CFR50.92 are included as Attachment B. A marked-up copy of the affected TS pages is provided as Attachment C to assist your review.

9707110348 2pp.

The proposed change revises Sections 3.2.3 and 4.2.3 to reflect the BWR water chemistry guidelines. In addition, the Bases for 3.2.3 and 4.2.3, "Coolant Chemistry", has been revised. These changes address the differences between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates.

Pursuant to 10CFR50.91(b)(1), NMPC has provided a copy of this license amendment request and the associated analysis regarding no significant hazards consideration to the appropriate state representative.

Very truly yours,



B. R. Sylvia  
Chief Nuclear Officer

BRS/TRE/cmK  
Attachments

xc: Mr. H. J. Miller, NRC Regional Administrator  
Mr. A. W. Dromerick, Acting Director, Project Directorate, I-1, NRR  
Mr. B. S. Norris, Senior Resident Inspector  
Mr. D. S. Hood, Senior Project Manager, NRR  
Mr. J. P. Spath  
NYSERDA  
2 Empire Plaza, Suite 1901  
Albany, NY 12223-1253  
Records Management



UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of )

Niagara Mohawk Power Corporation )

Nine Mile Point Unit 1 )

) Docket No. 50-220  
)  
)  
)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation (NMPC), holder of Facility Operating License No. DPR-63, hereby requests that Section 3.2.3 and the associated surveillance Section 4.2.3 of the Technical Specifications (TS) set forth in Appendix A to that license be amended. The proposed changes have been reviewed in accordance with Section 6.5, "Review and Audit," of the Nine Mile Point Unit 1 (NMP1) TS.

The proposed change revises the NMP1 TS Section 3.2.3 to reflect the "BWR water chemistry guidelines, 1996 revision" (EPRI TR-103515-R1, BWRVIP-29). Sections 3.2.3a and 3.2.3b define new conductivity limits when the reactor water is  $\geq 200$  degrees F and thermal power is  $\leq 10\%$ , and when thermal power is  $> 10\%$ . The new conductivity limit is now  $1 \mu\text{mho/cm}$  compared to the existing limits of  $2 \mu\text{mho/cm}$  and  $5 \mu\text{mho/cm}$ . The chloride ion limit from Section 3.2.3a remains at the same level but it is listed as 100 ppb instead of 0.1 ppm. The chloride ion limit from Section 3.2.3b is changed from 0.2 ppm to 20 ppb. Sulfate ion limits are added to Sections 3.2.3a and 3.2.3b at 100 ppb and 20 ppb, respectively. From Section 3.2.3c the maximum conductivity limit is changed from  $10 \mu\text{mho/cm}$  to  $5 \mu\text{mho/cm}$ , the maximum chloride ion concentration limit is changed from 0.5 ppm to 100 ppb and 200 ppb, and the maximum sulfate ion concentration of 100 ppb and 200 ppb is added.

The proposed change revises NMP1 TS Section 4.2.3 to include sulfate ions as a component to be included in the sample analysis.

Included in this TS change is a change to the Bases for 3.2.3 and 4.2.3, "Coolant Chemistry". The Bases has been changed to reflect the purpose of the specification which is to limit intergranular stress corrosion cracking (IGSCC) crack growth rates through the control of reactor coolant chemistry. The Bases describes the NMP1 operating philosophy of maintaining average levels for conductivity and chloride and sulfate concentrations over an operating cycle. Operation of the plant within these average values will ensure that the crack growth rate is bounded by the core shroud analysis.

The proposed change will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analyses which demonstrate no significant hazards considerations pursuant to 10CFR50.92, are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By *B.R. Sylvia*  
B. R. Sylvia  
Chief Nuclear Officer

Subscribed and Sworn to before me  
on this 2nd day of July 1997.

*Beverly W. Ripka*  
NOTARY PUBLIC

BEVERLY W. RIPKA  
Notary Public State of New York  
Qual. in Oswego Co. No. 4544879  
My Commission Exp. Mar. 30, 1998  
2/28/98

ATTACHMENT A

NIAGARA MOHAWK POWER CORPORATION

LICENSE NO. DPR-63

DOCKET NO. 50-220

Proposed Changes to Technical Specifications

Replace the existing pages 96, 97, and 98 with the attached revised pages 96, 97, and 98. The pages have been retyped in their entirety with marginal markings to indicate changes.

970710351 11/10/01

LIMITING CONDITION FOR OPERATION

3.2.3 COOLANT CHEMISTRY

Applicability:

Applies to the reactor coolant system chemical requirements.

Objective:

To assure the chemical purity of the reactor coolant water.

Specification:

- a. The reactor coolant water shall not exceed the following limits with the coolant temperature  $\geq 200$  degrees F and reactor thermal power  $\leq 10\%$ , except as specified in 3.2.3c:

Conductivity	1 $\mu\text{mho/cm}$
Chloride ion	100 ppb
Sulfate ion	100 ppb

- b. The reactor coolant water shall not exceed the following limits with reactor thermal power  $> 10\%$ , except as specified in 3.2.3c:

Conductivity	1 $\mu\text{mho/cm}$
Chloride ion	20 ppb
Sulfate ion	20 ppb

SURVEILLANCE REQUIREMENT

4.2.3 COOLANT CHEMISTRY

Applicability:

Applies to the periodic testing requirements of the reactor coolant chemistry.

Objective:

To determine the chemical purity of the reactor coolant water.

Specification:

Samples shall be taken and analyzed for conductivity, chloride and sulfate ion content at least 3 times per week with a maximum time of 96 hours between samples. In addition, if the conductivity becomes abnormal (other than short term spikes) as indicated by the continuous conductivity monitor, samples shall be taken and analyzed within 8 hours and daily thereafter until conductivity returns to normal levels.

When the continuous conductivity monitor is inoperable, a reactor coolant sample shall be taken and analyzed for conductivity, chloride and sulfate ion content at least once per 8 hours.

LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

- c. The limits specified in 3.2.3a and 3.2.3b may be exceeded for a period of time not to exceed 24 hours. In no case shall the reactor coolant exceed the following limits at the specified conditions:
  - 1. With reactor coolant temperature  $\geq 200$  degrees F, the conductivity has a maximum limit of  $5\mu\text{mho/cm}$ , or
  - 2. With reactor coolant temperature  $\geq 200$  degrees F and reactor thermal power  $\leq 10\%$ , the maximum limit of chloride or sulfate ion concentration is 200 ppb, or
  - 3. With reactor thermal power  $> 10\%$ , the maximum limit of chloride or sulfate ion concentration is 100 ppb.
- d. If Specifications 3.2.3a, b, and c are not met, normal orderly shutdown shall be initiated within one hour and the reactor shall be shutdown and reactor coolant temperature be reduced to  $< 200$  degrees F within ten hours.
- e. If the continuous conductivity monitor is inoperable for more than seven days, the reactor shall be shutdown and reactor coolant temperature be reduced to  $< 200$  degrees F within 24 hours.



## BASES FOR 3.2.3 AND 4.2.3 COOLANT CHEMISTRY

This specification is being submitted to address an NRC safety evaluation requirement. In its May 8, 1997 letter, the NRC required that NMPC submit an application for amendment to address the differences between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for the core shroud crack growth evaluations. The purpose of this specification is to limit intergranular stress corrosion cracking (IGSCC) crack growth rates through the control of reactor coolant chemistry. The LCO values ensure that transient conditions are acted on to restore reactor coolant chemistry values to normal in a reasonable time frame. Under transient conditions, potential crack growth rates could exceed analytical assumptions, however, the duration will be limited so that any effect on potential crack growth is minimized and the design basis assumptions are maintained. The plant is normally operated such that the average chemistry for the operating cycle is maintained at the conservative values of  $< 0.2 \mu\text{mho/cm}$  for conductivity and  $< 5 \text{ ppb}$  for chloride ions  $< 5 \text{ ppb}$  for sulfate ions. This will ensure that the crack growth rate is bounded by the core shroud analysis assumptions (the analysis shows the crack growth to be  $< 2.2\text{E-}5 \text{ in/hr}$  for these levels). Since these are average values, there are no specific LCO actions to be taken if these values are exceeded at a specific point in time.

Specification 3.2.3a, b, and c is consistent with the BWR water coolant chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29). The 24 hour action time period for exceeding the coolant chemistry limits described in 3.2.3a and b ensures that prompt action is taken to restore coolant chemistry to normal operating levels. The requirement to commence shutdown within 1 hour, and to be shutdown and reactor coolant temperature be reduced to  $< 200 \text{ degrees F}$  within 10 hours minimizes the potential for IGSCC crack growth.

A short term spike is defined as a rise in conductivity ( $> 0.2 \mu\text{mho/cm}$ ) such as that which could arise from injection of additional feedwater flow for a duration of approximately 30 minutes in time.

When conductivity is in its proper normal range, chloride, sulfate, and other impurities affecting conductivity must also be within their normal range. When and if conductivity becomes abnormal, then chloride and sulfate measurements are made to determine whether or not they are also out of their normal operating values. Significant changes provide the operator with a warning mechanism so he can investigate and remedy the condition causing the change and ensure that normal operating average conditions are maintained within the bounds of the core shroud crack growth analytical assumptions. Methods available to the operator for correcting the off-standard condition include, operation of the reactor clean-up system, reducing the input of impurities, and placing the reactor in shutdown and reducing reactor coolant temperature to  $< 200 \text{ degrees F}$ . The major benefit of reducing reactor coolant temperature to  $< 200 \text{ degrees F}$  is to reduce the temperature dependent corrosion rates and provide time for the clean-up system to re-establish the purity of the reactor coolant.

The conductivity of the reactor coolant is continuously monitored. The samples of the coolant which are analyzed for conductivity every 96 hours will serve as a comparison with the continuous conductivity monitor. The reactor coolant samples will also be used to determine the chloride and sulfate concentrations. Therefore, the sampling frequency is considered adequate to detect long-term changes in the chloride and sulfate ion content. However, if the conductivity becomes abnormal ( $> 0.2 \mu\text{mho/cm}$ ), chloride and sulfate measurements will be made to assure that the normal limits ( $< 5 \text{ ppb}$  of chloride or sulfate) are maintained.

## ATTACHMENT B

### NIAGARA MOHAWK POWER CORPORATION

LICENSE NO. DPR-63

DOCKET NO. 50-220

#### Supporting Information and No Significant Hazards Consideration Analysis

#### INTRODUCTION

The proposed Nine Mile Point Unit 1 (NMP1) Technical Specification (TS) change contained herein presents a revision to NMP1 TS Sections 3.2.3 and 4.2.3, and the Bases for 3.2.3 and 4.2.3, "Coolant Chemistry".

By letter dated April 8, 1997, Niagara Mohawk Power Corporation (NMPC) provided design documentation and evaluations to demonstrate the acceptability of the as-found vertical weld cracking in the NMP1 core shroud for at least 10,600 hours of hot (above 200 degrees F) operation. In its May 8, 1997 letter, "Modifications to Core Shroud Stabilizer Lower Wedge Retaining Clip and Evaluation of Shroud Vertical Weld Cracking, Nine Mile Point Nuclear Station, Unit 1," approving the restart of NMP1, the NRC required that NMPC submit an application for a license amendment addressing the difference between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates.

This proposed change incorporates into the TS the reactor coolant chemistry assumptions that were used for the core shroud weld crack evaluations.

#### EVALUATION

The proposed revisions to TS Sections 3.2.3a, b, c, d, and e incorporate the analytical assumptions that were used by NMPC to evaluate the vertical weld cracking found in the NMP1 core shroud during the 1997 refueling outage. The TS changes establish limits for conductivity and chloride and sulfate ion concentrations that are equal to or more restrictive than the existing TS values. As a result of the analysis, an average value of 0.2  $\mu\text{mho/cm}$  has been chosen for conductivity which is less than the BWR guideline action level 1 value for conductivity of 0.3  $\mu\text{mho/cm}$ .

The purpose of this TS change is to limit IGSCC crack growth rates through the control of reactor coolant chemistry. The proposed LCO values ensure that transient conditions are acted on to restore reactor coolant chemistry values to normal levels in a reasonable time frame. Under transient conditions, potential crack growth rates could exceed analytical assumptions, however, the duration will be limited so that any effect on potential crack growth is minimized and the design basis assumptions are maintained. The plant is operated such that the average coolant chemistry values for the operating cycle are maintained at the conservative values of  $< 0.2 \mu\text{mho/cm}$  for conductivity and  $< 5 \text{ ppb}$  for

chloride or sulfate ions. This will ensure that the crack growth rate is bounded by the  $5E-5$  in/hr core shroud analysis assumptions, since the analysis shows a crack growth rate of  $< 2.2E-5$  in/hr for these chemistry levels. Since the conductivity and chloride and sulfate ion values are average values, there are no specific LCO actions to be taken if these values are exceeded at a specific point in time. However, plant procedures will ensure that actions are taken to reduce the chemistry levels to the appropriate levels within a reasonable time frame.

The NMP1-specific analysis has established that the BWRVIP-14, Section 6.1.1 stress intensity independent crack growth rate of  $2.2E-5$  in/hr is conservative for NMP1, provided that the average reactor coolant conductivity is maintained  $< 0.2 \mu\text{mho/cm}$ . The reactor coolant conductivity applied in the analysis derived a "model" conductivity which considers that reactor coolant is at the 5 ppb limits associated with the chloride and sulfate ion concentrations. Typically conductivity is maintained below  $0.1 \mu\text{mho/cm}$  on a cycle average basis. This ensures that the NMP1-specific shroud analysis calculated crack growth is bounded by the  $2.2E-5$  in/hr growth rate as determined by the BWRVIP-14 disposition.

## CONCLUSIONS

The design documentation and evaluations provided by NMPC to demonstrate the acceptability of the as-found vertical weld cracking in the NMP1 core shroud for at least 10,600 hours of hot (above 200 degrees F) operation were accepted by the NRC. However, the NRC's safety evaluation was contingent on maintaining reactor coolant chemistry within the BWR water chemistry guidelines, 1996 revision, and on the submittal of an application for amendment that addressed the difference between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates. These proposed changes, which are equal to or more restrictive than the present TS values, will assure that NMP1 is operated within the requirements of the analysis used for the NRC's safety evaluation.

## ANALYSIS

### No Significant Hazards Consideration Analysis

10CFR50.91 requires that at the time a licensee requests an amendment, it must provide to the Commission its analysis using the standards in 10CFR50.92 concerning the issue of no significant hazards consideration. Therefore, in accordance with 10CFR50.91, the following analyses have been performed with respect to the requested change:

The operation of Nine Mile Point Unit 1, in accordance with the proposed amendment, will not involve a significant increase in the probability or consequences of an accident previously evaluated.

The changes to the conductivity and chloride ion action levels and the addition of sulfate ion levels as an action level in reactor water chemistry are being made to make the TS and its Bases consistent with the values used in the core shroud vertical weld cracking evaluations. These new values reflect the BWR water chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29) and are equal to or more restrictive than the present TS values. No physical modification of the plant is involved and no changes to the methods in

which plant systems are operated are required. None of the precursors of previously evaluated accidents are affected and therefore, the probability of an accident previously evaluated is not increased. These changes to the coolant chemistry TS are more restrictive limits and no new failure modes are introduced. Therefore, these changes will not involve a significant increase in the consequences of an accident previously evaluated.

The operation of Nine Mile Point Unit 1, in accordance with the proposed amendment, will not create the possibility of a new or different kind of accident from any accident previously evaluated.

The changes to the conductivity and chloride ion action levels and the addition of sulfate ion levels as an action level in reactor water chemistry are being made to make the TS and its Bases consistent with the values used in the core shroud vertical weld cracking evaluations. These new values reflect the BWR water chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29) and are equal to or more restrictive than the present TS values. No physical modification of the plant is involved and no changes to the methods in which plant systems are operated are required. The change does not introduce any new failure modes or conditions that may create a new or different accident. Therefore, this change does not create the possibility of a new or different kind of accident previously evaluated.

The operation of Nine Mile Point Unit 1, in accordance with the proposed amendment, will not involve a significant reduction in a margin of safety.

The changes to the conductivity and chloride ion action levels and the addition of sulfate ion levels as an action level in reactor water chemistry are being made to make the TS and its Bases consistent with the values used in the core shroud vertical weld cracking evaluations. These new values reflect the BWR water chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29) and are equal to or more restrictive than the present TS values. No physical modification of the plant is involved and no changes to the methods in which plant systems are operated are required. This change does not adversely affect any physical barrier to the release of radiation to plant personnel or the public. Therefore, the change does not involve a significant reduction in a margin of safety.



ATTACHMENT C

NIAGARA MOHAWK POWER CORPORATION

LICENSE NO. DPR-63

DOCKET NO. 50-220

Marked Copy of Proposed Changes to Current Technical Specification

The current version of pages 96, 97, and 98 of the NMP1 Technical Specifications have been hand marked-up to reflect the proposed changes.



**LIMITING CONDITION FOR OPERATION**

**3.2.3 COOLANT CHEMISTRY**

Applicability:

Applies to the reactor coolant system chemical requirements.

Objective:

To assure the chemical purity of the reactor coolant water.

Specification:

- a. The reactor coolant water shall not exceed the following limits with ~~steaming rates less than 100,000 pounds per hour~~ *the coolant temperature  $\geq 200$  degrees and reactor thermal power  $\leq 107$ ,* except as specified in 3.2.3c:

Conductivity	1.2 $\mu$ mho/cm
Chloride ion	0.1 ppm - 100 ppb
SULFATE ion	100 ppb

- b. The reactor coolant water shall not exceed the following limits with ~~steaming rates greater than or equal to 100,000 pounds per hour~~ *reactor thermal power  $> 107$ ,* except as specified in 3.2.3c:

Conductivity	1.8 $\mu$ mho/cm
Chloride ion	0.2 ppm - 20 ppb
SULFATE ion	20 ppb

**SURVEILLANCE REQUIREMENT**

**4.2.3 COOLANT CHEMISTRY**

Applicability:

Applies to the periodic testing requirements of the reactor coolant chemistry.

Objective:

To determine the chemical purity of the reactor coolant water.

Specification: *and sulfate*

Samples shall be taken and analyzed for conductivity and chloride ion content at least 3 times per week with a maximum time of 96 hours between samples. In addition, if the conductivity becomes abnormal (other than short term spikes) as indicated by the continuous conductivity monitor, samples shall be taken and analyzed within 8 hours and daily thereafter until conductivity returns to normal levels.

When the continuous conductivity monitor is inoperable, a reactor coolant sample shall be taken and analyzed for conductivity, *and sulfate* and chloride ion content at least once per 8 hours.

LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

c. The limits specified in 3.2.3a and 3.2.3b may be exceeded for a period of time not to exceed 24 hours. In no case shall (1) the conductivity exceed a maximum limit of 10  $\mu\text{mho/cm}$ , or (2) the chloride ion concentration exceed a maximum limit of 0.5 ppm.

*the reactor coolant exceed the following limits at the specified conditions;*

d. If Specifications 3.2.3a, b, and c are not met, normal orderly shutdown shall be initiated within one hour and the reactor shall be in the cold shutdown condition within ten hours.

*and reactor coolant temperature be reduced to < 200 degrees F*

e. If the continuous conductivity monitor is inoperable for more than 7 days the reactor shall be placed in the cold shutdown condition within 24 hours.

*and reactor coolant temperature be reduced to < 200 degrees F*

1. With reactor coolant temperature  $\geq 200$  degrees F, the conductivity has a maximum limit of 5  $\mu\text{mho/cm}$ , or

2. With reactor coolant temperature  $\geq 200$  degrees F and reactor thermal power  $\leq 10\%$ , the maximum limit of chloride or sulfate ion concentration is 200 ppb, or

3. With reactor thermal power  $> 10\%$ , the maximum limit of chloride or sulfate ion concentration is 100 ppb.

REPLACE WITH ATTACHED

### BASES FOR 3.2.3 AND 4.2.3 COOLANT CHEMISTRY

Materials in the primary system are primarily 304 stainless steel and the Zircaloy fuel cladding. The reactor water chemistry limits are established to prevent damage to these materials. Limits are placed on chloride concentration and conductivity. The most important limit is that placed on chloride concentration to prevent stress corrosion cracking of the stainless steel. When the steaming rate is less than 100,000 pounds per hour, a more restrictive limit of 0.1 ppm has been established. At steaming rates of at least 100,000 pounds per hour, boiling occurs causing deaeration of the reactor water, thus maintaining oxygen concentration at low levels.

A short term spike is defined as a rise in conductivity <sup>( $> 2 \mu\text{mho/cm}$ )</sup> such as that which could arise from injection of additional feedwater flow for a duration of approximately 30 minutes in time.

When conductivity is in its proper normal range, pH and chloride and other impurities affecting conductivity must also be within their normal range. When and if conductivity becomes abnormal, then chloride <sup>SULFATE, and sulfate</sup> measurements are made to determine whether or not they are also out of their normal operating values. This would not necessarily be the case. Conductivity could be high due to the presence of a neutral salt, e.g.,  $\text{Na}_2\text{SO}_4$ , which would not have an effect on pH or chloride. In such a case, high conductivity alone is not a cause for shutdown. In some types of water-cooled reactors, conductivities are in fact high due to purposeful addition of additives. In the case of BWR's,

however, where no additives are used and where neutral pH is maintained, conductivity provides a very good measure of the quality of the reactor water. Significant changes therein provide the operator with a warning mechanism so he can investigate and remedy the condition causing the change <sup>and ensure that normal operating average conditions are maintained within the bounds of the core should such</sup> before limiting conditions, with respect to variables affecting boundaries of the reactor coolant, are exceeded. Methods available to the operator for correcting the off-standard condition include operation of the reactor clean-up system, reducing the input of impurities, and placing the reactor in the cold shutdown condition <sup>and reducing reactor coolant temperature by  $< 100$  degrees F. Applying reactor temperature to  $< 200$  degrees</sup>. The major benefit of cold shutdown is to reduce the temperature dependent corrosion rates and provide time for the clean-up system to re-establish the purity of the reactor coolant. During start-up periods, which are in the category of less than 100,000 pounds per hour, conductivity may exceed  $2 \mu\text{mho/cm}$  because of the initial evolution of gases and the initial addition of dissolved metals. During this period of time, when the conductivity exceeds  $2 \mu\text{mho}$  (other than short term spikes), samples will be taken to assure that the chloride concentration is less than 0.1 ppm.


The conductivity <sup>of</sup> of the reactor coolant is continuously monitored. The samples of the coolant which are <sup>analyzed for conductivity</sup> taken every 96 hours will serve as a <sup>comparison with the continuous conductivity monitor</sup> reference for calibration of these monitors and is considered adequate to assure accurate readings of the monitors. If conductivity is within its normal range, chlorides and other impurities will also be within their normal ranges. The reactor coolant samples will also be used to determine the chloride <sup>and sulfate concentrations</sup> content. However, if the conductivity <sup>becomes abnormal ( $> 2 \mu\text{mho/cm}$ )</sup> changes significantly, chloride <sup>and sulfate</sup> measurements will be made to assure that the chloride limits of <sup>normal</sup> ( $< 5 \text{ppb of}$  Specification 3.2.3 are not exceeded. <sup>CHLORIDE OR SULFATE) are maintained.</sup>

# INSERT IN BASES

This specification is being submitted to address an NRC safety evaluation requirement. In its May 8, 1997 letter, the NRC required that NMPC submit an application for amendment to address the differences between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for the core shroud crack growth evaluations. The purpose of this specification is to limit intergranular stress corrosion cracking (IGSCC) crack growth rates through the control of reactor coolant chemistry. The LCO values ensure that transient conditions are acted on to restore reactor coolant chemistry values to normal in a reasonable time frame. Under transient conditions, potential crack growth rates could exceed analytical assumptions, however, the duration will be limited so that any effect on potential crack growth is minimized and the design basis assumptions are maintained. The plant is normally operated such that the average chemistry for the operating cycle is maintained at the conservative values of  $< 0.2 \mu\text{mho/cm}$  for conductivity and  $< 5 \text{ ppb}$  for chloride ions  $< 5 \text{ ppb}$  for sulfate ions. This will ensure that the crack growth rate is bounded by the core shroud analysis assumptions (the analysis shows the crack growth to be  $< 2.2\text{E-}5 \text{ in/hr}$  for these levels). Since these are average values, there are no specific LCO actions to be taken if these values are exceeded at a specific point in time.

Specification 3.2.3a, b, and c is consistent with the BWR water coolant chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29). The 24 hour action time period for exceeding the coolant chemistry limits described in 3.2.3a and b ensures that prompt action is taken to restore coolant chemistry to normal operating levels. The requirement to commence shutdown within 1 hour, and to be shutdown and reactor coolant temperature be reduced to  $< 200 \text{ degrees F}$  within 10 hours minimizes the potential for IGSCC crack growth.





NIAGARA MOHAWK

GENERATION  
BUSINESS GROUP

NUCLEAR LEARNING CENTER, 450 LAKE ROAD, OSWEGO, NY 13126/TELEPHONE (315) 349-2882

B. RALPH SYLVIA  
Executive Vice President  
Electric Generation  
Chief Nuclear Officer

July 2, 1997  
NMP1L 1232

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

RE:                   Nine Mile Point Unit 1  
                          Docket No. 50-220  
                          DPR-63

Gentlemen:

During the 1997 refueling outage at Nine Mile Point Unit 1 (NMP1), inspection of the core shroud vertical welds revealed cracks in excess of the screening criteria. By letter dated April 8, 1997, Niagara Mohawk Power Corporation (NMPC) provided design documentation and evaluations to demonstrate the acceptability of the as-found vertical weld cracking in the NMP1 core shroud for at least 10,600 hours of hot (above 200 degrees F) operation. By letter dated May 8, 1997, the NRC issued a Safety Evaluation approving the restart of NMP1 contingent on: 1) maintaining reactor coolant chemistry within the guidelines set forth in the Electric Power Research Institute (EPRI) technical report TR-103515-R1 (BWRVIP-29), "BWR Water Chemistry Guidelines - 1996 Revision," and 2) the requirement that NMPC submit an application for a license amendment to address the difference between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates. The NRC approved the NMPC analysis predicated on the condition that NMP1 is operated in accordance with the BWR water chemistry guidelines. This application for amendment is being submitted to address the NRC's second contingency.


NMPC hereby transmits an Application for Amendment to NMP1 Operating License DPR-63. Also enclosed as Attachment A is the proposed change to the Technical Specifications (TS) set forth in Appendix A to the above mentioned license. Supporting information and analyses which demonstrate that the proposed change involves no significant hazards consideration pursuant to 10CFR50.92 are included as Attachment B. A marked-up copy of the affected TS pages is provided as Attachment C to assist your review.



The proposed change revises Sections 3.2.3 and 4.2.3 to reflect the BWR water chemistry guidelines. In addition, the Bases for 3.2.3 and 4.2.3, "Coolant Chemistry", has been revised. These changes address the differences between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates.

Pursuant to 10CFR50.91(b)(1), NMPC has provided a copy of this license amendment request and the associated analysis regarding no significant hazards consideration to the appropriate state representative.

Very truly yours,



B. R. Sylvia  
Chief Nuclear Officer

BRS/TRE/cmk  
Attachments

xc: Mr. H. J. Miller, NRC Regional Administrator  
Mr. A. W. Dromerick, Acting Director, Project Directorate, I-1, NRR  
Mr. B. S. Norris, Senior Resident Inspector  
Mr. D. S. Hood, Senior Project Manager, NRR  
Mr. J. P. Spath  
NYSERDA  
2 Empire Plaza, Suite 1901  
Albany, NY 12223-1253  
Records Management

UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of )

Niagara Mohawk Power Corporation )

Nine Mile Point Unit 1 )

) Docket No. 50-220  
)  
)

APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the Regulations of the Nuclear Regulatory Commission, Niagara Mohawk Power Corporation (NMPC), holder of Facility Operating License No. DPR-63, hereby requests that Section 3.2.3 and the associated surveillance Section 4.2.3 of the Technical Specifications (TS) set forth in Appendix A to that license be amended. The proposed changes have been reviewed in accordance with Section 6.5, "Review and Audit," of the Nine Mile Point Unit 1 (NMP1) TS.

The proposed change revises the NMP1 TS Section 3.2.3 to reflect the "BWR water chemistry guidelines, 1996 revision" (EPRI TR-103515-R1, BWRVIP-29). Sections 3.2.3a and 3.2.3b define new conductivity limits when the reactor water is  $\geq 200$  degrees F and thermal power is  $\leq 10\%$ , and when thermal power is  $> 10\%$ . The new conductivity limit is now  $1 \mu\text{mho/cm}$  compared to the existing limits of  $2 \mu\text{mho/cm}$  and  $5 \mu\text{mho/cm}$ . The chloride ion limit from Section 3.2.3a remains at the same level but it is listed as 100 ppb instead of 0.1 ppm. The chloride ion limit from Section 3.2.3b is changed from 0.2 ppm to 20 ppb. Sulfate ion limits are added to Sections 3.2.3a and 3.2.3b at 100 ppb and 20 ppb, respectively. From Section 3.2.3c the maximum conductivity limit is changed from  $10 \mu\text{mho/cm}$  to  $5 \mu\text{mho/cm}$ , the maximum chloride ion concentration limit is changed from 0.5 ppm to 100 ppb and 200 ppb, and the maximum sulfate ion concentration of 100 ppb and 200 ppb is added.

The proposed change revises NMP1 TS Section 4.2.3 to include sulfate ions as a component to be included in the sample analysis.

Included in this TS change is a change to the Bases for 3.2.3 and 4.2.3, "Coolant Chemistry". The Bases has been changed to reflect the purpose of the specification which is to limit intergranular stress corrosion cracking (IGSCC) crack growth rates through the control of reactor coolant chemistry. The Bases describes the NMP1 operating philosophy of maintaining average levels for conductivity and chloride and sulfate concentrations over an operating cycle. Operation of the plant within these average values will ensure that the crack growth rate is bounded by the core shroud analysis.

The proposed change will not authorize any change in the types of effluents or in the authorized power level of the facility in conjunction with this Application for License Amendment. Supporting information and analyses which demonstrate no significant hazards considerations pursuant to 10CFR50.92, are included as Attachment B.

WHEREFORE, Applicant respectfully requests that Appendix A to Facility Operating License No. DPR-63 be amended in the form attached hereto as Attachment A.

NIAGARA MOHAWK POWER CORPORATION

By B. R. Sylvia  
B. R. Sylvia  
Chief Nuclear Officer

Subscribed and Sworn to before me  
on this 2nd day of July 1997.

Beverly W. Ripka  
NOTARY PUBLIC

BEVERLY W. RIPKA  
Notary Public State of New York  
Qual. in Oswego Co. No. 4644879  
My Commission Exp. Mar 30 1998  
2/28/98

ATTACHMENT A

NIAGARA MOHAWK POWER CORPORATION

LICENSE NO. DPR-63

DOCKET NO. 50-220

Proposed Changes to Technical Specifications

Replace the existing pages 96, 97, and 98 with the attached revised pages 96, 97, and 98. The pages have been retyped in their entirety with marginal markings to indicate changes.

4407110357-11 pp

**LIMITING CONDITION FOR OPERATION**

**3.2.3 COOLANT CHEMISTRY**

Applicability:

Applies to the reactor coolant system chemical requirements.

Objective:

To assure the chemical purity of the reactor coolant water.

Specification:

- a. The reactor coolant water shall not exceed the following limits with the coolant temperature  $\geq 200$  degrees F and reactor thermal power  $\leq 10\%$ , except as specified in 3.2.3c:

Conductivity	1 $\mu$ mho/cm
Chloride ion	100 ppb
Sulfate ion	100 ppb

- b. The reactor coolant water shall not exceed the following limits with reactor thermal power  $> 10\%$ , except as specified in 3.2.3c:

Conductivity	1 $\mu$ mho/cm
Chloride ion	20 ppb
Sulfate ion	20 ppb

**SURVEILLANCE REQUIREMENT**

**4.2.3 COOLANT CHEMISTRY**

Applicability:

Applies to the periodic testing requirements of the reactor coolant chemistry.

Objective:

To determine the chemical purity of the reactor coolant water.

Specification:

Samples shall be taken and analyzed for conductivity, chloride and sulfate ion content at least 3 times per week with a maximum time of 96 hours between samples. In addition, if the conductivity becomes abnormal (other than short term spikes) as indicated by the continuous conductivity monitor, samples shall be taken and analyzed within 8 hours and daily thereafter until conductivity returns to normal levels.

When the continuous conductivity monitor is inoperable, a reactor coolant sample shall be taken and analyzed for conductivity, chloride and sulfate ion content at least once per 8 hours.



LIMITING CONDITION FOR OPERATION

SURVEILLANCE REQUIREMENT

- c. The limits specified in 3.2.3a and 3.2.3b may be exceeded for a period of time not to exceed 24 hours. In no case shall the reactor coolant exceed the following limits at the specified conditions:
1. With reactor coolant temperature  $\geq 200$  degrees F, the conductivity has a maximum limit of  $5\mu\text{mho/cm}$ , or
  2. With reactor coolant temperature  $\geq 200$  degrees F and reactor thermal power  $\leq 10\%$ , the maximum limit of chloride or sulfate ion concentration is 200 ppb, or
  3. With reactor thermal power  $> 10\%$ , the maximum limit of chloride or sulfate ion concentration is 100 ppb.
- d. If Specifications 3.2.3a, b, and c are not met, normal orderly shutdown shall be initiated within one hour and the reactor shall be shutdown and reactor coolant temperature be reduced to  $< 200$  degrees F within ten hours.
- e. If the continuous conductivity monitor is inoperable for more than seven days, the reactor shall be shutdown and reactor coolant temperature be reduced to  $< 200$  degrees F within 24 hours.

## BASES FOR 3.2.3 AND 4.2.3 COOLANT CHEMISTRY

This specification is being submitted to address an NRC safety evaluation requirement. In its May 8, 1997 letter, the NRC required that NMPC submit an application for amendment to address the differences between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for the core shroud crack growth evaluations. The purpose of this specification is to limit intergranular stress corrosion cracking (IGSCC) crack growth rates through the control of reactor coolant chemistry. The LCO values ensure that transient conditions are acted on to restore reactor coolant chemistry values to normal in a reasonable time frame. Under transient conditions, potential crack growth rates could exceed analytical assumptions, however, the duration will be limited so that any effect on potential crack growth is minimized and the design basis assumptions are maintained. The plant is normally operated such that the average chemistry for the operating cycle is maintained at the conservative values of  $< 0.2 \mu\text{mho/cm}$  for conductivity and  $< 5 \text{ ppb}$  for chloride ions  $< 5 \text{ ppb}$  for sulfate ions. This will ensure that the crack growth rate is bounded by the core shroud analysis assumptions (the analysis shows the crack growth to be  $< 2.2\text{E-}5 \text{ in/hr}$  for these levels). Since these are average values, there are no specific LCO actions to be taken if these values are exceeded at a specific point in time.

Specification 3.2.3a, b, and c is consistent with the BWR water coolant chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29). The 24 hour action time period for exceeding the coolant chemistry limits described in 3.2.3a and b ensures that prompt action is taken to restore coolant chemistry to normal operating levels. The requirement to commence shutdown within 1 hour, and to be shutdown and reactor coolant temperature be reduced to  $< 200$  degrees F within 10 hours minimizes the potential for IGSCC crack growth.

A short term spike is defined as a rise in conductivity ( $> 0.2 \mu\text{mho/cm}$ ) such as that which could arise from injection of additional feedwater flow for a duration of approximately 30 minutes in time.

When conductivity is in its proper normal range, chloride, sulfate, and other impurities affecting conductivity must also be within their normal range. When and if conductivity becomes abnormal, then chloride and sulfate measurements are made to determine whether or not they are also out of their normal operating values. Significant changes provide the operator with a warning mechanism so he can investigate and remedy the condition causing the change and ensure that normal operating average conditions are maintained within the bounds of the core shroud crack growth analytical assumptions. Methods available to the operator for correcting the off-standard condition include, operation of the reactor clean-up system, reducing the input of impurities, and placing the reactor in shutdown and reducing reactor coolant temperature to  $< 200$  degrees F. The major benefit of reducing reactor coolant temperature to  $< 200$  degrees F is to reduce the temperature dependent corrosion rates and provide time for the clean-up system to re-establish the purity of the reactor coolant.

The conductivity of the reactor coolant is continuously monitored. The samples of the coolant which are analyzed for conductivity every 96 hours will serve as a comparison with the continuous conductivity monitor. The reactor coolant samples will also be used to determine the chloride and sulfate concentrations. Therefore, the sampling frequency is considered adequate to detect long-term changes in the chloride and sulfate ion content. However, if the conductivity becomes abnormal ( $> 0.2 \mu\text{mho/cm}$ ), chloride and sulfate measurements will be made to assure that the normal limits ( $< 5 \text{ ppb}$  of chloride or sulfate) are maintained.

## ATTACHMENT B

### NIAGARA MOHAWK POWER CORPORATION

LICENSE NO. DPR-63

DOCKET NO. 50-220

#### Supporting Information and No Significant Hazards Consideration Analysis

#### INTRODUCTION

The proposed Nine Mile Point Unit 1 (NMP1) Technical Specification (TS) change contained herein presents a revision to NMP1 TS Sections 3.2.3 and 4.2.3, and the Bases for 3.2.3 and 4.2.3, "Coolant Chemistry".

By letter dated April 8, 1997, Niagara Mohawk Power Corporation (NMPC) provided design documentation and evaluations to demonstrate the acceptability of the as-found vertical weld cracking in the NMP1 core shroud for at least 10,600 hours of hot (above 200 degrees F) operation. In its May 8, 1997 letter, "Modifications to Core Shroud Stabilizer Lower Wedge Retaining Clip and Evaluation of Shroud Vertical Weld Cracking, Nine Mile Point Nuclear Station, Unit 1," approving the restart of NMP1, the NRC required that NMPC submit an application for a license amendment addressing the difference between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates.

This proposed change incorporates into the TS the reactor coolant chemistry assumptions that were used for the core shroud weld crack evaluations.

#### EVALUATION

The proposed revisions to TS Sections 3.2.3a, b, c, d, and e incorporate the analytical assumptions that were used by NMPC to evaluate the vertical weld cracking found in the NMP1 core shroud during the 1997 refueling outage. The TS changes establish limits for conductivity and chloride and sulfate ion concentrations that are equal to or more restrictive than the existing TS values. As a result of the analysis, an average value of 0.2  $\mu\text{mho/cm}$  has been chosen for conductivity which is less than the BWR guideline action level 1 value for conductivity of 0.3  $\mu\text{mho/cm}$ .

The purpose of this TS change is to limit IGSCC crack growth rates through the control of reactor coolant chemistry. The proposed LCO values ensure that transient conditions are acted on to restore reactor coolant chemistry values to normal levels in a reasonable time frame. Under transient conditions, potential crack growth rates could exceed analytical assumptions, however, the duration will be limited so that any effect on potential crack growth is minimized and the design basis assumptions are maintained. The plant is operated such that the average coolant chemistry values for the operating cycle are maintained at the conservative values of  $< 0.2 \mu\text{mho/cm}$  for conductivity and  $< 5 \text{ ppb}$  for

chloride or sulfate ions. This will ensure that the crack growth rate is bounded by the  $5E-5$  in/hr core shroud analysis assumptions, since the analysis shows a crack growth rate of  $< 2.2E-5$  in/hr for these chemistry levels. Since the conductivity and chloride and sulfate ion values are average values, there are no specific LCO actions to be taken if these values are exceeded at a specific point in time. However, plant procedures will ensure that actions are taken to reduce the chemistry levels to the appropriate levels within a reasonable time frame.

The NMP1-specific analysis has established that the BWRVIP-14, Section 6.1.1 stress intensity independent crack growth rate of  $2.2E-5$  in/hr is conservative for NMP1, provided that the average reactor coolant conductivity is maintained  $< 0.2 \mu\text{mho/cm}$ . The reactor coolant conductivity applied in the analysis derived a "model" conductivity which considers that reactor coolant is at the 5 ppb limits associated with the chloride and sulfate ion concentrations. Typically conductivity is maintained below  $0.1 \mu\text{mho/cm}$  on a cycle average basis. This ensures that the NMP1-specific shroud analysis calculated crack growth is bounded by the  $2.2E-5$  in/hr growth rate as determined by the BWRVIP-14 disposition.

## CONCLUSIONS

The design documentation and evaluations provided by NMPC to demonstrate the acceptability of the as-found vertical weld cracking in the NMP1 core shroud for at least 10,600 hours of hot (above 200 degrees F) operation were accepted by the NRC. However, the NRC's safety evaluation was contingent on maintaining reactor coolant chemistry within the BWR water chemistry guidelines, 1996 revision, and on the submittal of an application for amendment that addressed the difference between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for core shroud crack growth rates. These proposed changes, which are equal to or more restrictive than the present TS values, will assure that NMP1 is operated within the requirements of the analysis used for the NRC's safety evaluation.

## ANALYSIS

### No Significant Hazards Consideration Analysis

10CFR50.91 requires that at the time a licensee requests an amendment, it must provide to the Commission its analysis using the standards in 10CFR50.92 concerning the issue of no significant hazards consideration. Therefore, in accordance with 10CFR50.91, the following analyses have been performed with respect to the requested change:

The operation of Nine Mile Point Unit 1, in accordance with the proposed amendment, will not involve a significant increase in the probability or consequences of an accident previously evaluated.

The changes to the conductivity and chloride ion action levels and the addition of sulfate ion levels as an action level in reactor water chemistry are being made to make the TS and its Bases consistent with the values used in the core shroud vertical weld cracking evaluations. These new values reflect the BWR water chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29) and are equal to or more restrictive than the present TS values. No physical modification of the plant is involved and no changes to the methods in



which plant systems are operated are required. None of the precursors of previously evaluated accidents are affected and therefore, the probability of an accident previously evaluated is not increased. These changes to the coolant chemistry TS are more restrictive limits and no new failure modes are introduced. Therefore, these changes will not involve a significant increase in the consequences of an accident previously evaluated.

The operation of Nine Mile Point Unit 1, in accordance with the proposed amendment, will not create the possibility of a new or different kind of accident from any accident previously evaluated.

The changes to the conductivity and chloride ion action levels and the addition of sulfate ion levels as an action level in reactor water chemistry are being made to make the TS and its Bases consistent with the values used in the core shroud vertical weld cracking evaluations. These new values reflect the BWR water chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29) and are equal to or more restrictive than the present TS values. No physical modification of the plant is involved and no changes to the methods in which plant systems are operated are required. The change does not introduce any new failure modes or conditions that may create a new or different accident. Therefore, this change does not create the possibility of a new or different kind of accident previously evaluated.

The operation of Nine Mile Point Unit 1, in accordance with the proposed amendment, will not involve a significant reduction in a margin of safety.

The changes to the conductivity and chloride ion action levels and the addition of sulfate ion levels as an action level in reactor water chemistry are being made to make the TS and its Bases consistent with the values used in the core shroud vertical weld cracking evaluations. These new values reflect the BWR water chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29) and are equal to or more restrictive than the present TS values. No physical modification of the plant is involved and no changes to the methods in which plant systems are operated are required. This change does not adversely affect any physical barrier to the release of radiation to plant personnel or the public. Therefore, the change does not involve a significant reduction in a margin of safety.



ATTACHMENT C

NIAGARA MOHAWK POWER CORPORATION

LICENSE NO. DPR-63

DOCKET NO. 50-220

Marked Copy of Proposed Changes to Current Technical Specification

The current version of pages 96, 97, and 98 of the NMP1 Technical Specifications have been hand marked-up to reflect the proposed changes.

**LIMITING CONDITION FOR OPERATION**

**3.2.3 COOLANT CHEMISTRY**

Applicability:

Applies to the reactor coolant system chemical requirements.

Objective:

To assure the chemical purity of the reactor coolant water.

Specification:

- a. The reactor coolant water shall not exceed the following limits with ~~steaming rates less than 100,000 pounds per hour~~ except as specified in 3.2.3c:

Conductivity	1.2 $\mu$ mho/cm
Chloride ion	0.1 ppm 100 ppb
SULFATE ion	100 ppb

- b. The reactor coolant water shall not exceed the following limits with ~~steaming rates greater than or equal to 100,000 pounds per hour~~ except as specified in 3.2.3c:

Conductivity	1.5 $\mu$ mho/cm
Chloride ion	0.2 ppm 20 ppb
SULFATE ion	20 ppb

*the coolant temperature  $\geq 200$  degrees and reactor thermal power  $\leq 10\%$*

*reactor thermal power  $> 10\%$*

**SURVEILLANCE REQUIREMENT**

**4.2.3 COOLANT CHEMISTRY**

Applicability:

Applies to the periodic testing requirements of the reactor coolant chemistry.

Objective:

To determine the chemical purity of the reactor coolant water.

Specification:

*and sulfate*

Samples shall be taken and analyzed for conductivity and chloride ion content at least 3 times per week with a maximum time of 96 hours between samples. In addition, if the conductivity becomes abnormal (other than short term spikes) as indicated by the continuous conductivity monitor, samples shall be taken and analyzed within 8 hours and daily thereafter until conductivity returns to normal levels.

When the continuous conductivity monitor is inoperable, a reactor coolant sample shall be taken and analyzed for conductivity and chloride ion content at least once per 8 hours.

*and sulfate*

**LIMITING CONDITION FOR OPERATION**

**SURVEILLANCE REQUIREMENT**

- c. The limits specified in 3.2.3a and 3.2.3b may be exceeded for a period of time not to exceed 24 hours. In no case shall (1) the conductivity exceed a maximum limit of 10  $\mu\text{mho/cm}$ , or (2) the chloride ion concentration exceed a maximum limit of 0.5 ppm.

*the reactor coolant exceed the following limits at the specified conditions;*

- d. If Specifications 3.2.3a, b, and c are not met, normal orderly shutdown shall be initiated within one hour and the reactor shall be in the cold shutdown condition within ten hours.

*and reactor coolant temperature be reduced to < 200 degrees F*

- e. If the continuous conductivity monitor is inoperable for more than 7 days the reactor shall be placed in the cold shutdown condition within 24 hours.

*and reactor coolant temperature be reduced to < 200 degrees F*

1. *With reactor coolant temperature  $\geq 200$  degrees F, the conductivity has a maximum limit of 5  $\mu\text{mho/cm}$ , or*
2. *With reactor coolant temperature  $\geq 200$  degrees F and reactor thermal power  $\leq 10\%$ , the maximum limit of chloride or sulfate ion concentration is 200 ppb, or*
3. *With reactor thermal power  $> 10\%$ , the maximum limit of chloride or sulfate ion concentration is 100 ppb.*

REPLACE WITH ATTACHED

### BASES FOR 3.2.3 AND 4.2.3 COOLANT CHEMISTRY

Materials in the primary system are primarily 304 stainless steel and the Zircaloy fuel cladding. The reactor water chemistry limits are established to prevent damage to these materials. Limits are placed on chloride concentration and conductivity. The most important limit is that placed on chloride concentration to prevent stress corrosion cracking of the stainless steel. When the steaming rate is less than 100,000 pounds per hour, a more restrictive limit of 0.1 ppm has been established. At steaming rates of at least 100,000 pounds per hour, boiling occurs causing deaeration of the reactor water, thus maintaining oxygen concentration at low levels.

A short term spike is defined as a rise in conductivity <sup>( $> 2 \mu\text{mho/cm}$ )</sup> such as that which could arise from injection of additional feedwater flow for a duration of approximately 30 minutes in time.

When conductivity is in its proper normal range, ~~pH and~~ <sup>SULFATE,</sup> chloride <sup>and sulfate</sup> and other impurities affecting conductivity must also be within their normal range. When and if conductivity becomes abnormal, then chloride measurements are made to determine whether or not they are also out of their normal operating values. This would not necessarily be the case. Conductivity could be high due to the presence of a neutral salt, e.g.,  $\text{Na}_2\text{SO}_4$ , which would not have an effect on pH or chloride. In such a case, high conductivity alone is not a cause for shutdown. In some types of water-cooled reactors, conductivities are in fact high due to purposeful addition of additives. In the case of BWR's, however, where no additives are used and where neutral pH is maintained, conductivity provides a very good measure of the quality of the reactor water. Significant changes therein provide the operator with a warning mechanism so he can investigate and remedy the condition causing the change before limiting conditions, with respect to variables affecting boundaries of the reactor coolant, are exceeded. Methods available to the operator for correcting the off-standard condition include, operation of the reactor clean-up system, reducing the input of impurities, and placing the reactor in the cold shutdown condition. <sup>and reducing reactor coolant temperature to  $< 200$  degrees F</sup> The major benefit of cold shutdown is to reduce the temperature dependant corrosion rates and provide time for the clean-up system to re-establish the purity of the reactor coolant. <sup>and reducing water concentration to  $< 2.0$  if great</sup> During start-up periods, which are in the category of less than 100,000 pounds per hour, conductivity may exceed  $2 \mu\text{mho/cm}$  because of the initial evolution of gases and the initial addition of dissolved metals. During this period of time, when the conductivity exceeds  $2 \mu\text{mho}$  (other than short term spikes), samples will be taken to assure that the chloride concentration is less than 0.1 ppm.

The conductivity <sup>of</sup> the reactor coolant is continuously monitored. The samples of the coolant which are <sup>analyzed for conductivity</sup> taken every 96 hours will serve as a reference for calibration of these monitors and is considered adequate to assure accurate readings of the monitors. If conductivity is within its normal range, chlorides and other impurities will also be within their normal ranges. The reactor coolant samples will also be used to determine the chloride <sup>and sulfate</sup> content. However, if the conductivity <sup>and sulfate concentration</sup> changes significantly, chloride measurements will be made to assure that the chloride limits of <sup>and sulfate</sup> Specification 3.2.3 are not exceeded. <sup>becomes abnormal ( $> 2 \mu\text{mho/cm}$ )</sup> <sup>ANAL</sup> <sup>( $< 5 \text{ppb of}$ )</sup> <sup>CHLORIDE and SULFATE) are maintained.</sup>

# INSERT IN BASES

This specification is being submitted to address an NRC safety evaluation requirement. In its May 8, 1997 letter, the NRC required that NMPC submit an application for amendment to address the differences between the current TS conductivity limits for reactor coolant chemistry and the analysis assumptions for the core shroud crack growth evaluations. The purpose of this specification is to limit intergranular stress corrosion cracking (IGSCC) crack growth rates through the control of reactor coolant chemistry. The LCO values ensure that transient conditions are acted on to restore reactor coolant chemistry values to normal in a reasonable time frame. Under transient conditions, potential crack growth rates could exceed analytical assumptions, however, the duration will be limited so that any effect on potential crack growth is minimized and the design basis assumptions are maintained. The plant is normally operated such that the average chemistry for the operating cycle is maintained at the conservative values of  $< 0.2 \mu\text{mho/cm}$  for conductivity and  $< 5 \text{ ppb}$  for chloride ions  $< 5 \text{ ppb}$  for sulfate ions. This will ensure that the crack growth rate is bounded by the core shroud analysis assumptions (the analysis shows the crack growth to be  $< 2.2\text{E-}5 \text{ in/hr}$  for these levels). Since these are average values, there are no specific LCO actions to be taken if these values are exceeded at a specific point in time.

Specification 3.2.3a, b, and c is consistent with the BWR water coolant chemistry guidelines, 1996 revision (EPRI TR-103515-R1, BWRVIP-29). The 24 hour action time period for exceeding the coolant chemistry limits described in 3.2.3a and b ensures that prompt action is taken to restore coolant chemistry to normal operating levels. The requirement to commence shutdown within 1 hour, and to be shutdown and reactor coolant temperature be reduced to  $< 200 \text{ degrees F}$  within 10 hours minimizes the potential for IGSCC crack growth.