

July 10, 1997

Mr. Roger O. Anderson, Director
Licensing and Management Issues
Northern States Power Company
414 Nicollet Mall
Minneapolis, Minnesota 55401

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION ON THE PRAIRIE
ISLAND NUCLEAR GENERATING PLANT, UNITS 1 AND 2,
AMENDMENT OF SPENT FUEL POOL SPECIAL VENTILATION
TECHNICAL SPECIFICATION (TAC NOS. M98752 AND M98753)

Dear Mr. Anderson:

By letters dated May 7, 1997, and supplemented May 30, 1997, Northern States Power Company submitted a request to amend the Prairie Island Technical Specifications pertaining to the spent fuel pool special ventilation system. In order to review the proposed changes the staff requires some additional information. Our request for additional information (RAI) is enclosed.

In order to continue our review of your submittal on an expedited basis, please provide your response to the staff's RAI as soon as practical. If you have any questions regarding the content of the RAI, please contact me at (301) 415-1355.

Sincerely,

ORIGINAL SIGNED BY

Beth A. Wetzel, Project Manager
Project Directorate III-I
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Docket Nos. 50-282, 50-306

Enclosure: As stated

cc w/encl: See next page

DF01/1

DISTRIBUTION: Docket File PUBLIC
PD# 3-1 Reading JRoe OGC
ACRS JMcCormick-Barger, RIII

DOCUMENT NAME: G:\WPDOCS\PRAIRIE\PI98752.RAI

To receive a copy of this document, indicate in the box C = Copy w/o attachment/enclosure E = Copy with attachment/enclosure N = No copy

OFFICE	PM:PD31	E	LA:PD31	E	PERB	E	SPLB	E	D:PD31	<i>JN</i>
NAME	BWetzel:db	<i>ban</i>	CJamerson	<i>C</i>	CMiller	<i>m</i>	LMarsh	<i>m</i>	JHannon	
DATE	7/9/97		7/7/97		7/9/97		7/11/97		7/11/97	

OFFICIAL RECORD COPY



9707150236 970710
PDR ADOCK 05000282
P PDR

TER COPY

Mr. Roger O. Anderson, Director
Northern States Power Company

Prairie Island Nuclear Generating
Plant

cc:

J. E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
2300 N Street, N. W.
Washington DC 20037

Plant Manager
Prairie Island Nuclear Generating
Plant
Northern States Power Company
1717 Wakonade Drive East
Welch, Minnesota 55089

Adonis A. Neblett
Assistant Attorney General
Office of the Attorney General
455 Minnesota Street
Suite 900
St. Paul, Minnesota 55101-2127

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
1719 Wakonade Drive East
Welch, Minnesota 55089-9642

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, Illinois 60532-4351

Mr. Jeff Cole, Auditor/Treasurer
Goodhue County Courthouse
Box 408
Red Wing, Minnesota 55066-0408

Kris Sanda, Commissioner
Department of Public Service
121 Seventh Place East
Suite 200
St. Paul, Minnesota 55101-2145

Site Licensing
Prairie Island Nuclear Generating
Plant
Northern States Power Company
1717 Wakonade Drive East
Welch, Minnesota 55089

Tribal Council
Prairie Island Indian Community
ATTN: Environmental Department
5636 Sturgeon Lake Road
Welch, Minnesota 55089

REQUEST FOR ADDITIONAL INFORMATION FOR REVIEW OF
THE AMENDMENT OF THE SPENT FUEL POOL SPECIAL VENTILATION ZONE
TECHNICAL SPECIFICATIONS

1. Step 8.27 of D95.2, "TN-40 Cask Unloading Procedure" directs the cask to be filled with water. The caution prior to step 8.27 reads, "The water/steam mixture from the vent port hose may contain some radioactive gas. The area directly above where the hose is discharging shall be closely monitored to determine if there is a radiological hazard." Is the spent fuel pool special ventilation system operable during the performance of this step of the unloading procedure? If the spent fuel pool special ventilation system is inoperable during this step and other portions of the unloading procedure because the overhead crane is supporting the cask through the open spent fuel pool enclosure slot doors, discuss why an inoperable ventilation system does not pose a radiological hazard and give any precautions and protections that ensure that 10 CFR Part 20 and Part 100 requirements are not exceeded.
2. Section 5.5 of the Prairie Island ISFSI [independent spent fuel storage installation] safety analysis report (SAR) states in part, "After moving the cask into the fuel pool area, the cavity will be depressurized and the cask lowered into the spent fuel pool." However, Step 8.4 of procedure D95.2 directs the cask to be depressurized while it is still located in the rail bay area. Explain the discrepancy between the two documents. Also, what is the basis for the SAR requiring the cask to be moved to the spent fuel pool area prior to depressurization? Does the SAR assume that the spent fuel pool special ventilation system will be operable during the cask depressurization evolution?
3. When the spent fuel cask is filled with water prior to unloading the fuel (per Step 8.27 of D95.2, "TN-40 Cask Unloading Procedure"), discuss the likelihood that this will result in cracking of the spent fuel rods due to the interaction of the cool spent fuel pool water with the hot fuel elements. If any fuel cracking is predicted, list the expected radionuclides and quantities that will be released into the cask and into the fuel building when the cask is vented. If the filtered ventilation system is not operating during cask venting, describe how you plan to detect and prevent these radioactive gases from being released into the environment.