



Northeast
Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

July 11, 1997

Docket No. 50-336

B16631

Re: 10 CFR 50.36

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station, Unit No. 2
Steam Generator Tube Plugging

This special report is being submitted pursuant to the requirements of Plant Technical Specifications 4.4.5.1.5.a and 6.9.2. Plant Technical Specification 4.4.5.1.5.a requires that a special report be submitted to the NRC within 15 days following completion of each inservice inspection of the steam generator tubes to document the number of tubes plugged in each steam generator.

An eddy current examination of the Millstone Unit No. 2 steam generator tubes was completed on June 26, 1997. Inspections were performed in both steam generators. There were no indications of tube degradation identified and no steam generator tube plugging was performed.

Should you have any questions on the information provided, please contact Mr. R. G. Joshi at (860) 440-2080.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

M L Bowling

Martin L. Bowling, Jr.
Millstone Unit No. 2 Recovery Officer

9707150264 970711
PDR ADOCK 05000336
P PDR

cc: see page 2



A 047/10

cc: H. J. Miller, Region I Administrator
D. G. McDonald, Jr., NRC Project Manager, Millstone Unit No. 2
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2
W. D. Travers, PhD, Director, Special Projects Office
P. F. McKee, Deputy Director of Licensing, Special Projects Office
W. D. Lanning, Deputy Director of Inspections, Special Projects Office