



Northeast Nuclear Energy

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

July 8, 1997

Docket No. 50-423
B16542

Re: 10CFR 50.73(a)(2)(ii)(B)

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Millstone Nuclear Power Station Unit 3
Licensee Event Report 97-036-00
Submitted Pursuant to 10CFR 50.73(a)(2)(ii)(B)

This letter forwards Licensee Event Report (LER) 97-036-00, documenting a condition that was determined to be reportable at Millstone Unit No. 3 on June 9, 1997. This LER is submitted pursuant to 10CFR 50.73(a)(2)(ii)(B). NNECO's commitments in response to this event are contained within Attachment 1 to this letter.

Should you have any questions regarding this submittal, please contact Mr. David A. Smith at (860) 437-5840.


Very truly yours,

NORTHEAST NUCLEAR ENERGY
COMPANY

JE 22/1

G. D. Hicks
Unit Director, Millstone Unit No. 3

150029
9707150303 970708
PDR ADDCK 05000423
S PDR



Attachment: 1) NNECO's commitments in response to LER 97-036-00
2) LER 97-036-00

cc: H. J. Miller, Region I Administrator
A. C. Cerne, Senior Resident Inspector, Millstone Unit No. 3
J. W. Andersen, NRC Project Manager, Millstone Unit No. 3
W. D. Travers, Dr., Director, Special Projects

Docket No. 50-423
B16542

Attachment 1

Millstone Nuclear Power Station, Unit No. 3
NNECO's Commitments
In Response To
(LER 97-036-00)

July 8, 1997

Attachment 1
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document. Please notify the Manager - Nuclear Licensing at the Millstone Nuclear Power Station Unit No. 3 of any questions regarding this document or any associated regulatory commitments.

Number	Commitment	Due
B16542-01	The Final Safety Analysis Report will be updated to reflect the correct design information.	September 30, 1997
B16542-02	Pipe stress calculations will be reconciled to the proper allowable stresses for the applicable containment penetrations and design documents will be revised to clearly address pipe break exclusion areas.	Prior to entry into Mode 4
B16542-03	The Containment Isolation System will be restored to compliance with the Final Safety Analysis Report.	Prior to entry into Mode 4

Docket No. 50-423
B16542

Attachment 2

Millstone Nuclear Power Station, Unit No. 3
NNECO's Submittal of
(LER 97-036-00)

July 8, 1997