



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 197
License No. DPR-59


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Power Authority of the State of New York (the licensee) dated June 30, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 197, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director
Project Directorate I-1
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 9, 1993

ATTACHMENT TO LICENSE AMENDMENT NO. 197

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Pages

165
188
188a

Insert Pages

165
188
188a

JAFNPP

3.7 LIMITING CONDITIONS FOR OPERATION

3.7 CONTAINMENT SYSTEMS

Applicability:

Applies to the operating status of the primary and secondary containment systems.

Objective:

To assure the integrity of the primary and secondary containment systems.

Specification:

A. Primary Containment

1. The level from the bottom of the torus and temperature of the water in the torus shall be maintained within the following limits whenever the reactor is critical or whenever the reactor coolant temperature is greater than 212°F and irradiated fuel is in the reactor vessel:

- a. Maximum level of 14.00 feet.
- b. Minimum level of 13.88 feet.

The torus water level may be outside the above limits for a maximum of four (4) hours as a result of required operability testing of HPCI, RCIC, RHR, CS, and the Drywell - Torus Vacuum Relief System.

- c. Maximum water temperature
 - (1) During normal power operation maximum water temperature shall be 95°F.

4.7 SURVEILLANCE REQUIREMENTS

4.7 CONTAINMENT SYSTEMS

Applicability:

Applies to the primary and secondary containment integrity.

Objective:

To verify the integrity of the primary and secondary containment systems.

Specification:

A. Primary Containment

1. The torus water level and temperature shall be monitored as specified in Table 4.2-8.

The accessible interior surfaces of the drywell and above the water line of the torus shall be inspected each operating cycle for evidence of deterioration.

Whenever there is indication of relief valve operation or testing which adds heat to the suppression pool, the pool temperature shall be continuously recorded until the heat addition is terminated. The operator will verify that average temperature is within applicable limits every 5 minutes. In lieu of continuous recording, the operator shall log the temperature every 5 minutes.

Whenever there is indication of relief valve operation with the temperature of the suppression pool reaching 160°F or more and the primary coolant system pressure greater than 200 psig, an external visual examination of the torus shall be conducted before resuming power operation.

3.7 BASES (cont'd)

Using the minimum or maximum torus water level (which are based on downcomer submergence levels where 13.88 feet above the bottom of the torus is 0.005 feet higher than the minimum submergence of 51.5 inches and 14.00 feet above the bottom of the torus is equivalent to the maximum submergence of 53 inches assumed in containment analyses) containment pressure during the design basis accident is approximately 45 psig which is below the design of 56 psig. The minimum downcomer submergence of 51.5 inches results in a minimum torus water volume of approximately 105,600 feet³. The majority of the Bodega tests (9) were run with a submerged length of 4 feet and with complete condensation. Thus, with respect to downcomer submergence, this specification is adequate. Additional JAFNPP specific analyses done in connection with the Mark I Containment-Suppression Chamber Integrity Program indicate the adequacy of the specified range of submergence to ensure that dynamic forces associated with pool swell do not result in overstress of the torus or associated structures. Level instrumentation is provided for operator use to maintain downcomer submergence within the specified range.

The maximum temperature at the end of blowdown tested during the Humboldt Bay (10) and Bodega Bay tests was 170°F, and this is conservatively taken to be the limit for complete condensation of the limit for complete condensation of the reactor coolant, although condensation would occur for temperatures above 170°F.

Using a 40°F rise (Section 3.2 FSAR) in the torus water temperature and a maximum initial temperature of 95°F, a temperature of 145°F is achieved, which is well below the 170°F temperature which is used for complete condensation.

For an initial maximum torus water temperature of 95°F and assuming the normal complement of containment cooling pumps (two LPCI pumps and two RHR service water pumps) containment pressure is not required to maintain adequate net positive suction head (HPSH) for the core spray LPCI and HPCI pumps.

Limiting suppression pool temperature to 130°F during RCIC, HPCI, or relief valve operation, when decay heat and stored energy are removed from the primary system by discharging reactor steam directly to the torus assures adequate margin for a potential blowdown any time during RCIC, HPCI, or relief valve operation.

Experimental data indicates that excessive steam condensing loads can be avoided if the peak temperature of the suppression pool is maintained below 160°F during any period of relief valve operation with sonic conditions at the discharge exit. Specifications have been placed on the envelope of reactor operating conditions so that the reactor can be depressurized in a timely manner to avoid the regime of potentially high torus loadings.

3.7 BASES (Cont'd)

In addition to the limits on temperature of the suppression pool water, operating procedures define the action to be taken in the event a relief valve inadvertently opens or sticks open. These procedures include: (1) use of all available means to close the valve, (2) initiate suppression pool cooling, (3) initiate reactor shutdown, and (4) if other relief valves are used to depressurize the reactor, their discharge shall be separated from that of the stuck-open relief valve to assure mixing and uniformity of energy insertion to the pool.

Because of the large volume and thermal capacity of the suppression pool, the volume and temperature normally changes very slowly and monitoring these parameters daily is sufficient to establish any temperature trends. By requiring the suppression pool temperature to be verified as within applicable limits every 5 minutes as well as continuously recorded (the operator can log temperature during verification if continuous recording is not available) during periods of significant heat addition, the temperature trends will be closely followed so that appropriate action can be taken. There are alarms at applicable limits to provide further assurance of appropriate action. The requirement for an external visual examination following any event where potentially high loadings could occur provides assurance that no significant damage was encountered. Particular attention should be focused on structural discontinuities in the vicinity of the relief valve discharge since these are expected to be the points of highest stress.

If a loss-of-coolant accident were to occur when the reactor water temperature is below 330°F, the containment pressure will not exceed the 56 psig design pressure, even if no condensation were to occur. The maximum allowable pool temperature, whenever the reactor is above 212°F, shall be governed by this