

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 665-5000

December 29, 1987
MP-11294

Re: Technical Specification 3.7.9.2.a.

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Reference: Facility Operating License No. DPR-65
Docket No. 50-336

Gentlemen:

This letter forwards special report submitted pursuant to action a. of Millstone Unit 2 Technical Specification 3.7.9.2.

The cable vault (Auxiliary Building) deluge fire sprinkler system, Technical Specification item 3.7.9.2.c.2. was removed from service on November 25, 1987 for modifications. The manually activated deluge system is being replaced by an automatic wet pipe sprinkler system. The modifications are being performed to upgrade the system to meet 10CFR50 Appendix R requirements.

While the system is out of service a fire watch is posted and back up fire fighting equipment is available.

The modifications will be completed and the system will be restored to operable status prior to start-up from the 1988 refueling outage.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

Stephen E. Scace
Stephen E. Scace

Station Superintendent
Millstone Nuclear Power Station

SES/SLS:cjh

cc: W. T. Russell, Region I
W. J. Raymond, Senior Resident Inspector

8801110303 871229
PDR ADOCK 05000336
S
PCD PDR

IE22
1/0