IRC Form 366 1831		LIC	ENSEE EVE	NT RE	PORT	(LER)	U.S. NU A E	CLEAR REGULA PROVED OMB I KPIRES 8/31/85	TORY COMMISSION NO. 3150-0104
ACILITY NAME (1)						0	OCKET NUMBER	(2)	PAGE (3)
PLANT VOGTL	E - UNIT 1				200	0	0 15 10 10	0 4 12 1	4 1 OF 01
ITLE (4)									
EVENT DATE (5)	HE MAXIMUM	POWER	LEVEL SPE	CIFIEL) IN C	OPERATING OTHER	LICE SE	VED (8)	
WONTH DAY YEAR YEAR	SEQUENTIAL	REVISION	MONTH DAY	EAH		FACILITY NAM	ES	DOCKET NUMB	ER(S)
								0 15 10 1	0 0 1 1 1
1 1 2 10 8 7 8 7	069	-00	0 1 0 5	88				0 15 10 1	0 0 1 1 1
OPERATING MODE (9)	A02(b)	D PURSUANT 1	20 406 (c)	ENTS OF 10	CFR S 10	50 73(a)(2)(iv)	t the following) (1)) 73.71(b)	
POWER 20	0.406(a)(1)(i)		50.36(c)(1)			50.73(a)(2)(v)		73.71(c)	
(10) 110 D 21	0.405(a)(1)(ii)		50.36(c)(2)			50.73(a)(2)(vii)		X OTHER I	Specify in Abstract
21	0.406(a)(1)(iii)	-	50.73(a)(2)(i)		-	50.73(s)(2)(viii)(A	d A	366A)	
2	0.406(a)(1)(v)		50.73(a)(2)(iii)			50.73(s)(2)(x)			
energe and a second		L	ICENSEE CONTACT	FOR THIS	LER (12)				
AME							AREA CODE	TELEPHONE NU	MBER
	1000 1 1000	ada a Ma					41014	FIDIC I	1710 8 1
W. F. BUFNS, NUC	COMPLETE	ONE LINE FOR	EACH COMPONEN	T FAILURE	DESCRIBE	D IN THIS REPORT	T (13)	51/10 -	17.10 11 1
CAUSE SYSTEM COMPONENT	MANUFAC- TURER	REPORTABLE TO NPROS		CAUSE	SYSTEM	COMPONENT	MANUFAC TURER	REPORTABLE TO NPRDS	
1 11	1.1.1				1				
S. Lilian	1								
	BUPPLEME	INTAL REPORT	EXPECTED (14)		<u> </u>			MON	TH DAY YEAN
_							SUBMISSI DATE (1	ON 51	
BSTRACT /Limit to 1400 spaces i.e.	approximately fifteen	single souce type	ewritten lines/ (16)				L	101	2 1 2 81
Proteus com power, a po Vogtle Unit review of p investigati exceeded on instantaneo a maximum v Corrective calorimetri plant condi	puter calo ssible vio l Facilit lant opera on determi numerous us data po alue of 34 actions we cs for NI tions and	orimetri lation cy Opera ned tha occasio oint whe 84 MWt ere take calibra at incr	c methods of licens ting Lice ta was un t the max ns. Subs re the ra (approxim n to revi tion are eased fre	for c e conc nse No dertak imum 1 equent ted th ately se pro perfor quence	determ dition b. NPF (en. licens trevi nermal 102.1 bocedur rmed u les.	ining rea 2.C.(1) -68 was d By Novemb ed power ew detect power ma % rated t res such t inder more	actor the of the P liscovere per 20, 1 level ha ed one by have r chermal p chat e stabili	rmal lant d. A 987, d been eached ower). zed	
submitted o	n or about	: Februa	ry 12, 19	88.	icai r	eport is	scheduie	u to be	

LICENSEE EVENT REPORT (LER) TEXT CON							ON	ITI	NU	AT	101	N		U	S. NU A E	CLE PPRI (PIR)	OVED O	MB NO.	315	0-0	104	SION
	000	CKE	TNU	MBE	R (2)	-				-		LE	RNU	MBER	6)				PAG	E (3	3)	
										YĘ	AR		SEQU	MBER	-	Rj N	UMBER		T	T		
	0	5	0	10	10)	41	21	4	81	7	_	0	61) -	- 1	010	012	0	0.5	0	16
	VENT REPOI	VENT REPORT (VENT REPORT (LER)	VENT REPORT (LER) TE	VENT REPORT (LER) TEXT	VENT REPORT (LER) TEXT C	VENT REPORT (LER) TEXT CON	VENT REPORT (LER) TEXT CONTIN	VENT REPORT (LER) TEXT CONTINU	VENT REPORT (LER) TEXT CONTINUAT	VENT REPORT (LER) TEXT CONTINUATION APPR EXPIR OOCKET NUMBER (2) LER NUMBER (6) YEAR SEQUENTIAL N UMBER 0 5 0 0 4 2 4 8 7 - 0 6 9 -	VENT REPORT (LER) TEXT CONTINUATION APPROVED 0 EXPIRES: 8/31 DOCKET NUMBER (2) LER NUMBER (6) VERT REPORT (LER) TEXT CONTINUATION VERTICAL 0 5 0 0 4 2 4 8 7 0 6 9 0 0	VENT REPORT (LER) TEXT CONTINUATION APPROVED OMB NO. EXPIRES: 8/31/88 DOCKET NUMBER (2) LER NUMBER (6) VERT REPORT (LER) TEXT CONTINUATION VERT NUMBER (6) 0 5 0 0 4 2 4 8 7 0 6 9 0 0 2	VENT REPORT (LER) TEXT CONTINUATION APPROVED OMB NO. 315 DOCKET NUMBER (2) LER NUMBER (6) PAC VEAR SEQUENTIAL REVISION NUMBER PAC 0 5 0 0 4 2 4 8 7 0 6 9 0 0 2 0	VENT REPORT (LER) TEXT CONTINUATION APPROVED OMB NO. 3150-0 EXPIRES: 8/31/88 EXPIRES: 8/31/88 DOCKET NUMBER (2) LER NUMBER (6) PAGE (1) 0 5 0 0 4 2 4 8 7 0 6 9 0 0 2 0	VENT REPORT (LER) TEXT CONTINUATION APPROVED OMB NO. 3150-0104 EXPIRES: 8/31/88 DOCKET NUMBER (2) LER NUMBER (6) PAGE (3) YEAR SEQUENTIAL NUMBER NUMBER (2) 0 5 0 0 4 2 4 8 7 0 6 9 0 0 2 0 0					

A. REQUIREMENT FOR REPORT

The Plant Vogtle Unit 1, Facility Operating License No. NPF-68, section 2.H, requires the reporting of any violations of section 2.C. It appears that license condition 2.C.(1), Maximum Power Level, has been exceeded on a number of occasions. On one occasion the reactor power level may have reached 3484 MWt or approximately 102.1% rated thermal power.

B. UNIT STATUS AT TIME OF EVENT

The unit was in Mode 1 (power operation) at approximately 100% of rated thermal power (RTP), as indicated by nuclear instrumentation (NIs).

C. DESCRIPTION OF EVENT

In March, 1987, NRC correspondence was reviewed and discussions conducted with the NRC by Georgia Power Company (GPC) concerning achievement and control of maximum thermal power output. These documents and conversations lead to the establishment of the following criteria: "The average core thermal power level over any eight (8) hours shift shall not exceed 3411 MWt. It is permissible to briefly exceed 3411 MWt by as much as 2 percent for as long as fifteen (15) minutes (or 1 percent for 30 minutes, 1/2 percent for 1 hour); however, in no case should 102% (full steady state) power be exceeded." GPC believes that complying with this position ensured compliance with license condition 2.C.(1), " Maximum Power Level". A review has shown that Plant Vogtle Unit 1 appears to have exceeded the above criteria on the licensed RTP limit on numerous occasions with the maximum power level reaching approximately 102.1% on one occasion.

During August, 1987, Reactor Engineering, in response to a concern that Unit 1 was not generating the expected electrical output for given primary plant conditions, began a review of operations procedure 14030-1, "Power Range Calorimetric Channel Calibration". Computer logs of the Proteus computer point Ull18, which provides reactor information for a given instant of time, were also examined closely as a means of determining the reactor thermal output. Procedure 14030-1 and computer point Ull18 provide the hand calculated and computer calculated calorimetric, respectively. This review indicated a number of occurrences where the NI's indicated over 100% RTP which were not confirmed by the calorimetrics (hand and Ull18).

NRC Form 366A (9-83) LICENSEE EV	ENT REPOR	T (LER) TEXT	CON	rinu	οιτα	N	i.	S. NUC	ROVED (PROVED (PRES: 8/3	GULATOF 0MB NO. 1 1/88	Y COMM	ISSION	
FACILITY NAME (1)		DOCKET NUMBER (?)		1	LEP	NUMBER	(6)		PAGE (3)			
					YEAR		NUMBER	4L	REVISION				
PLANT VOGTLE - UNIT 1		0 15 10 10 1	0141	214	817	_	0 1 619 - 0 10			013	OFO	16	
TEXT (If more spece is required, use additional NRC Form 388A's) (171												
NOTE: 14030-1 utilizing the calo from computer logs	are calcul rimetric p	ations perf procedure 14	formed 1030-1	by wit	reac th da	tor ta	engi obtai	neer ned	ing				
A review of the 14	030-1 calc	ulations (H	and)	indi	icate	d t	hat R	TP h	ad				

MWt % Power 6/27/87 2057 3474 1.018 2230 6/28/87 3426 1.004 7/17/87 2341 3134 1.007 7/18/87 0947 3433 1.007 7/26/87 1038 3435 1.007

instants of time as indicated in the following table:

TIME

DATE

A review of the computer calculated calorimetric (U1118) indicated that the RTP may have been exceeded on five (5) occasions as indicated in the following table:

DATES	TIME	INTERVALS (hours)	DATA SOURCE	Maximum MWt	% Power
7/16/87	17	(approximate)	U1118	3451	1.012
7/17/87	11	(approximate)	U1118	3443	1,009
7/22/87	11	(approximate)	U1118	3470	1.017
7/24/87-7/25/8	7 37	(approvimate)	U1118	3443	1.009
7/26/87-7/27/8	7 33	(appr/ximate)	U1118	3445	1.01

These conditions were identified as possible deficiencies on September 10, 1987. Investigation was begun to determine if there was a violation of a license condition. This investigation was performed by Reactor Engineering and reviewed by the Plant Review Board (PRB) and, on November 20, 1987, determined to be reportable as a violation of the license condition.

After these possible deficiencies were first identified on September 10, 1987, there was a temporary change to Operations procedure, 14030-1, to change the acceptance criteria for comparison to the calorimetric. The criteria was changed from +2%, -2% to +2%, -0%. This was believed to be adequate action until the investigation was completed.

NRC Form 368A (9-83)	LICENSEE EVENT P	REPO	RT (LER) TEXT CONTINU	ΟΙΤΑ	N	∪.\$.	APP	ROVED C	GULA DMB / 1/88	NO. 3	50-010	11 5510 1
FACILITY NAME (1)			DOCKET NUMBER (2)	T	LER	NUMBER (6)	PAGE (3)					
PLANT VOGTLE - UNI				YEAR	8	SEQUENTIAL REVE NUMBER NUM						
	IT 1		0 15 10 10 10 14 12 14	8 7	_p	16 19	_	ορ	0	A	OFO	6

from hand calculated calorimetrics using procedure 14030-1 and the computer calculated calorimetric from the Proteus computer point U1118. Past computer logs were also examined to determine the time intervals involved. The investigation also continued to evaluate recent plant operating conditions.

The following table indicates additional dates and time intervals when the RTP was exceeded, and information source:

DATES	TI	ME INTERVALS (hours)	DATA SOURCE	MAX MWT*	CALC MWT	% Power
9/30/87 10/6/87 10/7/87	8 8 14	(approximate) (approximate) (approximate)	U1118 and 14030-1 U1118 and 14030-1 U1118 and 14030-1	3440 3442 3441	3431 3431 3439	1.009 1.009 1.009
11/4/87	7	(approximate)	U1118 and 14030-1	3484**		1.022

* From computer point U1118 **No calculated value available for comparison

> During the last week in September, the feedwater flow transmitters that are used for calculations of 14030-1 were recalibrated. Prior to the calibration of the flow transmitters, a comparison was made of the thermal power from calculations using calorimetric procedure 14030-1 and the Proteus computer point Ull18. This comparison demonstrated that the calculated value exceeded computer point Ull18 by 20 MWT. Indicated feedwater flow was reduced by almost 1 percent which indicates that reactor thermal power may have been overestimated conservatively by almost 1 percent. After the calibration of the feedwater flow transmitters, a comparison was performed between the calculated calorimetric, Procedure 14030-1, and the Proteus computer point Ull18. The results show the calculated value is 5 to 7 MWt less than the computer point Ull18. No specific conclusions have been reached at this time as a result of this data.

D. CAUSE OF EVENT

The plant has been controlled based upon the indication of the NIs. This was considered to be the most conservative approach, since there had not been an engineering evaluation of the accuracy and acceptability of the Proteus output. The calibration of the NIs (once every twenty-four (24) hours per operations procedure 14030-1) is based upon the calcoratetric results from either the computer calorimetric (point Ull18) or, as was normally the case, the hand calculated calorimetric. This procedure had an acceptance

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104

EXPIRES 8/31/88

FACILITY NAME (1)	DOCKET NUMBER (2)							L	ER NU	PAGE (3)								
	1Ľ					Ľ	EAR		SEO	UENTIAL		REVISION NUMBER		T				
PLANT VOGTLE - UNIT 1	0	15	0	0	0	14	2	1	8 7	-	0	69	-	0 0	0 15	OF	0	16

criteria of +2%,-2% in comparison with the calorimetric and required adjustment if the criteria were not met. Although the NI indication was used to control the reactor power at approximately 100%, the calorimetric data could indicate values as high as 102%. This was caused by the NIs being allowed to indicate below the calorimetric value. A software program was never established to control reactor power based upon a continuous MWt output value.

The difference of the NIs and the Proteus computer point Ull18 will be discussed in the supplemental LER.

E. ANALYSIS OF EVENT

NRC Form 366A

Reactor data demonstrated that none of the reactor trip limits were approached. Although the licensed power limit was exceeded, there was no event or condition that resulted in the nuclear power plant being in an unanalyzed condition that significantly compromised plant safety. Further evaluations and investigations are being performed and the analysis for these events will be discussed in the supplemental LER.

F. CORRECTIVE ACTIONS

Corrective action taken include the following:

- A temporary change to procedure 1:030-1, "Power Range Calorimetric Channel Calibration", was issued to change the the Power Range Channels acceptance criteria to +2%, -0% of the calculated calorimetric power. This sets the NIs so they read the same or higher than the calculated calorimetric. Now, three (3) sets of data are taken and averaged for the calorimetric calculations.
- A standing order was issued to perform 14030-1 every six (6) hours, to log NIs power every hour, and to operate utilizing the highest reading on a NIs channel. The continuous monitoring of reactor power ensures that the RTP of the license is not exceeded.
- A revision to procedure 12004-1, "Power Operation", was issued. The change includes adding the following:
 - At 98% RTP, perform a calorimetric as soon as power has stabilized.

LICENSEE	EVENT	REPORT	(LER)	TEXT	CONTINUATION
----------	-------	--------	-------	------	--------------

U.S. NUCLEAR REGULATORY COMMISSION APPROVED OMB NO. 3150-0104

FACILITY NAME (1)		DOCKET NUM	BER (2)								-	-			
	and the best					YEAR	LEP	SEQUEN	TIAL		REVISION		PAGE	31	
					1	Tean		NUM	BER	-	NUMBER	÷.).			
PLANT VOGTLE - UNIT 1		0 5 0	00	4 2	4	8 7		0 6	19	-	0 0	0 16	OF	0	16
TEXT III more space is required, use additional NRC	Form 386.4 's) (17)														
		(10)													
ь.	perform another of	n (10) 1 calorime	etric.	afte	rr	each	ing	98%	RTI	Ρ					
c.	Reactor Engineer calorimetrics. I raised to 99.99% Reactor Engineer plant and the 24 exceeding 3411 M	ing will With the power of ing will hour ca Wt (the	l reve eir co on the l perion alorin licen	iew p oncur e hig form netri nsed	lan ren hes cal c i pow	t da ce, t re orim s st er 1	ta powe adin etr able eve	and er c ng N ics e to 1).	an l I. unt pro	be il eve	the ent				
d.	If the plant rece reduced to 98% or returning to 99.9	eives a r below 99% powe	power , pert	r tra form	nsi ste	ent ps a	and . an	pow nd b	er • pi	is ric	or to				
4. In ord	ler to begin using	g U1118	, read	tor	eng	inee	rin	g ha	s:						
ā.	performed a veritivalidity of the f	fication Proteus	n eval compu	luati uter	on poi	to d nt U	eter	rmin 8.	e ti	ne					
b.	established the F provide operation	Proteus ns with	compu data	iter on a	dis n a	play vera	an gin	d/or g ba	lo sis	gs	to				
с.	revised operation	ns proce	edure	(s).											
These action	is (1-4) were com	pleted 1	by Dec	embe	r 3	1, 1	987								
When complet perform acti Proteus comp computer fai will provide	ed and implemente ons 1, 2, and 3 a uter point U1118 lure or verifica the alternate me	ed, it w above. cannot tion of eans to	Howey Howey be ut an ir monit	ver, tiliz haccu	ude in ed, rac he	the the eit y, p reac	neo even her roco tor	cess nt t thr edur pow	ity hat ough e 12 er.	to th h 200) 1e)4-1				
G. ADDITIONAL 1	NFORMATION														
1. Failed None	Components														
2. Simila None	r Events														
3. Energy Reacto	Industry Identia or Core - AC	fication	n Syst	tem C	ode										

NRC . ORM 386A (9-83)

NRC Form 386A (9-33)

Georgia Power Company 333 Piedmont Avenue Atlanta, Georgia 30308 Telephone 404 526-6526

. .

Mailing Address: Post Office Box 4545 Atlanta: Georgia 30302

L. T. Gucwa Manager Nuclear Safety and Licensing



SL-3875 0695m X7GJ17-V310

January 5,1988

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555

PLANT VOGTLE - UNIT 1 NRC DOCKET 50-424 OPERATING LICENSE NPF-68 LICENSEE EVENT REPORT OPERATING ABOVE THE MAXIMUM POWER SPECIFIED IN THE OPERATING LICENSE

Gentlemen:

In accordance with the requirements of our facility operating license, Georgia Power Company is submitting a Licensee Event Report (LER) concerning events where the plant was operated marginally above the power leval specified in our license. The licensee event report was submitted after the expiration of the thirty day reporting requirement due to the need for a detailed review of plant records over the recent holiday period. This delay was acknowledged by Region II personnel in a telephone conversation on December 21, 1987.

Sincerely,

AT Quan

L. T. Gucwa

PAH/1m

Enclosure: LER 50-424/1987-069

c: (see next page)



. . . .

U. S. Nuclear Regulatory Commission January 5,1988 Page Two

c: <u>Georgia Power Company</u> Mr. J. P. O'Reilly Mr. P. D. Rice Mr. G. Bockhold, Jr. Mr. J. E. Swartzwelder Mr. C. W. Hayes GO-NORMS

> Southern Company Services Mr. R. A. Thomas Mr. J. A. Bailey

Shaw, Pittman, Potts & Trowbridge Mr. B. W. Churchill, Attorney-at-Law

Troutman, Sanders, Lockerman & Ashmore Mr. A. H. Domby, Attorney-at-Law

<u>U. S. Nuclear Regulatory Commission</u> Dr. J. N. Grace, Regional Administrator Mr. J. B. Hopkins, Licensing Project Manager, NRR (2 copies) Mr. J. F. Rogge, Senior Resident Inspector-Operations, Vogtle

0695m

700775