

Detroit
Edison

Douglas R. Gipson
Senior Vice President
Nuclear Generation

Fermi 2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-5249

September 10, 1993
NRC-93-0089

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

- References:
- 1) Fermi 2
NRC License No. NPF-43
NRC Docket No. 50-341
 - 2) NRC Inspection Report 50-341/93010, dated
June 30, 1993
 - 3) Detroit Edison letter to NRC, NRC-93-0085, "Response
to Notice of Violation 93-010-06 & 08" dated July
28, 1993

Subject: Withdrawal of Request on NOV 93-010-06

In response to Notice of Violation (NOV) 93-010-06 (Reference 3), Detroit Edison had requested that the NRC review the conclusion of the cited violation and consider the applicability of NRC policy on the exercise of discretion. Subsequent to this response, additional discussions have taken place with the NRC Senior Resident Inspector (SRI) regarding this event and the initial acceptance of the results for the surveillance test in question. In these discussions, Detroit Edison acknowledged that a Deviation Event Report (DER) should have been initiated at the time of discovery to further investigate the validity and potential impact of the relief valve setpoint noted in the test results. In view of this, we hereby withdraw our previous request that the NRC reconsider the severity level assigned to this violation. It is the understanding of Detroit Edison that the NRC still considers this to be a Severity level IV violation.

As stated in Reference 3, to prevent recurrence, procedure 24.139.03 was revised to Revision 25 to better define an acceptable relief valve test during that inspection period. Therefore, in response to the issuance of NOV 93-010-06, no further corrective action is required to be taken. With respect to this issue, Detroit Edison is currently in full compliance with 10 CFR 50, Appendix B, Criterion V.

170022


9309200099 930910
PDR ADOCK 05000341
G PDR

ED
10

USNRC
September 10, 1993
NRC-93-0089
Page 2

If you have any questions, please contact Elizabeth A. Hare at
(313) 586-1427.

Sincerely,



cc: T. G. Colburn
W. J. Kropp
J. B. Martin
M. P. Phillips
Region III