

SEP 16 1993

Docket Nos. 50-220
50-410

Mr. B. Ralph Sylvia
Executive Vice President - Nuclear
Niagara Mohawk Power Corporation
301 Plainfield Road
Syracuse, New York 13212

Dear Mr. Sylvia:

SUBJECT: NRC REGION I COMBINED INSPECTION REPORT NOS.
50-220/93-15 AND 50-410/93-15

This letter transmits the NRC Region I inspection report for the inspections conducted by Mr. R. Bhatia of this office on July 19-23, 1993, at Niagara Mohawk, Salina Meadows Office in Syracuse, New York, and at Nine Mile Point Units 1 and 2, Scriba, New York. Mr. Bhatia discussed the findings of this inspection with members of your staff at the conclusion of the inspection.

Areas examined during this inspection focused on assessing the offsite power supply sources for Nine Mile Units 1 and 2 and your completed corrective actions to close the previous Electrical Distribution Functional Inspection (EDSFI) outstanding items for Unit 1. The inspection included the ongoing breaker replacement effort to further enhance the offsite power supply sources for Unit 2, based on several concerns generated by the loss of power events during the last two years. Within this scope, the inspection consisted of selective examinations of design records, procedures and representative records, interviews with personnel, and observations by the inspector.

Overall, the inspector concluded that the Nine Mile Point 1 and 2 offsite power sources are reliable. We note that you have taken adequate steps to assure corrective and preventive measures to enhance the reliability of the station offsite power supply sources. Further, you are replacing the four less reliable 115 kV breakers in the Scriba substation during the 1993 fall refueling outage of Unit 2. In addition, the corrective actions for three previously identified issues were found to be adequate and the items are closed. One other issue reviewed pertaining to the emergency diesel generator transient loading analysis was found partially complete; however, because of the low margin obtained in your calculation results, you have taken

OFFICIAL RECORD COPY A:NM9315.INS

9309210026 930916
PDR ADOCK 05000220
G PDR

JEOL

Mr. B. Ralph Sylvia

2

additional test data to confirm that your computer model assumptions are adequate. Therefore, this item is updated in this report. Within the scope of this inspection, no violation or deviation was observed.

Your cooperation with us in this matter is appreciated.

Sincerely,

Jacque P. Durr, Chief
Engineering Branch
Division of Reactor Safety

Enclosure: NRC Region I Combined Inspection Report Nos. 50-220/93-15 and
50-410/93-15

cc w/encl:

C. Terry, Vice President - Nuclear Engineering
J. Perry, Vice President - Quality Assurance
Vice President - Nuclear Generation
K. Dahlberg, Unit 1 Plant Manager
M. McCormick, Unit 2 Plant Manager
D. Greene, Manager, Licensing
J. Warden, New York Consumer Protection Branch
G. Wilson, Senior Attorney
M. Wetterhahn, Winston and Strawn
Director, Energy & Water Division, Department of Public Service, State of New York
C. Donaldson, Esquire, Assistant Attorney General, New York Department of Law
K. Abraham, PAO (2)
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
State of New York, SLO Designee

SEP 16 1993

Mr. B. Ralph Sylvia

bcc w/encl:

Region I Docket Room (with concurrences)

C. Cowgill, DRP

L. Nicholson, DRP

D. Weaver, DRP

W. Schmidt - Nine Mile Point

V. McCree, OEDO

R. Capra, NRR

J. Menning, NRR

D. Brinkman, NRR

RI:DRS

Bhatia

RS

09/7/93

Jeb H
RI:DRS

Ruland

09/7/93

RI:DRS

Durr

09/ /93

OFFICIAL RECORD COPY A:NM9315.INS