

Docket No. 50-336
B12723

Attachment 1

Removal of Control Room Chlorine Detectors

8802090507 880203
PDR ADOCK 05000336
P PDR

February 1988

"This Page Left
Blank Intentionally"

INSTRUMENTATION

3/4.3.3.6 Fire Detection Instrumentation

OPERABILITY of the fire detection instrumentation ensures that adequate warning capability is available for the prompt detection of fires. This capability is required in order to detect and locate fires in their early stages. Prompt detection of fires will reduce the potential for damage to safety related equipment and is an integral element in the overall facility fire protection program.

In the event that a portion of the fire detection instrumentation is inoperable, the establishment of frequent fire patrols in the affected areas is required to provide detection capability until the inoperable instrumentation is restored to OPERABILITY.

3/4.3.3.7 Accident Monitoring Instrumentation

The OPERABILITY of the accident monitoring instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables during and following an accident. This capability is consistent with the recommendations of NUREG-0578, "TMI-2 Lessons Learned Task Force Status Report and Short-Term Recommendations".