

SEP 10 1993

Docket Nos. 50-334  
50-412

Mr. J. D. Sicber  
Senior Vice President  
Nuclear Power Division  
Duquesne Light Company  
Post Office Box 4  
Shippingport, Pennsylvania 15077

Dear Mr. Sieber:

SUBJECT: NRC INSPECTION REPORT NOS. 50-334/93-16 AND 50-412/93-17

This refers to the inspection conducted by Messrs. L. Rossbach, P. Sena, and S. Greenlee of this office from July 21 to August 23, 1993. The inspection included a review of activities authorized for the Beaver Valley Power Station in Shippingport, Pennsylvania. At the conclusion of the inspection, the findings were discussed with Mr. D. Sperry and other members of your staff.

Areas examined during the inspection are identified in the report. The inspection consisted of document reviews, interviews, and observation of activities important to public health and safety. The purpose of the inspection was to determine whether activities authorized by the license were conducted safely and in accordance with NRC requirements.

Two non-cited violations were identified. Your staff identified that a Unit 1 hydrogen analyzer train was inoperable. Also, the manner in which you posted NRC Form 3 did not allow the form to be directly seen by individuals passing by. These violations are not being cited because of their minor safety significance and your corrective actions.

No reply to this letter is necessary. Your cooperation with us is appreciated.

Sincerely,

James C. Linville, Chief  
Projects Branch No. 3  
Division of Reactor Projects

9309210048 930910  
PDR ADOCK 05000334  
G PDR

OFFICIAL RECORD COPY

JE01 1/1

SEP 10 1993

Mr. J. D. Sieber

2

Enclosures:

1. NRC Inspection Report Nos. 50-334/93-16 and 50-412/93-17
2. Attachment A, Employee Concerns Programs

cc w/encls:

G. S. Thomas, Vice President, Nuclear Services  
D. E. Spoerry, Vice President, Nuclear Operations  
L. R. Freeland, General Manager, Nuclear Operations Unit  
K. D. Grada, Manager, Quality Services Unit  
N. R. Tonet, Manager, Nuclear Safety Department  
H. R. Caldwell, General Superintendent, Nuclear Operations  
K. Abraham, PAO (2 copies)  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania  
State of Ohio

**OFFICIAL RECORD COPY**

SEP 10 1993

Mr. J. D. Sieber

3

bcc w/encls:

Region I Docket Room (with concurrences)

W. Lazarus, DRP

bcc w/encls: (VIA E-MAIL):

W. Butler, NRR

G. Edison, NRR

D. Wheeler, OEDO

J. Lanning, DRP (see Section 5.5 and Attachment A)

R. Rosano, OWFN 7-H-5 (see Section 5.5 and Attachment A)

J. Calvert, DRS (see Section 2.6)

*Linnville comments  
incorporated*

RI:DRP

LRossbach  
09/01/93

RI:DRP

*[Signature]*  
WLazarus  
19/8

RI:DRP

*[Signature]*  
JLinnville  
9/10/93

OFFICIAL RECORD COPY

A:BV931617.MEO