NRC Forr (9-83)	n 366				LIC	ENSE	EE EVE	NT RE	PORT	(LER)	U.S. N	UCLEA APPRO EXPIRI	AR REGULAT	DRY COMM	AISSION 04
FACILITY	NAME IT	)									DOCKET NUMBER	(2)		PAG	E (3)
McG	ire N	Nuclea	ar Sta	tion - U	nit 2						0 15 10 10	10	131710	1 OF	016
TITLE 14	UNIT	2 RE/	ACTOR	COOLANT	SYSTEM	AND L	JNITS	1&2 PI	RESSUR	IZER EX	CEEDED HE	ATU	P AND (	COOLDO	WN
RATE	ALLO	VED BY	Y TECH	INICAL SP	ECIFICA	TIONS	5 - FA	ILED 1	TO REC	COGNIZE D	ISCREPANC	IES	- PERS	SONNEL	ERR
€VI	INT DATE	(6)		LER NUMBER	(6)	R	EPORT DA	TE (7)		OTHER	FACILITIES INVO	LVED	(8)		
MONTH	DAY	YEAR	YEAR	NUMBER	REVISION NUMBER	MONTH	YAQ I	YEAR		FACILITY NA	MES	000	KET NUMBE	R(\$)	
		100	-									0	151010	101	1
1 12	1   1	8 7	8 7 -	0 2 0	-010	0 1	29	8 8				0	151010	101	11
OPE	RATING	11-	THIS REPO	AT IS SUBMITTE	PURSUANT	TO THE	REQUIREN	IENTS OF 1	CFR &: 18	Check one or more	of the following) (	11)			
	1		20.40	2(6)	-	20.408	20.406(c) 50.73(a) (2)(iv			50.73(a)(2)(iv)	n		73,71(6)		
LEVE		0.00	20.40	(a)(1)(1)	-	50.36	(a) (2)		-	50.73(a)(2)(vii)			ecity in Ab	stract	
(10)		010	20.40	B(a)(1)(iii)	NY.	80,73	a)(2)(i)		-	50.73(a)(2)(viii))	s)(2)(viii)(A) s)(2)(viii)(A)		below and i 366AJ	n Text, NR	C Form
		ŀ	20.40	(a)(1)(lv)	140	80.73	(a)(2)(U)			50.73(a)(2)(vili))					
		t l	20.40	(a)(1)(v)		50.73	(a)(2)(iii)			50.73(e1(2)(x)					
						ICENSER	CONTAC	T FOR THIS	LER (12)						
NAME												TEL	EPHONE NUN	BER	
STE	VEN E	. LeR	OY - I	ICENSING							TO A	3	7 3	- 6.2	3 . 3
						-					LIL	1	111	1012	P P
				COMPLETE	ONE LINE FOR	EACH C	COMPONEN	TFAILURE	DESCRIBE	ID IN THIS REPOI	1 (13)	T			
CAUSE	SYSTEM	COMPO	NENT	MANUFAC- TURER	REPORTABLE TO NPROS			CAUSE	SYSTEM	COMPONENT	MANUFAC- TURER	RI	EPORTABLE TO NPROS	•	
	-	11		III.		ļ			1		111	-			
	1	11	1	111					1	111					
				SUPPLEM	INTAL REPORT	EXPECT	TED (14)				EXPEC	CON	MONTH	A DAY	YEAR
-	100	annista FX	PECTED S	IRMISSION DATE			NO.				DATE	15)		1.	
	Durin an ev sever limit Dpera incid perfo Coola for t integ Error durin proce assig limit surge this an ev	g Deci aluat: al evi s and tions ents a rmed a the Pri becan g the dures ned a s bein s are proble	ember ion of ents v one v (OPS) occurr a prei C) sys essur: of the use n shute compi cause ng exe not v em wit	1987, A- f Quality where pla violation ) discove red durin liminary stem inte izer (PZF e PZR and o discrep down and lete with e of Mana ceeded wa uncommon th Design ad OPS with	halysis Assuration of Tec ered oth ng norma evaluat evaluat all action startup h all action during h Engine 11 revi	and nce down hnice er part ion nd co he No tem. were mode cepta Defin o NC this erin se a	Evalua (QA) a and h al Spe ast in utdown of eff onclue C syst notee es of ance of ciency surge mode g and ppropr	ation survei heatup ecific nciden ns. O fects ded th tem di s even d by O opera criter y beca es int of op Westi riate	of Ope llance rates ations ts that n 12/1 of sin at exc d not t is a PS on tion, ia be: use on o and eratic nghous proces	erational e. This s exceede s (TS). at exceed ll and 16 milar tra ceeding r compromi assigned 3 out of and OPS ing met. ne reason out of t on; OPS s se. West dures.	Data (NH evaluatio d Adminis Subsequer ed TS lin /87, West nsients o he allowa se struct a cause o 4 proceo verified This eve for the he PZR. hould hav inghouse	C) on i stra tly hits ing on t ble cura of P dure the ent TS Sir e a will	conduc indicat ative y, s. The ghouse the Rea a TS 11 al Personn es used is als cooldo nce the address ll prov	ted ed ctor mits el o wn se ed ide	
		8802 PDR S	0905 ADO	75 8801 CK 0500	29 0370 PDR								I	EZZ	e

U S. NUCLEAR REGULATORY COMMISSION APPROVED OME NO 3150-0104 EXPIRES 8/31 95

FACILITY NAME (1)	DOCK ET NUME IR (2)	LER NUMBER (8)	PAGE (3)	
		VEAR SEQUENTIAL REVION		
McGuire Nuclear Station - Unit 2	0 15 10 10 10 1 31 71	0 817 - 01210 - 010	012 05 016	

DKT (# more space # required, use additional ARC Form 3864's) (17)

# INTRODUCTION:

RC Forin 364A

During December 1987, Nuclear Regulatory Commission Analysis and Evaluation of Operational Data (NRC) personnel conducted an evaluation of Quality Assurance (QA) surveillance reports. This evaluation indicated several incidents on both units where plant cooldown and heatup rates exceeded Administrative limits and one violation of Technical Specification (TS) limits. Subsequently, Operations (OPS) discovered several other past incidents that exceeded TS limits. The incidents occurred during normal shutdowns. On December 11 and 16, 1987, Westinghouse performed a preliminary engineering evaluation of the effects of similar transients on the Reactor Coolant (NC) system [EIIS:AB] integrity and concluded that exceeding the allowable TS rate limits for the Pressurizer (PZR) [EIIS:PZR] and the NC system did not compromise the structural integrity of the PZR and the NC system.

Both units were in Mode 1, Power Operation, at the time this event was discovered.

This event has been assigned a cause of Personnel Error because there were no discrepancies noted by OPS on 3 out of 4 procedures used during the shutdown and startup modes of operation, and OPS personnel verified the procedures complete with all acceptance criteria being met. This event has also been assigned a cause of Management Deficiency because one reason for the TS cooldown limits being exceeded was due to NC surges into and out of the PZR. Since these surges are not uncommon during this mode of operation and there is always the potential for Administrative and TS limits being exceeded. OPS should have addressed this problem with Design Engineering and Westinghouse.

### EVALUATION:

## Background

The NC system transports heat from the reactor [EIIS:RCT] core to the steam generators [EIIS:SG], where heat is transferred to the Feedwater [EIIS:SJ]/Main Steam [EIIS:SB] Systems. The NC system consists of four Steam Generators connected in parallel to the reactor vessel [EIIS:VSL]. In addition, the system includes a PZR, a PZR Relief Tank [EIIS:TK], interconnecting piping [EIIS:PSP], valves [EIIS:V], and instrumentation necessary for operational control.

The NC system pressure is controlled by the PZR where water and steam are maintained at saturation by electrical heaters [EIIS:HTR] and water sprays. Steam can be formed (by the heaters) or condensed (by the PZR spray) to reduce pressure variations due to contraction and expansion of the NC system.

The PZR is designed to accommodate positive and negative surges caused by load transients. The surge line, which is attached to the bottom of the PZR, connects the PZR to the hot leg of "B" NC system loop. During an insurge from the NC system, the spray system, which is fed from "A" and "B" cold legs,

U & NUCLEAR REGULATORY COMMISSION APPROVED OME NO 3150-0104 EXPIRES 8/31 95

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (8)	PAGE (3)
		YEAR SEQUENTIAL NEVISION	
McGuire Nuclear Station - Unit 2	0 5 0 0 0 3 7 0	87 920 00	930F 016

TEXT IN more space a required, use additional NIAC Form 3064's/ (17)

AC Form 364A

condenses steam in the vessel to prevent the pressure from reaching the setpoint of the Power Operated Relief Valves [EIIS:RV]. During an outsurge from the PZR, flashing of water to steam and the generating of steam by automatic actuation of the heaters, keeps the pressure above the low pressure reactor trip setpoint.

TS 3/4.9.1 states that the NC system (except the PZR) shall be limited to a maximum heatup rate of 100 degrees-F for Unit 1 and 60 degrees-F for Unit 2 in any one hour period, a maximum cooldown rate of 100 degrees-F in any one hour period, and a maximum temperature change of less than or equal to 10 degrees-F in any one hour period during inservice hydrostatic and leak testing operations above the heatup and coolcown limit curves. These conditions are applicable at all times. With any of the above limits exceeded, the temperature and/or pressure must be restored to within the limit within thirty minutes and an engineering evaluation must be performed to determine the effects of the out-of-limit condition on the structural integrity of the NC system. If the evaluation indicates that the structural integrity is unacceptable for continued operation, the unit must be in at least Hot Standby within the next six hours and the NC system T-ave and pressure must be reduced to less than 200 degrees-F and 500 psig, respectively, within the following thirty hours. The NC system temperature and pressure shall be determined to be within the limits at least once every thirty minutes during system heatup, cooldown, and inservice leak and hydrostatic testing operations.

TS 3/4.9.2 states that the PZR temperature shall be limited to a maximum heatup rate of 100 degrees-F in any one hour period, a maximum cooldown rate of 200 degrees-F in any one hour period, and a maximum spray water temperature differential of 320 degrees-F. These conditions are applicable at all times. With the PZR temperature limits in excess of any of the above limits, the temperature must be restored to within the limits within thirty minutes and an engineering evaluation must be performed to determine the effects of the out-of-limit condition on the structural integrity of the PZR. If the PZR's structural integrity is unacceptable for continued operation, the unit must be in at least Hot Standby within the next six hours and the PZR pressure must be reduced to less than 500 psig within the following thirty hours. The PZR temperatures shall be determined to be within the limits at least once every thirty minutes during system heatup or cooldown.

The purpose of Surveillance Requirements for Unit Shutdown, PT/1,2/A/4600/09 and Precriticality Surveillance Requirements For Unit Startup, PT/1,2/A/4600/08, is to document various TS requirements and exhibit safe operating procedures for unit shutdown and startup, respectively. These procedures include administrative limits and precautions requiring that the cooldown rate of the NC system should not exceed 50 degrees-F/hr, the NC system heatup rate should not exceed 50 degrees-F/hr, the PZR cooldown rate should not exceed 100 degrees-F/hr and the PZR heatup rate should not exceed 50 degrees-F/hr.

Operations Management Procedure 1-2 states that after the completion of a Periodic Test, & Operations Supervisor shall determine that each applicable

U & NUCLEAR REGULATORY COMMISSION APPROVED OME NO 3150-0104 EXPIRES 8/31 95

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)	PAGE (3)	
	1. A. A. A.	YEAR SEQUENTIAL REVISION NUMBER		
McGuire Nuclear Station - Unit 2	0 5 0 0 0 3 7 0	8 7 _ 0 2 0 _ 0 0	014 00 0 16	

surveillance item meets its specified acceptance criteria or is identified as a discrepancy, and is evaluated according to TS and appropriate corrective action is initiated (work request, etc.).

A Procedure Discrepancies Process Record shall be filled out for any discrepancies and routed to a Senior Reactor Operator (SRO) for approval. After SRO approval, the SRO routes the Procedure Discrepancies Process Record and the procedure to the Unit Coordinator or his designee. The Unit Coordinator or his designee insures the Procedure Discrepancies Process Record and procedure is completed properly.

# Description of Event

RC Form 384.A

During a normal unit shutdown on April 27, 1981, between 1130 and 1200, the Unit 1 PZR experienced a cooldown event that exceeded the TS cooldown limit of 200 degrees-F/hr by 21 degrees-F. Also on the same day between 1200 and 1300, and 1230 and 1330, the Unit 1 PZR experienced heatup events that exceeded the TS heatup limit of 100 degrees-F/hr by 118 degrees-F and 26 degrees-F, respectively. According to OPS, the TS limits were exceeded because of an increase in PZR level due to NC system surges into the PZR.

During a normal unit startup on July 20, 1981, between 2400 and 0100, the Unit 1 PZR experienced a heatup event that exceeded the TS heatup limit of 100 degrees-F/hr by 20 degrees-F. There were no discrepancies noted on the procedure.

During a normal unit shutdown on May 3, 1983, between 1700 and 1800, the Unit 2 NC system experienced a cooldown event that exceeded the TS cooldown limit of 100 degrees-F/hr by 1 degree-F. There were no discrepancies noted on the procedure and the procedure was verified complete by OPS personnel with all acceptance criteria being met.

During a normal unit shutdown on April 21, 1985, between 0930 and 1050, the Unit 2 PZR experienced a cooldown event that exceeded the TS cooldown limit of 200 degrees-F/hr by 19 degrees-F. Also on the same day, the Unit 2 PZR experienced two heatup events, one between 1000 and 1100 and the other between 1030 and 1100, that exceeded the TS heatup limit of 100 degrees-F/hr by 28 degrees-F and 74 degrees-F, respectively. There were no discrepancies noted on the procedure, and the procedure was verified as complete by OPS with all acceptance criteria being met.

During December 1987, NRC personnel conducted an evaluation of QA surveillance reports and noted several observations which were made by QA concerning plant cooldown rates that exceeded Administrative cooldown rates. NRC and OPS researched the Surveillance Requirements For Unit Shutdown and Precriticality Surveillance Items for Unit Startup Procedures, and found events where plant cooldown and heatup rates exceeded TS limits. These events occurred during normal shutdown and startup.

U & NUCLEAR REGULATORY COMMISSION APPROVED DMB NO 3150-0104 EXPIRES 8/31/95

FACIL - 7 NAME (1)	DOCKET NUMBER (2)	LER NUMBER IS	PAGE J	
		YEAR SEQUENTIAL REVISION		
McGuire Nuclear Station - Unit 2	0 5 0 0 0 3 7 0	8 7 0 2 0 0 0	0 5 0 0 6	

#### TEXT (If more space is required, use additional hift: Form 3864 (s) (17)

On December 11 and 16, 1987, Westinghouse performed a preliminary PZR heatup and cooldown transient evaluation and found that the Unit 1 and Unit 2 PZRs, and the Unit 2 NC system's structural integrity had not been compromised.

## Conclusion

AC Form 384A

Betwe 5 1981 and 1985, the Unit 2 NC system, and the Unit 1 and the Unit 2 PZRs experienced transient events that exceeded administrative and TS limits. There was only one procedure, which was dated April 27, 1981, that indicated a discrepancy in surveillance requirements; all other procedures indicated no discrepancies and were verified as complete by OPS personnel with all acceptance criteria being met. OPS personnel did not thoroughly review the procedures to recognize the transients as discrepancies and therefore did not note them on the procedures. Therefore, this event has been assigned a cause of Personnel Error.

A cause of Management Deficiency has also been assigned to this event because the transients experienced by the PZR and NG system are not uncommon during the shutdown and startup modes of operation and there is always the potential for Administrative and TS limits being exceeded; OPS should have addressed this problem with Design Engineering and Westinghouse.

Westinghouse performed an engineering evaluation and made a preliminary judgement that the transients experienced by the PZR and the NC system did not compromise their structural integrity. A final engineering evaluation is forthcoming from Westinghouse.

This event is not Nuclear Plant Reliability Data System (NPRDS) reportable.

A review of previous McGuire Licensee Event Reports revealed no other documented events where plant heatup and cooldown rates had been in violation of TS. Therefore, this event is not considered recurring.

### CORRECTIVE ACTIONS:

Immediate: None

1)

Subsequent: Westinghouse performed an engineering evaluation of the effects of similar transients on the NC system's integrity. A preliminary judgement determined that the transient events did not compromise the structural integrity of the Pressurizer and the NC system.

Planned:

OPS will review this report with a representative from each shift to emphasize the importance of thoroughly reviewing procedures for discrepancies and properly completing procedures.

US NUCLEAR REGULATORY COMMISSION APPROVED OME NO 3150-0104 EXPIRES 8/31/95

FACILITY NAME (1)	DOCKET NUMBER (2)	LER NUMBER (6)	PAGE IS	
		YEAR SEQUENTIAL AEVISION NUMBER NUMBER		
McGuire Nuclear Station - Unit 2	0 15 10 10 10 1 3 7 0	8 7 _ 0 2 0 _ 0 0	0 6 0 0 0 6	

EXT (If more space is required, use additional NRC Form 3864's) (17)

 Westinghouse will submit a final engineering evaluation and OPS will revise the appropriate procedures based on recommendations from Westinghouse.

NOTE: Based on the results of the Westinghouse evaluation and the impact it has on this event, Duke may supplement this report. If so, the supplemental information would be submitted 30 days after receipt of the Westinghouse report.

## SAFETY ANALYSIS:

NAC Form 386A

The U.it 1 PZR experienced cooldown and heatup rates that exceeded the allowable TS limits. The PZR temperature ranged from 196 degrees-F to 427 degrees-F during the events. The NC system pressure varied between 313 psi and 337 psi. The NC system temperature varied from 144 degrees-F to 168 degrees-F. The maximum temperature that the cooldown and heatup rates of the Unit 1 PZR were exceeded was 21 degrees-F and 118 degrees-F, respectively.

The Unit 2 PZR experienced cooldown and heatup events that exceeded the allowable TS limits. The NC system and PZR pressure varied between 50 psi and 300 psi during the cooldown. Also, the Unit 2 NC system experienced a cooldown rate exceeding allowable TS limits. During this cooldown, the PZR water temperature ranged from 650 degrees-F to 428 degrees-F, the NC system temperature ranged from 55. degrees-F to 184 degrees-F and the NC system pressure ranged from 2268 psi to 328 psi. The maximum temperature that the cooldown and heatup rates of the Unit 2 PZR were exceeded was 19 degrees-F and 74 degrees-F, respectively. The Unit 2 NC system exceeded its cooldown rate by 1 degree-F.

NC surges into and out of the PZR are not uncommon during the heatup and cooldown modes of operation, and based on the above information and experience with evaluation of the effects of similar transients on the NC system's integrity, it was Westinghouse's preliminary judgement that the events above did not compromise the structural integrity of the Unit 1 and the Unit 2 PZRs and related systems or the Unit 2 NC system.

Also, Quality Assurance personnel performed non-destructive examinations of Pressurizer primary welds and NC system primary welds during the 1986 outage. Any significant failure in the structural integrity of the PZR or the NC system would have been noted during these examinations. There were none noted.

There were no personnel injuries, personnel overexposures, or releases of radioactive material as a result of this event.

This event is considered to be of no significance with respect to the health and safety of the public.

DUKE POWER COMPANY P.O. BOX 33189 CHARLOTTE, N.C. 28242

HAL B. TUCKER

TELEPHONE (704) 373-4531

January 29, 1988

U.S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

Subject: McGuire Nuclear Station, Unit 2 Docket No. 50-370 Licensee Event Report 370/87-20

Gentlemen:

Pursuant to 10CFR 50.73 Sections (a)(1) and (d), attached is Licensee Event Report 370/87-20 concerning McGuire exceeding allowable technical specification limits for heatup and cooldown of the Unit 2 reactor coolant system and Units 1 and 2 pressurizers. This report was to have been submitted on January 11, 1988; however, was delayed till January 29, 1988 by my letter of December 29, 1987. This report is being submitted in accordance with 10CFR 50.73(a)(2)(i)(B). This event is considered to be of no significance with respect to the health and safety of the public.

Very truly yours,

Hall. Tuckerpun

Hal B. Tucker

SEL/217/jgc

Attachment

xc: Dr. J. Nelson Grace Regional Administrator, Region II U.S. Nuclear Regulatory Commission 101 Marietta St., NW, Suite 2900 Atlanta, GA 30323

> INPO Records Center Suite 1500 1100 Circle 75 Parkway Atlanta, GA 30339

M&M Nuclear Consultants 1221 Avenue of the Americas New York, NY 10020 American Nuclear Insurers c/o Dottie Sherman, ANI Library The Exchange, Suite 245 270 Farmington Avenue Farmington, CT 06032

Mr. Darl Hood U.S. Nuclear Regulatory Commission Office of Nuclear Reactor Regulation Washington, D.C. 20555

Mr. W.T. Orders NRC Resident Inspector McGuire Nuclear Station

