



Nebraska Public Power District

COOPER NUCLEAR STATION
P.O. BOX 98, BROWNVILLE, NEBRASKA 68321
TELEPHONE (402)625-3811
FAX (402)825-5211

NLS970133

July 15, 1997

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: Monthly Operating Status Report for June 1997, Docket No. 50-298.

Gentlemen:

Enclosed for your information and use is the Cooper Nuclear Station Monthly Operating Status Report for June 1997. In accordance with the guidance provided by Generic Letter 97-02, this report includes an Operating Data Report and Unit Shutdown Report for the month of June.

Should you have any comments, or require additional information regarding this report, please contact me.

Sincerely,

M. F. Peckham
Plant Manager

MFP:lb
Enclosures

cc: ANI Library
R. W. Beck and Associates
T. L. Bundy
J. M. Cline
A. L. Dostal
P. D. Graham
R. L. Gumm
INPO Records Center
E. A. Lanning
T. LaPorte
B. Lewis
J. L. Long
W. R. Mayben
NRC Regional Administrator
NRC Senior Resident Inspector
E. Pasche
R. D. Stoddard
W. Turnbull

1/1
Je24

9707180027 970630
PDR ADOCK 05000298
R PDR



**APPENDIX A
OPERATING DATA REPORT**

DOCKET NO. 050-0298
 UNIT NAME Cooper Nuclear Station
 DATE 7/15/97
 COMPLETED BY P. L. Ballinger
 TELEPHONE (402) 825-5295

Reporting Period: June 1997

	This Month	Yr -to-Date	Cumulative
1. Design Electrical Rating (Net MWe). The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.	<u>778</u>	<u>N/A</u>	<u>N/A</u>
2. Maximum Dependable Capacity (Net MWe). The gross electrical output as measured at the output terminals of the turbine-generator during the most restrictive seasonal conditions minus the normal station service loads.	<u>764</u>	<u>N/A</u>	<u>N/A</u>
3. Number of Hours the Reactor Was Critical. The total number of hours during the gross hours of the reporting period that the reactor was critical.	<u>720.0</u>	<u>3,088.5</u>	<u>150,733.2</u>
4. Number of Hours the Generator Was On Line. (Also called Service Hours). The total number of hours during the gross hours of the reporting period that the unit operated with the breakers closed to the station bus. The sum of the hours the generator was on line plus the total outage hours should equal the gross hours in the reporting period.	<u>720.0</u>	<u>3,050.0</u>	<u>148,534.1</u>
5. Unit Reserve Shutdown Hours. The total number of hours during the gross hours of the reporting period that the unit was removed from service for economic or similar reasons but was available for operation.	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
6. Net Electrical Energy (MWH). The gross electrical output of the unit measured at the output terminals of the turbine-generator minus the normal station service loads during the gross hours of the reporting period, expressed in megawatt hours. Negative quantities should not be used.	<u>522,911.0</u>	<u>2,232,039.0</u>	<u>97,797,066.0</u>

**APPENDIX B
UNIT SHUTDOWNS**

DOCKET NO.	<u>050-0298</u>
UNIT NAME	<u>Cooper Nuclear Station</u>
DATE	<u>7/15/97</u>
COMPLETED BY	<u>P. L. Ballinger</u>
TELEPHONE	<u>(402) 825-5295</u>

REPORT MONTH June 1997

No.	Date	Type	Duration (Hours)	Reason (1)	Method Of Shutting Down Reactor (2)	CAUSE/CORRECTIVE ACTIONS COMMENTS
		F: FORCED S: SCHEDULED				
None						

SUMMARY: A power reduction was made on 6/14/97 to enter the Drywell and repair minor leakage. The plant returned to full power operation.

(1) Reason:

- A - Equipment Failure (Explain)
- B - Maintenance or Test
- C - Refueling
- D - Regulatory Restriction
- E - Operator Training/License Examination
- F - Administrative
- G - Operational Error (Explain)
- H - Other (Explain)

(2) Method:

- 1 - Manual
- 2 - Manual Trip/Scram
- 3 - Automatic Trip/Scram
- 4 - Continuation
- 5 - Other (Explain)

Correspondence No: NLS970133

The following table identifies those actions committed to by the District in this document. Any other actions discussed in the submittal represent intended or planned actions by the District. They are described to the NRC for the NRC's information and are not regulatory commitments. Please notify the Licensing Manager at Cooper Nuclear Station of any questions regarding this document or any associated regulatory commitments.

COMMITMENT	COMMITTED DATE OR OUTAGE
None	