



Log # TXX-88024
File # 10110
903.8
Ref. # 10CFR50.55(e)

William G. Council
Executive Vice President

January 5, 1988

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
ROLL-AWAY MISSILE SHIELDS (RAMS)
SDAR: CP-87-30 (INTERIM REPORT)

Gentlemen:

On July 1, 1987, we verbally notified your Mr. H. S. Phillips of a deficiency involving errors in the seismic qualification report supplied by the vendor of the Roll-Away Missile Shields (RAMS). A preliminary review of these errors indicated that RAMS were overstressed for the designed seismic conditions detailed in the applicable specifications. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). Our last report was logged TXX-6871, dated October 16, 1987.

We are continuing our evaluation of this issue and will submit our next report by February 5, 1988.

Very truly yours,

W. G. Council

W. G. Council

By: *D. R. Woodlan*

D. R. Woodlan
Supervisor,
Docket Licensing

BSD/grr

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

IE27
1/0