

DUKE POWER COMPANY

P.O. BOX 33189  
CHARLOTTE, N.C. 28242

HAL B. TUCKER  
VICE PRESIDENT  
NUCLEAR PRODUCTION

TELEPHONE  
(704) 373-4531

December 31, 1987


U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Subject: Catawba Nuclear Station, Unit 1  
Docket No. 50-413  
Steam Generator Tube Inspection

Gentlemen:

Pursuant to Technical Specification 4.4.5.5.a and 6.9.2, please be advised that an inservice inspection of Catawba Nuclear Station Unit 1 Steam Generators A, B, C, and D was completed on December 18, 1987. No tubes were plugged as the result of the inspection. Further information will be provided prior to December 18, 1988, pursuant to Technical Specification 4.4.5.5.b.

Very truly yours,



Hal B. Tucker

JGT/1180/sbn

Attachment

xc: Dr. J. Nelson Grace, Regional Administrator  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30323

Mr. P. K. Van Doorn  
NRC Resident Inspector  
Catawba Nuclear Station

8801130433 871231  
PDR ADOCK 05000413  
G PDR

A047  
/0