VERMONT YANKEE NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 88-01

FOR THE MONTH OF JANUARY, 1988

VYDPF 0411 Rev. 1

> 8802110306 880131 PDR ADDCK 05000271 R PDR

2024

OPERATING DATA REPORT

DOCKET NO. 50-271

DATE 880210

COMPLETED BY G.A. Wallin

TELEPHONE (802) 257-7711

OPERATING STATU	S	_				
 Licensed Th Nameplate R Design Elec Maximum Dep Maximum Dep 	eriod: January ermal Power (MWt): 1593 ating (Gross MWe): 540 trical Rating (Net MWe):514(oc endable Capacity (Gross MWe): endable Capacity (Net MWe): occur in capacity ratings (Ite) 504(cc) 535 504	Notes: 3 through 7) since last report,			
	to which restricted, if any (restrictions, if any:	Net MWe): N/A				
13. Reactor Res 14. Hours Gener 15. Unit Reserv 16. Gross Therm 17. Gross Elect 18. Net Electri 19. Unit Servic 20. Unit Availa 21. Unit Capaci 22. Unit Capaci 23. Unit Forced	ours Reactor was Critical erve Shutdown Hours ator On-Line e Shutdown Hours al Energy Generated (MWH) rical Energy Generated (MWH) cal Energy Generated (MWH) e Factor bility Factor ty Factor (using MDC Net) ty Factor (using DER Net) l Outage Rate scheduled over next 6 months (T	This month 744.00 744.00 0.00 744.00 0.00 1169153.00 399527.00 379488.00 100.00 100.00 101.20 99.23 0.00 ype, Date and	Yr-to-Date 744.00 744.00 0.00 744.00 0.00 1169153.00 395527.00 379488.00 100.00 100.00 101.20 99.23 0.00 Duration of 8	Cumulative 105589.36 0.00 103013.27 0.00 150909864.50 50235471.00 47674575.00 76.50 76.50 76.50 70.24 68.88 6.27		
	n at end of report period, est est Status (prior to commercial			1		
VYDPF 0411.01 Rev. 1	INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION		Forecast	Achieved		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.

50-271

MONTE	January	UNIT DATE COMPLE TELEP	Vermont 880210 ETED BY G.A. Wa	Vermont Yankee	
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY A	AVERAGE DAILY PO (MWe-Net)	OWER LEVEL	
1	516	17	512		
2	517	18	517		
3	478	19	518		
4	516	20	519		
5	516	21	519		
6	518	22	519		
7	516	23	519		
8	516	24	516		
9	516	25	519		
10	512	26	518		
11	516	27	518		
12	516	28	518		
13	517	29	518		
14	515	30	395		
15	516	31	473		
16	516				

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

VYDPF 0411.02 Rev. 1

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH January

DOCKET NO. 50-271 UNIT NAME Vermont Yankee DATE 880210 COMPLETED BY G. A. Wallin (802) 257-7711 TELEPHONE

No.	Date	Type	Duration (hours)	2 Reason	Method of Shutting Down Reactor	Licensee Event Report *	4 System Code	5 Component Code	Cause and Corrective Action to Prevent Recurrence
88-01	880130	S	0.00	В,Н*	4 Power Reduction	N/A	RB	CONROD	Control Rod Pattern Exchange and Surveillance Testing
88-01	880130	S	0.00	В	Power Reduction	N/A	СВ	XXXXXX	A and B recirculation MG sets removed from service for brush wear replacement.

F-Forced S-Scheduled 2 Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training and License Examination 4-Other (Explain)

F-Administrative

3 Method:

1-Manual 2-Manual Scram

3-Automatic Scram

4 Exhibit G - Instructions for Preparation of Data Entry

Sheets for Licensee Event Report (LER) File (NUREG 0161)

5 Exhibit I - Same Source

G-Operational Error (Explain) See Above Cause and Corrective Action section

H-Other (Explain) - Control Rod Pattern Exchange

VYDPF 0411.03 Rev. 1

DOCKET NO. 50-271
UNIT Vermont Yankee
880210
COMPLETED BY G.A. Wallin
TELEPHONE (802) 257-7711

REPORT MONTH January

SUMMARY OF OPERATING EXPERIENCES

Highlights

Vermont Yankee operated at 98.6% cf rated thermal power for the month. Gross electrical generation was 395,527 MWHe or 98.4% of design electrical capacity.

Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at $\underline{100.0\%}$ of rated thermal power.

- 880130 At 0948 hours, reduced power to minimum recirculation flow to remove the "P" recirc pump from service from MG set brush wear replacement. (See Unit Shutdowns and Power Reductions).
- 880130 At 1043 hours, initiated control rod exercising.
- 880130 At 1152 hours, completed control rod exercising.
- 880130 At 1300 hours, started the "B" recirc pump following the MG set brush replacement.
- 880130 At 1314 hours, removed the "A" recirc pump from service for MG set brush wear replacement. (See Unit Shutdowns and Power Reductions).
- 880130 At 1345 hours, initiated a rod pattern exchange. (See Unit Shutdowns and Power Reductions).
- 880130 At 1445 hours, completed the rod pattern exchange.
- 880130 At 1523 hours, started the "A" recirc pump following the MG set brush replacement and a return to full power was initiated.

At the end of the reporting period, the plant was operating at $\underline{91.7\%}$ of rated thermal power.



VERMONT YANKEE NUCLEAR POWER CORPORATION

P. O. BOX 157 GOVERNOR HUNT ROAD VERNON, VERMONT 05354

> February 10, 1988 VYV 88-021

U. S. Nuclear Regulatory Commission Director, Office of Management Information and Program Control Washington, D. C. 20555

Dear Sir:

Submitted herewith is the Monthly Statissical Report for the Vermont Yankee Nuclear Power Station for the month of January, 1988.

Very truly yours,

VERMONT YANKEE NUCLEAR POWER CORP.

Warren P./ Murphy Vice President and Manager of Operations

VYDPF 0411 Rev. 1