



**Northeast
Nuclear Energy**

Rope Ferry Rd. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station
Northeast Nuclear Energy Company
P.O. Box 128
Waterford, CT 06385-0128
(860) 447-1791
Fax (860) 444-4277

The Northeast Utilities System

July 9, 1997

Docket No. 50-336
B16562

Re: 10 CFR 50.73(a)(2)(i)

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

This letter forwards Licensee Event Report (LER) 97-022-00, documenting multiple deficient conditions which were identified at Millstone Nuclear Power Station, Unit No. 2, during a detailed review of the unit's Technical Specifications to address commitment B16076-2. This review is ongoing and is expected to identify additional issues which may be reported periodically in supplements to this and other LERs. This LER is a compilation of Technical Specification violations which address conditions that have been present for a significant length of time and are characterized by a low safety significance. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(i).


The following are NNECO's commitments made within this letter.

- B16562-01: A Technical Specification Change Request will be submitted to add appropriate action statements for the Containment Spray and Containment Air Recirculation Systems before entering Mode 4 from the current outage.
- B16562-02: The noble gas surveillance procedure will be revised to properly conform to the applicable Technical Specification referenced Offsite Dose Calculation Manual Requirements before entering Mode 4 from the current outage.

///
Law

9707220025 970709
PDR ADOCK 05003336
S PDR


210064



B16562-03: Technical Specification surveillance procedures will be reviewed to ensure compliance with Technical Specifications surveillance requirements as part of Millstone Unit 2 Operational Readiness Plan (Reference NOV 336/96-08-07, NNECO Commitment No. B16076-2).

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



J. A. Price
Director - Millstone Unit No. 2

Attachment: LER 97-022-00

cc: W. D. Travers, PhD, Director, Special Projects Office
H. J. Miller, Region I Administrator
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2
P. F. McKee, Deputy Director of Licensing, Special Projects Office
W. D. Lanning, Deputy Director of Inspections, Special Projects Office