

PARSONS POWER

Critical Design Characteristics

Overcooling Events

Millstone 2

Prepared By: Richard T. Glavin Date: 7/18/97

Reviewed By: J.A. Brenden Date: 7/18/97

Approved By: [Signature] Date: 7/18/97

Revision 0

9707220037 970718
PDR ADOCK 05000336
P PDR

— PARSONS POWER —

Tier 2 Revision 0
18 July, 1997

TABLE OF CONTENTS

1.0 INCREASE IN HEAT REMOVAL BY THE SECONDARY SYSTEM	2
2.0 CRITICAL DESIGN CHARACTERISTICS	5
2.1 DECREASE IN FEEDWATER TEMPERATURE	5
2.2 INCREASE IN FEEDWATER FLOW	6
2.3 INCREASE IN STEAM FLOW	7
2.4 INADVERTENT OPENING OF A STEAM GENERATOR RELIEF OR SAFETY VALVE	10
2.5 MAIN STEAM LINE BREAK (MSLB) ACCIDENT, RCS ANALYSIS	11

**ATTACHMENT 1
OVERCOOLING EVENTS CRITICAL DESIGN CHARACTERISTICS**

1.0 INCREASE IN HEAT REMOVAL BY THE SECONDARY SYSTEM

1.1 Five design basis events (DBEv's) are considered in section 14.1 of the FSAR. The applicability of each accident for each plant operating mode, and whether an analysis was performed by NNECo, is presented in Figure 1.

Figure 1: Tier-2 AMSR - Overcooling Events					
Plant Oper. Mode	14.1.1 Decrease in Feedwater Temperature	14.1.2 Increase in Feedwater Flow	14.1.3 Increase in Steam flow	14.1.4 Steam Generator Relief Valve Opening	14.1.5 Main Steam Line Break (MSLB)
1	14.1.3	14.1.3	Analyze	14.1.3	Analyze
2	14.1.3	Mode 3	Mode 1	14.1.3	Analyze
3	14.1.3	14.1.3	Analyze	14.1.3	Mode 2
4	N/A	14.1.3	Mode 3	14.1.3	Mode 2
5	N/A	14.1.3	Mode 3	N/A	Mode 2
6	N/A	14.1.3	Mode 3	N/A	Mode 2

Analyze - The DBEv was analyzed, by NNECo, for the listed operating mode and the results summarized in FSAR section 14.1.

Mode "n" - The DBEv is bounded by the mode "n" case ("n" = 1 - 6).

14.1.3 - The DBEv is bounded by another event, in this case by event 14.1.3.

N/A - The DBEv is not applicable for the listed operating mode.

1.2 The AMSR Program will "review" the DBEv's listed as "Analyze" in Figure 1. These are:

DBEv 14.1.3 Mode 1 - 10% increase in steam flow at full power (limiting case).

DBEv 14.1.3 Mode 3 - 41% increase in steam flow at Hot Zero Power, equivalent to rapid opening of the steam dump and turbine bypass valves.

DBEv 14.1.5 Mode 1 - MSLB @ Hot Full Power (HFP) offsite power available,

DBEv 14.1.5 Mode 1 - MSLB @ Hot Full Power (HFP) coincident with a loss of offsite power,

DBEv 14.1.5 Mode 2 - MSLB @ Hot Zero Power (HZP) offsite power available,

DBEv 14.1.5 Mode 2 - MSLB @ Hot Zero Power (HZP) coincident with a loss of offsite power.

1.3 Figure 2 shows the systems involved in the mitigation of each analyzed overcooling event.

Figure 2: Tier-2 AMSR - Systems Involved in Overcooling Events						
SYSTEM	14.1.2 Increase in Steam Flow Mode 1	14.1.2 Increase in Steam Flow Mode 3	14.1.5 MSLB Mode 1	14.1.5 MSLB w/LOOP Mode 1	14.1.5 MSLB Mode 2	14.1.5 MSLB w/LOOP Mode 2
RPS	X	X	X	X	X	X
CEDM	X	X	X	X	X	X
RCS			X	X	X	X
TURB	X	X	X	X		
EHC	X	X	X	X		
MS	X	X	X	X	X	X
MFW			X	X		
AFW			X	X	X	X
CVCS			X	X	X	X
HPSI			X	X	X	X
ELECT DIST	X	X	X	X	X	X
EDG				X		X

1.4 Figure 3 shows the Which Critical Safety Functions have corresponding Critical Design Characteristics for each of the analyzed accidents.

Figure 3: Tier-2 AMSR - Critical Safety Functions with CDCs in Overcooling Events			
Critical Safety Function	14.1.2 Increase in Steam Flow Mode 1	14.1.2 Increase in Steam Flow Mode 3	14.1.5 MSLB Mode 1 (4 Cases)
Reactivity	X	X	X
Fuel Integrity	X	X	X
RCS Heat Removal	X	X	X
RCS Pressure & Inventory	*	*	*
Containment Integrity & Radiation Control			
Electrical Power	X	X	X
Essential Support Systems			
Environmental Control			

* To be determined from detailed analyses

- 1.5 The analyzed event duration, Minimum Departure from Nucleate Boiling Ratio (MDNBR) and Maximum Linear Heat Generation Rate (Max LHGR), as documented in FSAR chapter 14 for each analyzed event, are presented in Figure 4.

Figure 4: Tier-2 AMSR - Overcooling Events Analysis Results

FSAR SECTION 14.1 ANALYZED DESIGN BASIS EVENT	Analyzed Duration (sec)	MDNBR	Max LHGR
DBEv 14.1.3 Mode 1 - 10% increase in steam flow at HFP	43	1.21	19.3
DBEv 14.1.3 Mode 3 - 41% increase in steam flow at HZP	*	*	*
DBEv 14.1.5 Mode 1 - MSLB @ HFP offsite power available	600	3.00	17.1
DBEv 14.1.5 Mode 1 - MSLB @ HFP & loss of offsite power	600	4.6	5.7
DBEv 14.1.5 Mode 2 - MSLB @ HZP offsite power available	600	2.4	20.99
DBEv 14.1.5 Mode 2 - MSLB @ HZP & loss of offsite power	600	1.18	16.5

* Results not available in FSAR section 14.1.3

- 1.6 Critical Design Characteristics Development Method

The following method was used to develop the overcooling event CDCs. Five (5) overcooling events are described in section 14.1 of the FSAR. Each event was reviewed and design inputs extracted. Each design input was assigned to one or more Critical Safety Functions (CSFs). The CSF diagrams were then used to develop functional/system level CDCs for each event.

- 1.7 System Boundary Diagrams

System Boundary Diagrams (SBDs) are developed for each accident mitigation system. Using the SBDs, the AMSR Program Team will identify the system configuration and component actions required to meet the system/functional CDCs. This information will be loaded into the Tier-2 Data Base and will constitute the Chapter 14 requirement at the component level.

- 1.8 CDC Validation

The CDCs will be validated "as present" in the installed plant configuration. The validation method will be determined following review of the detailed analyses supporting the FSAR Chapter 14 events. Milestone-2 system and component test data will be used to the maximum extent possible to perform this validation. When CDCs cannot be validated by test, then analysis or alternate means will be used to perform the validation.

2.0 CRITICAL DESIGN CHARACTERISTICS

A discussion of each FSAR section 14.1 DBEv, and the functional/system CDC listing, are presented in sections 2.1 through 2.5 of this attachment. These CDCs will be augmented with information derived from FSAR Chapter 6, 7, 8 and 9, and the detailed analyses and calculations that support FSAR Chapter 14.

2.1 DECREASE IN FEEDWATER TEMPERATURE

2.1.1 EVENT DESCRIPTION

The decrease in feedwater temperature event is discussed in FSAR section 14.1.1. The event can be caused by loss of one or more feedwater heaters. This can occur due to a loss of extraction steam or due to heater bypass. The worst case loss of feedwater heaters would occur if the low pressure heaters were bypassed. The most limiting case is from rated power.

2.1.2 DESIGN BASIS

N/A - Bounded by event 14.1.3

2.1.3 SYSTEM INTERFACE

N/A - Bounded by event 14.1.3

2.1.4 EVENT DISPOSITION

This event is bounded by the Increase in Steam Flow Event discussed in FSAR Section 14.1.3, and thus is not analyzed.

2.1.5 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.1: DECREASE IN FEEDWATER TEMPERATURE

This event is bounded by event 14.1.3. Therefore, no functional/system level CDCs are identified.

2.2 INCREASE IN FEEDWATER FLOW

2.2.1 EVENT DESCRIPTION

The increase in feedwater flow event is discussed in FSAR section 14.1.2. The event is initiated by a failure in the feedwater system which causes an increase in feedwater flow to the steam generators. The limiting consequences of the increase in feedwater flow will occur at rated power conditions and will bound all other power operating conditions due to the initial steam generator inventory and initial margin to DNB. The largest cooldown which can be postulated due to feedwater addition at full power is the inadvertent startup of all three AFW pumps. This cooldown rate is less than that calculated for event 14.1.3, Increase in Steam Flow, and thus is bounded by that event.

2.2.2 DESIGN BASIS

N/A - Bounded by event 14.1.3

2.2.3 SYSTEM INTERFACE

N/A - Bounded by event 14.1.3

2.2.4 EVENT DISPOSITION

This event is bounded by the Increase in Steam Flow Event discussed in FSAR Section 14.1.3.

2.2.5 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.1: INCREASE IN FEEDWATER FLOW

This event is bounded by event 14.1.3. Therefore, no functional/system level CDCs are identified.

2.3 INCREASE IN STEAM FLOW

2.3.1 EVENT DESCRIPTION

This event is initiated by a failure or misoperation in the main steam system which results in an increase in steam flow from the steam generators. The simultaneous opening of the condenser dump and turbine bypass valves could result in a steam load increase of 41% above full rated load. The consequences of this event for all other power operating conditions, including Mode 2, are bounded by the rated power operating conditions. The Mode 3 condition bounds modes 4 - 6 for "zero power" initial conditions. This energy removal rate also bounds the rated power operating conditions for events 14.1.1, 14.1.2 and 14.1.4.

2.3.2 DESIGN BASIS

The MNPS-2 Increase in Steam Flow analysis is based on the following primary assumptions:

- a. Most reactive control rod stuck in its fully withdrawn position.
Reference: FSAR Section 14.0.6
- b. Single failure criteria for offsite power case is (to be determined)
- c. Single failure criteria for LOOP case does not apply.

2.3.3 SYSTEM INTERFACE

The following systems interface during this event:

- a. Main Steam
- b. Control Element Drive
- c. Reactor Protection System
- d. Turbine Generator (Turbine Stop Valves)
- e. Electro-Hydraulic Control System
- f. Electrical Distribution

2.3.4 EVENT DISPOSITION

Two cases are analyzed. For Mode 1, the limiting event is a 10% increase in steam load initiated from full power. This event is mitigated by reactor and turbine trip. For Mode 3, the limiting event is a rapid opening of both the atmospheric dump turbine bypass valves resulting in a steam flow equal to 41% of full rated load. The event sequence is not included in the FSAR.

2.3.5 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.3: INCREASE IN STEAM FLOW (Mode 1)

The Critical Design Characteristics for the Increase in Steam Flow Event, Mode 1, are presented below.

2.3.5.1 REACTIVITY CONTROL CSF

Functional/System CDCs - Insert control rods.
Reference: FSAR Table 14.1.3-3

2.3.5.2 FUEL INTEGRITY & CORE HEAT REMOVAL CSF

Functional/System CDCs - Included with RCSHR CSF.

2.3.5.3 RCS HEAT REMOVAL CSF

Functional/System CDCs - Trip turbine to reduce the steaming rate.
Reference: FSAR Table 14.1.3-3

2.3.5.4 RCS PRESSURE & INVENTORY CONTROL

Functional/System CDCs - Identify from event detailed analyses, if applicable

2.3.5.5 CONTAINMENT INTEGRITY & RADIATION CONTROL CSF

Functional/System CDCs - N/A for this event.

2.3.5.6 ELECTRICAL POWER CSF

Functional/System CDCs - Transfer loads to offsite power source.

2.3.5.7 ESSENTIAL SUPPORT SYSTEMS CSF

Functional/System CDCs - N/A for this event.

2.3.5.8 ENVIRONMENTAL CONTROL CSF

Functional/System CDCs - N/A for this event

2.3.6 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.3: INCREASE IN STEAM FLOW (Mode 3)

The Critical Design Characteristics for the Increase in Steam Flow Event, Mode 3, are presented below.

2.3.6.1 REACTIVITY CONTROL CSF

Functional/System CDCs - Identify from event detailed analyses

2.3.6.2 FUEL INTEGRITY & CORE HEAT REMOVAL CSF

Functional/System CDCs - Included with RCSR CSF.

2.3.6.3 RCS HEAT REMOVAL CSF

Functional/System CDC - Steam flow limited to 41%
Reference: FSAR Section 14.1.3.6

2.3.6.4 RCS PRESSURE & INVENTORY CONTROL

Functional/System CDCs - Identify from event detailed analyses, if applicable

2.3.6.5 CONTAINMENT INTEGRITY & RADIATION CONTROL CSF

Functional/System CDCs - N/A for this event.

2.3.6.6 ELECTRICAL POWER CSF

Functional/System CDCs - Plant loads power from offsite power source which is maintained through out event. No additional functional/system CDCs.

2.3.6.7 ESSENTIAL SUPPORT SYSTEMS CSF

Functional/System CDCs - N/A for this event.

2.3.6.8 ENVIRONMENTAL CONTROL CSF

Functional/System CDCs - N/A for this event

2.4 INADVERTENT OPENING OF A STEAM GENERATOR RELIEF OR SAFETY VALVE

2.4.1 EVENT DESCRIPTION

This event is initiated by an increase in steam flow caused by the inadvertent opening of a secondary side safety or relief valve. The inadvertent opening of a steam generator safety valve would result in an increased steam flow of approximately 6.75% of full rated steam flow. This event is bounded by event 14.1.3, which analyzes steam flow increases of 10% and greater. See discussion in section 1.3 above.

2.4.2 DESIGN BASIS

N/A - Bounded by event 14.1.3 (Relief valve capacity <10% full rated flow)

2.4.3 SYSTEM INTERFACE

N/A - Bounded by event 14.1.3

2.4.4 EVENT DISPOSITION

This event is bounded by the Increase in Steam Flow Event discussed in FSAR Section 14.1.3, and thus is not analyzed. However, a functional/system level critical characteristic is appropriate. That is, to validate that the steam generator relief valve capacity is less than the 10% assumed in the event 14.1.3 analysis.

2.4.5 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.4: INADVERTENT OPENING OF A STEAM GENERATOR RELIEF OR SAFETY VALVE

The Critical Design Characteristics for the Inadvertent Opening of a Steam Generator Relief or Safety Valve Event are presented below.

2.4.5.1 RCS HEAT REMOVAL CSF

Functional/System CDCs - Steam generator relief valve capacity is limited to 10% of full rated steam flow. Reference: FSAR sections 14.1.4.4 and 14.1.3.6.

2.4.5.2 Functional/System CDCs do not apply for the other 7 critical safety functions.

2.5 MAIN STEAM LINE BREAK (MSLB) ACCIDENT, RCS ANALYSIS

2.5.1 EVENT DESCRIPTION

This event is initiated by a rupture in the main steam piping upstream of the MSIVs which results in an uncontrolled steam release from the secondary system. The increase in energy removal through the secondary system results in severe overcooling of the primary system. In the presence of a negative Moderator Temperature Coefficient (MTC), this cooldown causes a decrease in the shutdown margin (following reactor trip) such that a return to power might be possible following a steam line rupture assuming that the most reactive control rod is stuck in its fully withdrawn position. The MNPS-2 limiting MSLB from a safety standpoint is a Hot Zero Power (HZP) double-ended guillotine break inside containment between the steam generator and the flow restrictors. The MNPS-2 MSLB-RCS analysis is described in FSAR Section 14.1.5.

2.5.2 DESIGN BASIS

The MNPS-2 MSLB-RCS analysis is based on the following primary assumptions:

- a. Most reactive control rod is stuck in its fully withdrawn position.
Reference: FSAR Section 14.1.5.1.1
- b. Single failure criteria for LOOP are loss of one HPSI pump and one charging pump.
Reference: FSAR Section 14.1.5.5.1.3, and Table 14.1.5-3.
- c. Single failure criteria for LOOP are loss of one diesel generator, resulting in the loss of one HPSI pump and one charging pump.
Reference: FSAR Section 14.1.5.4, 14.1.5.5.1.3, and Table 14.1.5-3
- d. Safety injection actuation signal (SIAS) actuated by low pressurizer pressure.
- e. Secondary isolation signal (MSI) actuated by low steam pressure.

2.5.3 SYSTEM INTERFACE

The following systems interface during the postulated MSLB-RCS recovery analysis:

- a. Reactor Protection System
- b. Control Element Drive
- c. Reactor Coolant System
- d. Turbine
- e. Electro-Hydraulic Control
- f. Main Steam
- g. Main Feedwater System (hot full power case)
- h. Auxiliary Feedwater
- i. Chemical & Volume Control System
- j. High Pressure Safety Injection
- k. Electrical Distribution
- l. Emergency Power System (loss of offsite power case)

2.5.4 EVENT DISPOSITION

The limiting break is a double-ended guillotine break inside containment between SG and flow restrictors. Two modes are analyzed. For mode 2, the limiting case is with the reactor just critical.

The mode 2 analysis is performed with offsite power available and also concurrent with a loss of offsite power. For mode 1, the limiting case is with the reactor at full rated power. The mode 1 analysis is performed with offsite power available and also concurrent with a loss of offsite power.

2.5.5 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.5.6.1: MSLB @ HZP

The Critical Design Characteristics for the MSLB Event @ HZP, with offsite power available, are presented below.

2.5.5.1 REACTIVITY CONTROL CSF

Functional/System CDC - Insert control rods within 3.9 seconds of reaching reactor trip setpoint.
Reference: FSAR Table 14.1.5-4

Functional/System CDC - Inject boron to limit peak power.
Reference: FSAR Table 14.1.5-7

Note: HPSI and charging pump actuation times included under RCS Pressure & Inventory CSF.

Functional/System CDC - Inject boron to achieve core subcritical condition beyond 600 seconds.
Reference: FSAR Table 14.1.5-7

2.5.5.2 FUEL INTEGRITY & CORE HEAT REMOVAL CSF - Functional/System CDCs included in 2.5.5.3 and 2.5.5.4 below.

2.5.5.3 RCS HEAT REMOVAL CSF

Functional/System CDC - Close MSIV on intact main steam line to limit cooldown from non-affected steam generator blowdown. Reference: FSAR Table 14.1.5-7

Functional/System CDC - Limit AFW flow to affected steam generator for first 180 seconds of event.
Reference: FSAR Section 14.1.5.5.1.4

Functional/System CDC - Isolate AFW flow to affected steam generator at 600 seconds.
Reference: FSAR Table 14.1.5-7

2.5.5.4 RCS PRESSURE & INVENTORY CONTROL CSF

Functional/System CDC - Initiate HPSI flow per design basis HPSI pump head curve.
Reference: FSAR Table 14.1.5-7

Functional/System CDC - initiate charging flow per design basis pump capacity.
Reference FSAR Table 14.1.5-7

2.5.5.5 CONTAINMENT INTEGRITY & RADIATION CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.5.6 ELECTRICAL POWER CSF - Plant loads power from offsite power source which is maintained through out event. No additional functional/system CDCs.

2.5.5.7 ESSENTIAL SUPPORT SYSTEMS CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.5.8 ENVIRONMENTAL CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.6 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.5.6.2: MSLB @ HZP w/LOOP

The Critical Design Characteristics for the MSLB Event @ HZP, with a loss of offsite power, are presented below.

2.5.6.1 REACTIVITY CONTROL CSF

Functional/System CDC - (Similar to event 14.1.5.6.1) Insert control rods within 3.9 seconds of reaching reactor trip setpoint.

Reference: FSAR Table 14.1.5-4

Functional/System CDC - (Similar to event 14.1.5.6.1) Inject boron to limit peak power.

Reference: FSAR Table 14.1.5-8

Functional/System CDC - (Similar to event 14.1.5.6.1) Inject boron to achieve core subcritical condition beyond 600 seconds.

Reference: FSAR Table 14.1.5-8

2.5.6.2 FUEL INTEGRITY & CORE HEAT REMOVAL CSF - Functional/System CDCs included in 2.5.6.3 and 2.5.6.4 below.

2.5.6.3 RCS HEAT REMOVAL CSF

Functional/System CDC - (Similar to event 14.1.5.6.1) Close MSIV on intact main steam line to limit cooldown from non-affected steam generator blowdown. Reference: FSAR Table 14.1.5-8

Functional/System CDC - Limit AFW flow to affected steam generator for first 180 seconds of event. Reference: FSAR Section 14.1.5.5.1.4

Functional/System CDC - Isolate AFW flow to affected steam generator at 600 seconds. Reference: FSAR Table 14.1.5-7

2.5.6.4 RCS PRESSURE & INVENTORY CONTROL CSF

Functional/System CDC - (Similar to event 14.1.5.6.1) Initiate HPSI flow per design basis HPSI pump head curve.

Reference: FSAR Table 14.1.5-8

Functional/System CDC - (Similar to event 14.1.5.6.1) initiate charging flow per design basis pump capacity.

Reference FSAR Table 14.1.5-8

2.5.6.5 CONTAINMENT INTEGRITY & RADIATION CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.6.6 ELECTRICAL POWER CSF

Functional/System CDC - Diesel Generator start and load to supply power to HPSI, charging, and AFW pumps.

2.5.6.7 ESSENTIAL SUPPORT SYSTEMS CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.6.8 ENVIRONMENTAL CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.7 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.5.6.3: MSLB @ HFP

The Critical Design Characteristics for the MSLB Event @ HFP, with offsite power available, are presented below.

2.5.7.1 REACTIVITY CONTROL CSF

Functional/System CDC - (Similar to Event 14.1.5.6.1) Insert control rods within 3.9 seconds of reaching reactor trip setpoint.

Reference: FSAR Table 14.1.5-4

Functional/System CDC - Inject boron to limit peak power.

Reference: FSAR Table 14.1.5-9

Note: HPSI and charging pump actuation times included under RCS Pressure & Inventory CSF.

Functional/System CDC - Inject boron to achieve core subcritical condition beyond 600 seconds.

Reference: FSAR Table 14.1.5-9

2.5.7.2 FUEL INTEGRITY & CORE HEAT REMOVAL CSF - Functional/System CDCs included in 2.5.7.3 and 2.5.7.4 below.

2.5.7.3 RCS HEAT REMOVAL CSF

Functional/System CDC - (Similar to Event 14.1.5.6.1) Close MSIV on intact main steam line to limit cooldown from non-affected steam generator blowdown. Reference: FSAR Table 14.1.5-9

Functional/System CDC - FW flow limited to that allowed by secondary pressure decrease for the first 30 seconds of the event.

Reference: FSAR Section 14.1.5.5.1.4

Functional/System CDC - Isolate FW flow 30 seconds after the reactor trip.

Functional/System CDC - (Similar to Event 14.1.5.6.1) AFW flow initiated at runout value at t=180 sec.

Reference: FSAR Section 14.1.5.5.1.4

Functional/System CDC - (Similar to Event 14.1.5.6.1) Isolate AFW flow to affected steam generator at 600 seconds.

Reference: FSAR Table 14.1.5-9

2.5.7.4 RCS PRESSURE & INVENTORY CONTROL CSF

Functional/System CDC - (Similar to Event 14.1.5.6.1) Initiate HPSI flow per design basis HPSI pump head curve.

Reference: FSAR Table 14.1.5-9

Functional/System CDC - (Similar to Event 14.1.5.6.1) initiate charging flow per design basis pump capacity.

Reference FSAR Table 14.1.5-9

2.5.7.5 CONTAINMENT INTEGRITY & RADIATION CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.7.6 ELECTRICAL POWER CSF

Functional/System CDC - Transfer loads to offsite power source.

2.5.7.7 ESSENTIAL SUPPORT SYSTEMS CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.7.8 ENVIRONMENTAL CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.8 FUNCTIONAL/SYSTEM CDCs - EVENT 14.1.5.6.4: MSLB @ HFP w/LOOP

The Critical Design Characteristics for the MSLB Event @ HFP, with a loss of offsite power, are presented below.

2.5.8.1 REACTIVITY CONTROL CSF

Functional/System CDC - (Similar to Event 14.1.5.6.1) Insert control rods within 3.9 seconds of reaching reactor trip setpoint.

Reference: FSAR Table 14.1.5-4

Functional/System CDC - Inject boron to limit peak power.

Reference: FSAR Table 14.1.5-10

Note: HPSI and charging pump actuation times included under RCS Pressure & Inventory CSF.

Functional/System CDC - Inject boron to achieve core subcritical condition beyond 600 seconds.

Reference: FSAR Table 14.1.5-10

2.5.8.2 FUEL INTEGRITY & CORE HEAT REMOVAL CSF - Functional/System CDCs included in 2.5.8.3 and 2.5.8.4 below.

2.5.8.3 RCS HEAT REMOVAL CSF

Functional/System CDC - (Similar to Event 14.1.5.6.1) Close MSIV on intact main steam line to limit cooldown from non-affected steam generator blowdown. Reference: FSAR Table 14.1.5-10

Functional/System CDC - FW flow limited to that allowed by secondary pressure decrease for the first 30 seconds of the event.

Reference: FSAR Section 14.1.5.5.1.4

Functional/System CDC - Isolate FW flow 30 seconds after the reactor trip.

Functional/System CDC - (Similar to Event 14.1.5.6.1) AFW flow initiated at runout value at t=180 sec.

Reference: FSAR Section 14.1.5.5.1.4

Functional/System CDC - (Similar to Event 14.1.5.6.1) Isolate AFW flow to affected steam generator at 600 seconds.

Reference: FSAR Table 14.1.5-10

2.5.8.4 RCS PRESSURE & INVENTORY CONTROL CSF

Functional/System CDC - (Similar to Event 14.1.5.6.1) Initiate HPSI flow per design basis HPSI pump head curve.

Reference: FSAR Table 14.1.5-10

Functional/System CDC - (Similar to Event 14.1.5.6.1) initiate charging flow per design basis pump capacity.

Reference FSAR Table 14.1.5-10

2.5.8.5 CONTAINMENT INTEGRITY & RADIATION CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.8.6 ELECTRICAL POWER CSF

Functional/System CDC - (Similar to Event 14.1.5.6.2) Diesel Generator start and load to supply power to HPSI, charging, and AFW pumps.

2.5.8.7 ESSENTIAL SUPPORT SYSTEMS CSF - RCS analysis only. No applicable functional/system CDCs.

2.5.8.8 ENVIRONMENTAL CONTROL CSF - RCS analysis only. No applicable functional/system CDCs.

PARSONS POWER

Critical Safety Function Diagrams

Millstone Unit 2

TABLE OF CONTENTS

1. Definitions

2. Diagrams

- REACTIVITY CONTROL
- FUEL INTEGRITY & CORE HEAT REMOVAL
- RCS HEAT REMOVAL
- RCS PRESSURE & INVENTORY CONTROL

ATTACHMENT 2
CRITICAL SAFETY FUNCTIONS

1. REACTIVITY CONTROL

Trip the reactor and maintain the reactor core shutdown margin within Technical Specification Limits.

2. FUEL INTEGRITY & CORE HEAT REMOVAL

Maintain core cooling to prevent fuel cladding failure and release of fission products to the reactor coolant system. The core should remain covered and reactor coolant subcooling margin maintained > 30 degF.

3. RCS HEAT REMOVAL

Utilize the steam generators as an RCS heat sink. $Q_{rx} = Q_{sg} = U_{sg} A_{sg} (T_{ave} - T_{sat})$

Deliver reactor core heat output (Q_{rx}) to the steam generators via forced flow or natural circulation. Maintain steam generator water level to provide sufficient wetted tube area (A_{sg}) for primary to secondary heat transfer.

Control steam generator pressure (and thereby T_{sat}) to maintain the steam generator as an RCS heat sink.

Control steam generator pressure to control RCS temperature (T_{ave}) and its rate/direction of change.

4. RCS PRESSURE & INVENTORY CONTROL

Maintain RCS pressure within the limits of EOP Figure 3.2 (RCS Pressure/Temperature Limits) for the given RCS temperature by use of a pressurizer steam bubble (preferred method) or emergency injection system throttling and CVCS/relief valve operation.

Maintain RCS inventory sufficient to ensure core heat removal and primary to secondary heat transfer.

5. CONTAINMENT INTEGRITY & RADIATION CONTROL

Maintain the integrity of the reactor building as a fission product boundary. For LOCA and steam generator tube rupture events, limit fission product release to maintain exposure within 10CFR100 limits.

Maintain Reactor Building environmental conditions (temperature, pressure, and combustible gas concentrations) within the RB design basis.

Isolate non-accident mitigation process lines penetrating the containment structure. Maintain isolation capability for process lines required for accident mitigation.

Provide penetration cooling.

Maintain the integrity of electrical penetrations.

Maintain the integrity of access hatches and their sealing function.

6. ELECTRICAL POWER

Provide electric power to equipment required to achieve and maintain safe shutdown

7. ESSENTIAL SUPPORT SYSTEMS

Maintain the operability of cooling water systems essential to the proper operation of safe shutdown systems. (Component-specific systems are included with the safety function provided by that system.)

8. ENVIRONMENTAL CONTROL

Maintain acceptable environmental conditions (temperature and radiation level) in plant areas requiring personnel access to achieve a safe shutdown condition. Provide ventilation and cooling to vital equipment.

REACTOR PROTECTION SYSTEM
R, REGULATING

CONTROL RODS

WITHDRAW
INSERT

INSERT CONTROL RODS

STEAM GENERATOR PRESSURE CONTROL

STEAM GENERATOR LEVEL CONTROL

RCS INVENTOR CONTROL

CVCS CHARGING

TRD

REACTIVITY MTC-TRANSIENT



REACTIVITY MTC-COOLDOWN (LONG TERM)

REACTIVITY FUEL

REACTIVITY POWER DOPPLER

REACTIVITY MODERATOR TEMPERATURE COEFFICIENT

REACTIVITY CONTROL



SIAS


T-8 A,B
T-9 A,B
CH-510, 511
CH-512
CH-508, 509
CH-514

INITIATE
CONTROL

PHOSPHORIC ACID
ADDITION


ANSTEC APERTURE CARD

Also Available on
Aperture Card

 PARSONS <small>PARSONS POWER GROUP INC. BOSTON / BOSTON / CHARLOTTE / DALLAS</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2CSFD-REACT	REV.
REACTIVITY CONTROL			
<i>A.T. Glawanski</i> 7/18/97	<i>J.H. DeLoe</i> 7/18/97	<i>M. J. Okin</i> 7/18/97	
ORIGINATED DATE	REVIEWED DATE	APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	


PPGI-FILE: 526005:reactcon.dgn
PPGI-DATE: 18-Jul-97 12:36

9707220037-01




ANSTEC APERTURE CARD

Also Available on
Aperture Card

 PARSONS <small>PARSONS POWER GROUP INC. MEMPHIS / BOSTON / CHARLOTTE / CHATTANOOGA</small>	536852-00085 WORK ORDER NO.	TIER 2 FIGURE #M2-T2CSFD-FICHR	0 REV.
FUEL INTEGRITY AND CORE HEAT REMOVAL			
<i>R.T. Slavianski</i> 7/18/97 ORIGINATED DATE	<i>J.H. Smith</i> 7/18/97 REVIEWED DATE	<i>R.B. Olin</i> 7/18/97 APPROVED DATE	
N/A INTERFACE DATE	N/A INTERFACE DATE	N/A INTERFACE DATE	

PPGI-FILE: 526005:fuelintg.dgn
 PPGI-DATE: 18-Jul-97 12:19

9707220037-02



REACTOR OPERATOR

TURBINE PROTECTION AND CONTROL

2-P-40 1A-D

RCS INVENTORY CONTROL

STEAM GENERATOR PRESSURE CONTROL

STEAM GENERATOR LEVEL CONTROL

2-MS-6B 1A-D
2-MS-6I 1A-D
2-MS-2 M.C.

2-MS-(239-254)

START

STOP

INITIATE

CONTROL

CONTROL

ISOLATE

LIFT

RESET

REACTOR COOLANT PUMP OPERATION

REACTOR COOLANT NATURAL CIRCULATION FLOW

TURBINE GENERATOR OPERATION

STEAM GENERATOR OVER PRESSURE PROTECTION

REACTOR COOLANT FLOW TO STEAM GENERATORS

HEAT
PRIMARY
HEAT

STEAM GENERATOR PRESSURE
RCS TAVE
FAST OPEN CIRCUIT

STEAM GENERATOR PRESSURE
MAIN STEAM ISOLATION

FEED WATER REGULATING SYSTEM
MAIN STEAM ISOLATION
CLASS
HIGH RAD

AUXILIARY FEED WATER INITIATE
STEAM GENERATOR LEVEL

ANSTEC APERTURE CARD

Also Available on Aperture Card

2-MS-1206-209

2-MS-198 A,B

2-P-1 A,B
2-FW-8 A,B
2-FW-51 A,B
2-FW-41 A,B
2-FW-42 A,B
2-FW-38 A,B
2-P-2 A,B,C
2-X8 A,B
2-MS-191 A,B
2-MS-220 A,B

2-P-4
2-P-9 A,B
2-FW-12 A,B
2-FW-43 A,B
2-T-40

INITIATE
CONTROL
ISOLATE

INITIATE
CONTROL
ISOLATE

CONTROL
ISOLATE

INITIATE
CONTROL
ISOLATE


STEAM BYPASS TO CONDENSER
(PREFERRED PATH)

STEAM DUMP TO ATMOSPHERE
(ALTERNATE PATH)

MAIN FEED WATER OPERATION


AUXILIARY FEED WATER OPERATION


STEAM GENERATOR LEVEL CONTROL

 PARSONS <small>PARSONS POWER GROUP INC. HEAVY / DESIGN / CONSTRUCTION / MAINTENANCE</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2CSFD-RCSHR	REV.
RCS HEAT REMOVAL			
<i>R. T. Mariano</i> 7/18/97	<i>J. H. B...</i> 7/18/97	<i>[Signature]</i> 7/18/97	
ORIGINATED DATE	REVIEWED DATE	APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	

PPGI-FILE: 526005r:rcshtr:em.dgn
 PPGI-DATE: 18-Jul-97 12:27

9707220037-03





**ANSTEC
APERTURE
CARD**

Also Available on
Aperture Card

RCS
PRESSURE & INVENTORY
CONTROL

PARSONS <small>PARSONS POWER GROUP INC. HEADQUARTERS / 80075 / CHARLOTTE / NORTH CAROLINA</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2CSFD-RCSPI	REV.
RCS PRESSURE & INVENTORY CONTROL			
<i>A.T. Slavov</i> 7/18/97 ORIGINATED DATE	<i>J.H. Buehler</i> 7/18/97 REVIEWED DATE	<i>M. J. Ok</i> 7/18/97 APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	

9707220037-04


PPGI-FILE: 526005:r:cspr:inc.dgn
 PPGI-DATE: 18-Jul-97 12:28

PARSONS POWER

System Boundary Diagrams


Overcooling Events

Millstone Unit 2



1B
(M)
7B
7BA
ATOR
PIJMP
7A
SJA
A
TO
MSR 1A

STOP CONTROL



- LEGEND:**
- * - RPS SIGNAL
 - ⏏ - MSI CLOSE/STOP
 - - CIAS CLOSE/STOP
 - ☛ - HIGH RAD CLOSE/STOP
 - ⊕ - TURBINE TRIP
 - - TRAIN 'A' OR COMMON FLOW PATH

ANSTEC APERTURE CARD

Also Available on Aperture Card


- NOTES:**
1. VALVE OPENS ON MANUAL DEMAND SIGNAL.

- REFERENCES:**
- DWG. 25203-26002, SH.1, REV. 36
 - DWG. 25203-26002, SH.2, REV. 21
 - DWG. 25203-26002, SH.3, REV. 23
 - DWG. 25203-26002, SH.4, REV. 16
 - DWG. 25203-26002, SH.5, REV. 6

PARSONS <small>PARSONS POWER GROUP INC. HEADING / BOSTON / DANVILLE / DAYTON/MSA</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-MS1	REV.
MAIN STEAM			
<i>200</i> ORIGINATED DATE N/A INTERFACE DATE	<i>RS Farret</i> REVIEWED DATE N/A INTERFACE DATE	<i>P.T. ...</i> APPROVED DATE N/A INTERFACE DATE	7/18/97 APPROVED DATE N/A INTERFACE DATE

PPGI-FILE: 526005mainstem.dgn
 PPGI-1 ATE: 18-Jul-97 12:24

9207220037-05



B
M
A
TOR
PUMP
A
IAE
TO
R IA

STOP CONTROL

LEGEND:

- * - RPS SIGNAL
- ⬇ - MSI CLOSE/STOP
- - CIAS CLOSE/STOP
- ☼ - HIGH RAD CLOSE/STOP
- ⊗ - TURBINE TRIP
- - TRAIN 'A' OR COMMON FLOW PATH

ANSTEC APERTURE CARD


Also Available on Aperture Card

NOTES:

1. VALVE OPENS ON MANUAL DEMAND SIGNAL.

REFERENCES:


- DWG. 25203-26002, SH.1, REV. 36
- DWG. 25203-26002, SH.2, REV. 21
- DWG. 25203-26002, SH.3, REV. 23
- DWG. 25203-26002, SH.4, REV. 16
- DWG. 25203-26002, SH.5, REV. 6



<p>PARSONS PARSONS POWER GROUP INC. MEMPHIS / BOSTON / CHARLOTTE / DAYTON/OHIO</p>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-MS2	REV.
<p>MAIN STEAM HOT ZERO POWER ALIGNMENT</p>			
<p><i>[Signature]</i> 7/18/97</p> <p>ORIGINATED DATE</p> <p>N/A</p> <p>INTERFACE DATE</p>	<p><i>[Signature]</i> 7/18/97</p> <p>REVIEWED DATE</p> <p>N/A</p> <p>INTERFACE DATE</p>	<p><i>[Signature]</i> 7/18/97</p> <p>APPROVED DATE</p> <p>N/A</p> <p>INTERFACE DATE</p>	

PPGI-FILE: 526095:mainstem.dgn
 PPGI-DATE: 18-Jul-97 12:24


9707220037-06



LEGEND:

☐ - MSI CLOSE/STOP

— - TRAIN 'A' OR COMMON FLOW PATH



ANSTEC APERTURE CARD

Also Available on Aperture Card

NOTES:


REFERENCES:

- 25203-26005 SH1 REV 21
- 25203-26005 SH2 REV 30

PARSONS PARSONS POWER GROUP INC. <small>BLACK - BOSTON / CHARLOTTE / CHATTANOOGA</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-MFWI	REV.
MAIN FEED			
<i>[Signature]</i> 7/14/97	<i>[Signature]</i> 7/18/97	<i>[Signature]</i> 7/18/97	
ORIGINATED DATE	REVIEWED DATE	APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	

PPGI-FILE: 526005:mainfeed.dgn
 PPGI-DATE: 18-Jul-97 12:23

9707220037-07




LEGEND:

☑ - MSI CLOSE/STOP

— - TRAIN 'A' OR COMMON FLOW PATH

ANSTEC APERTURE CARD

Also Available on Aperture Card



NOTES:

REFERENCES:


25203-26005 SH1 REV 21

25203-26005 SH2 REV 30

<p>PARSONS PARSONS POWER GROUP INC. REACTOR / BISTOR / QUALITY / ON-TIME</p>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-MFW2	REV.
<p>MAIN FEED HOT ZERO POWER ALIGNMENT</p>			
<p><i>[Signature]</i> 7/10/97</p> <p>ORIGINATED DATE</p>	<p><i>[Signature]</i> 7/18/97</p> <p>REVIEWED DATE</p>	<p><i>[Signature]</i> 7/18/97</p> <p>APPROVED DATE</p>	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	

PPGI-FILE: 526005:mainfeed.dgn
 PPGI-DATE: 18-Jul-97 12:23

9707220037-08



LEGEND:

☆ - AUXILIARY FEED INITIATE SIGNAL OPEN

— - TRAIN 'A' OR COMMON FLOW PATH



ANSTEC APERTURE CARD


Also Available on
Aperture Card

NOTES:


REFERENCES:

- 25203-26002, SH.1, REV. 36
- 25203-26005, SH.2, REV. 30
- 25203-26005, SH.3, REV. 28



 PARSONS <small>PARSONS POWER GROUP INC. MEMPHIS / BOSTON / CHARLOTTE / CHATTANOOGA</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBO-AFW1	REV.
AUXILIARY FEEDWATER			
<i>RC</i> 7/18/97	<i>R. Faust</i> 7/18/97	<i>A.T. Glavin</i> 7/18/97	
ORIGINATED DATE	REVIEWED DATE	APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	


9207220037-09



LEGEND:

☆ - AUXILIARY FEED INITIATE SIGNAL OPEN


— - TRAIN 'A' OR COMMON FLOW PATH



**ANSTEC
APERTURE
CARD**

**Also Available on
Aperture Card**

NOTES:




REFERENCES:

25203-26002, SH.1, REV. 36


25203-26005, SH.2, REV. 30

25203-26005, SH.3, REV. 28

 PARSONS <small>PARSONS POWER GROUP INC. HEADQUARTERS / BOSTON / CHARLOTTE / CHATTANOOGA</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-AFW2	REV.
AUXILIARY FEEDWATER HOT ZERO POWER ALIGNMENT			
<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>	
ORIGINATED DATE	REVIEWED DATE	APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	

PPG1-FILE: 526005:auxwater.dgn
PPG1-DATE: 18-Jul-97 12:16

9707220057-10



ANSTEC APERTURE CARD

Also Available on
Aperture Card

LEGEND:

- ▲ - SIAS CLOSE/STOP
- △ - SIAS OPEN/START
- - CIAS CLOSE/STOP
- - TRAIN 'A' OR COMMON FLOW PATH

NOTES:


1. VALVES OPEN ON LOW VCT LEVEL.
2. VALVE CLOSES ON LOW VCT LEVEL.
3. VALVE OPERATES ON PZR LEVEL CONTROL.
4. VALVE OPERATES ON PRESSURE CONTROL.

RE-GEN
HEAT
EXCHANGER

▲ ●
2-CH-516


REFERENCES:

- 25203-26014.SH.1, REV.17
- 25203-26015.SH.2, REV.10
- 25203-26017.SH.1, REV.20
- 25203-26017.SH.3, REV.15
- 25203-26030.SH.1, REV.26

 PARSONS <small>PARSONS POWER GROUP INC. BOSTON / NEWTON / CHARLOTTE / DAYTON</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-CVCSI	REV.
C.V.C.S.			
<i>[Signature]</i> 7/15/97 <small>ORIGINATED DATE</small>	<i>[Signature]</i> 7/18/97 <small>REVIEWED DATE</small>	<i>[Signature]</i> 7/18/97 <small>APPROVED DATE</small>	
N/A	N/A	N/A	
<small>INTERFACE DATE</small>	<small>INTERFACE DATE</small>	<small>INTERFACE DATE</small>	

PPGI-FILE: 526005:cvcs.dgn
 PPGI-DATE: 18-Jul-97 12:17

9707220037-11



LEGEND:

- ▲ - SIAS CLOSE/STOP
- △ - SIAS OPEN/START
- - CIAS CLOSE/STOP
- - SRAS CLOSE/STOP
- - SRAS OPEN/START
- ▬ - TRAIN 'A' OR COMMON FLOW PATH

ANSTEC APERTURE CARD


Also Available on Aperture Card

NOTES:

ALL COMPONENT ID'S PRECEDED BY '2-' UNLESS OTHERWISE NOTED

REFERENCES:


- 25203-26015 SHT 2 REV 10
- 25203-26015 SHT 1 REV 13
- 25203-26017 SHT 3 REV 15
- 25203-26014 SHT 1 REV 17



PARSONS <small>PARSONS POWER GROUP INC. MADE IN BRITAIN • DUBLIN • DALLAS</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T25BD-HPSII	REV.
H.P.S.I.			
<i>[Signature]</i> ORIGINATED DATE	<i>RS Faust</i> 7/18/97 REVIEWED DATE	<i>[Signature]</i> 7/18/97 APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	

PPGI-FILE: 526005:hpsi.dgn
 PPGI-DATE: 18-Jul-97 12:20

9707220037-12



LEGEND:

- - SIAS CLOSE/STOP
- ▲ - CIAS CLOSE/STOP
- - TRAIN 'A' OR COMMON FLOW PATH

APERTURE CARD

Also Available on Aperture Card


NOTES:

1. PZR PRESSURE CONTROL.

REFERENCES:


- 25203-26014 SHT 2 REV 13
- 25203-26014 SHT 1 REV 17
- 25203-26017 SHT 2 REV 17
- 25203-26017 SHT 1 REV 20

JENCH
TANK
T38

 PARSONS <small>PARSONS POWER GROUP INC. HOUSTON / BOSTON / CHARLOTTE / CHATTANOOGA</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-RCS1	REV.
RCS			
<i>[Signature]</i> 7/14/97 <small>ORIGINATED DATE</small>	<i>[Signature]</i> 7/18/97 <small>REVIEWED DATE</small>	<i>[Signature]</i> 7/18/97 <small>APPROVED DATE</small>	
N/A	N/A	N/A	
<small>INTERFACE DATE</small>	<small>INTERFACE DATE</small>	<small>INTERFACE DATE</small>	

PPGI-FILE: 526005:r.cs.dgn
PPGI-DATE: 18-Jul-97 12:25

9707220037-13



LEGEND:

- - SIAS CLOSE/STOP
- ▲ - CIAS CLOSE/STOP
- - TRAIN 'A' OR COMMON FLOW PATH

APERTURE CARD

Also Available on Aperture Card


NOTES:

1. PZR PRESSURE CONTROL.

REFERENCES:

- 25203-26014 SHT 2 REV 13
- 25203-26014 SHT 1 REV 17
- 25203-26017 SHT 2 REV 17
- 25203-26017 SHT 1 REV 20

QUENCH TANK T38

 PARSONS <small>PARSONS POWER GROUP INC. HOUSTON / BOSTON / DANVILLE / DAYTON/OREGON</small>	536852-00085	TIER 2	0
	WORK ORDER NO.	FIGURE #M2-T2SBD-RCS1	REV.
RCS			
<i>[Signature]</i> 7/14/97	<i>[Signature]</i> 7/18/97	<i>[Signature]</i> 7/18/97	
ORIGINATED DATE	REVIEWED DATE	APPROVED DATE	
N/A	N/A	N/A	
INTERFACE DATE	INTERFACE DATE	INTERFACE DATE	

9707220037-13

PPGI-FILE: 526005:r:cs.dgn
PPGI-DATE: 18-Jul-97 12:25