

DUKE POWER COMPANY

P.O. BOX 33180

CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

January 12, 1988

Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW
Suite 2900
Atlanta, Georgia 30323

Subject: Duke Power Company
Oconee Nuclear Station
Docket Nos. 50-269, - 270, - 287

McGuire Nuclear Station
Docket Nos. 50-369, -370

Catawba Nuclear Station
Docket Nos. 50-413, -414
Response to NRC Compliance
Bulletin No. 87-02

Attached is a partial Duke Power response to NRC Compliance Bulletin No. 87-02, "Fastener Testing to Determine Conformance with Applicable Material Specifications." Included as attachments to this letter is the following information required by the bulletin.

| | |
|--------------|---|
| Attachment A | Description of the Duke Power Procurement and Receipt Inspection Program for Fasteners |
| Attachment B | Description of the Duke Power Controls Used During Storage and Issuance From Stock to Assure the Appropriate Use of Fasteners |
| Attachment C | Method for Choosing the Fasteners to be Tested |
| Attachment D | Status and Schedule of the Evaluation of Fastener Testing Results |

TELL
11


Dr. J. Nelson Grace
Page #2
January 12, 1988

At this time, we are unable to submit the test results and the evaluation thereof. This is because 1) we were unable to complete the overall workload required by this bulletin within the 60-day time allotment; 2) the time required to interface with vendor testing laboratories; and 3) the performance of Charpy Impact Testing on some samples. This latter item, although not specifically required by Compliance Bulletin 87-02, was requested by the NRC Resident Inspectors based upon interpretation of the NRC Temporary Instruction 2500/26 covering the bulletin.

Presently we have completed the mechanical and chemical testing of all samples (except the additional impact testing of the required samples). The status and schedule of the evaluation of the test results is detailed in Attachment D.

I declare under penalty of perjury that the statements set forth herein are true and correct to the best of my knowledge.

Very truly yours,



Hal B. Tucker

HBT/JSW/lcc

Original Letter and Copy of Attachments:

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

xc: (w/Attachments):

NRC Resident Inspector
Oconee Nuclear Station

NRC Resident Inspector
McGuire Nuclear Station

NRC Resident Inspection
Catawba Nuclear Station

Duke Power Company
Response to NRC Compliance Bulletin 87-02
"Description of the Duke Power Procurement
and Receipt Inspection Program for Fasteners"

INTRODUCTION

The Quality Assurance Procurement Program is based on the following:

- a) Review of requisitions and purchase orders by QA personnel
- b) QA Vendor audits and surveillances of suppliers
- c) Duke QA releases required prior to shipment
- d) Review of vendor documentation by QA Vendors
- e) Receiving inspection by site QA

QA REVIEW OF REQUISITIONS AND PURCHASE ORDERS

All QA Condition purchase orders and requisitions are reviewed by Quality Assurance personnel to assure the appropriate documentation requirements are specified on the purchase orders.

QA VENDOR AUDITS AND SURVEILLANCES

During audit/surveillance activities, Duke representatives verify that the vendor has applied applicable sections of their approved quality program to the materials being purchased. examples of audit and surveillance activities are:

- a) Reviewing Certified Material Test Reports (CMTR's); comparison to ASME Code Section II requirements as applicable.
- b) Reviewing heat treat records.
- c) Performing dimensional verification.
- d) Reviewing audit reports, inspection reports, Nondestructive Examination (NDE) reports, equipment calibration records, and employee qualifications and certification records.
- e) Verifying proper markings.
- f) Reviewing the vendor's purchase documents.
- g) Verifying that stock materials used were from approved source or (when applicable) properly qualified (eg., NCA-3867.4e).
- h) Verifying acceptance of physical properties such as hardness, tensile, yield, and impact through document review.
- i) Witnessing manufacturing and testing processes.

Response To NRC Compliance Bulletin 87-02
Page 2

QA RELEASE BY QA VENDORS

In addition to subject audits and surveillances, the vendor is required by each safety related purchase order to receive a Duke QA release prior to shipment, except as exempted per procedure. When notified by the vendor that an item is ready for shipment, QA Vendors schedules a visit to the vendor or grants a telephone release. We perform surveillances for approximately 10% of the purchase orders. For the other 90%, QA Vendors perform telephone communications to obtain the sufficient information to grant releases. The QA Vendors Division documents their release on Form QA-605, "QA Vendors Release". Verification of proper marking, proper documentation, and material manufacturer would be addressed as a minimum.

QA REVIEW OF VENDOR DOCUMENTATION

Vendor documentation is forwarded to Duke's QA Vendor Division Documentation Section for review. If found acceptable, documentation is approved and forwarded to applicable stations (approval is required and forwarded to applicable stations use). The applicable site is notified if problems are noted and material is placed in "HOLD" statues pending satisfactory resolution. During the review, the following areas are verified:

- a) Comparisons to purchase order.
- b) Chemical and physical properties reported are compared with applicable material specifications.
- c) Assure applicable ASME Code requirements have been included in the certification.
- d) Necessary historical and added testing data are included in the documentation package for material qualified per NCA-3867.4(e).
- e) Verify that the material supplier is an approved vendor.

QA RECEIVING INSPECTION

The receiving inspections at Duke's Nuclear sites are performed to ensure conformance of material to the purchase order. The QA procedure used for receipt at the site requires the material to be visually examined to assure identification and markings are in accordance with the purchase orders, standards and the vendor documentation.

Response To NRC Compliance Bulletin 87-02
Page 3

QA RECEIVING INSPECTION CONTINUED:

All QA Condition materials are identified with an unique QA Tag Number in addition to the assigned company number (i.e., MMIS Number). The QA Tag Number is specified to a given purchase order and a single line on that purchase order. This tag is either attached to the item(s) itself or on the packages(s) or container(s). Some items transferred from a Construction Program may not be traceable to purchase orders. In those cases sufficient documentation shall be specified to establish the acceptability of the item.

Duke Power Company
Response to NRC Compliance Bulletin 87-02
"Description of the Duke Power Controls Used During
Storage and Issuance From Stock to Assure the
Appropriate Use of Fastener"

All fasteners are stored in accordance with the requirements of ANSI N45.2.2 Level B or C. Procedures in each station's materials manual describe the controls applied for the handling and storage of items (not just fasteners). Stock fasteners are assigned a company number which facilitates in the retrieval of procurement information in addition to being used in the control of inventories and other company business needs. Non-stock fasteners are not identified by a company number since, in most situations, they are fasteners that are not common to other uses or applications.

Fasteners are identified for use normally in one of two ways. First, the Duke Design Engineering Department's piping installation specification (covering flange connections, etc.), hanger installation specification, and various electrical installation specifications are all used in identifying a need for fasteners. The second and most often used method is through each equipment specification and associated instruction manuals, maintenance manuals, and equipment drawings which have bills of material. The majority of fasteners in this category would be identified by a manufacturer's part number or by some relationship to the equipment. Much of the information from these documents can be found on data bases. After selection for procurement through one of the methods above, the fastener would be stored and identified as described previously.

In addition to the assigned company number, all stock and non-stock QA fasteners are assigned a unique QA tag number. This number is unique to a specific line item on a specific purchase order. For safety-related fasteners, the QA tag number facilitates traceability to the installed location required by 10 CFR 50 Appendix B. The issuance of QA fasteners is controlled by procedures found in each station's materials manual. These fasteners are issued to a work request, which is the Duke administrative program used to control maintenance work activities at each station, that identifies and captures all pertinent data such as company and QA tag number, quantities, procedures utilized, and other descriptive information. Although non-QA fasteners are not required to be issued to a work request, in many cases they will be included since the equipment they are used on is safety-related. Their actual function in those cases, however is not considered safety-related. If fasteners have not been adequately identified on design documents or data bases and there is a question concerning the proper fastener, it is the responsibility of the site engineering section to provide (with the help of Design Engineering if needed) the maintenance technician with the correct fastener for that particular application.

Duke Power Company Response to NRC Bulletin 87-02

Method for Choosing the Fasteners to be Tested.

The selection process began by listing all: 1. Bolts 2. Screws 3. Studs 4. Capscrews and 5. Nuts described in the MMIS (Materials Management Information System) computer data files for each station.

The following factors were used in the selection of test samples.

1. Fasteners listed as standard issue fasteners, not necessarily listed as a part for a specific component, were chosen. In a few cases (especially Oconee), there was not a suitably large selection of general issue fasteners and so the list was supplemented by equipment vendor supplied fasteners.
2. Fasteners that represented an assortment of different materials were chosen. For a reasonable number of fasteners, the description listed the material type.
3. Fasteners that represented an assortment of manufacturers and suppliers were chosen. The MMIS list had very little information on manufacturers and suppliers but the samples chosen took this requirement into account as much as possible.
4. If tensile tests were required (such as safety related bolts), fasteners had to be at least 4 inches long and, if possible, with either 3/8-16 or 3/4-10 threads to accommodate tensile specimen fabrication. To support chemical analysis, the fasteners were at least 3/8 inch nominal size. In some cases, samples were slightly smaller than this. To assure their representation, some safety related fasteners shorter than 4 inches were added to the Non-Safety list. (Testing under bulletin 87-02 is identical for QA and non-QA bolts except for tensile testing.)

A list of forty fasteners was made for each station and presented to each station's NRC resident inspector as a draft from which to begin. The MMIS numbers that begin with "1007", the Construction Department numbering method, are coded for the piping class they are to be used on. For safety related fasteners the last alpha character is either A, B, or C. The eight or nine digit numbers, Nuclear Production Department numbering method, are safety related if they end with an "N". Non safety related fastener lists contain a number of safety related fasteners because of the reason stated in paragraph 4. above and because general purpose fasteners are often purchased as safety related to allow a greater versatility of application. Some minor discrepancies were found in the nomenclature of MMIS descriptions. A final list of fasteners from each station is attached.

McGuire Fastener Sampling

On November 25, 1987 Bill Orders, NRC Resident Inspector for McGuire, reviewed the list of fasteners and performed an inspection of the fasteners in stock.

The NRC Temporary Instructions concerning this bulletin recommended fasteners be added if they had one of nine manufacturer codes or no code. Four examples of this were found and two of them were exchanged with others on the list. Also found during the inspection was threaded rod which is often issued for making studs. A sample of this was added also. Mr. Orders then reviewed the diversity of materials and manufacturers and agreed that the adjusted sample selection was acceptable. Six samples were replaced on December 2, 1987 because the samples originally chosen were out of stock or deleted from stock. A letter was written to document this adjustment to the list. Other minor list adjustments were made after verbal confirmation with Bill Orders.

For MMIS sequence number 0253580, Sample Numbers MNS/NQ/SCRW/15 and 16, two different manufacturers were found so both were used.

Catawba Fastener Sampling

On November 30, 1987 Mark Lesser, NRC Resident Inspector for Catawba, reviewed the list of fasteners, tabulated them by material type, and performed an inspection of the fasteners in stock. Threaded rod was found but not chosen because a storekeeper familiar with fasteners stated that it was not issued very often; also the material types and manufacturers were represented by other bolt samples. Two non-QA bolt samples were chosen and one of them was added to the list. Mr. Lesser then reviewed the diversity of materials and manufacturers and agreed that the adjusted sample selection was acceptable. Four fasteners were replaced on December 3, 1987 because the samples originally chosen were out of stock or were misnumbered. A letter was written to document this adjustment to the list.

Oconee Fastener Sampling

On December 1, 1987 Len Wert, NRC Resident Inspector for Oconee and Nick Economos of Region II reviewed the list of fasteners, tabulated them by material type, and performed an inspection of the fasteners in stock. Threaded rod was found and an example was added to the list. Silica Bronze and eye bolt fasteners were removed from the list because they were not of interest to this bulletin. Oconee carries very few standard issue, general purpose fasteners and so most of the fasteners selected were Safety Related and associated with a specific plant purpose. Two materials and manufacturers of nuts were found under MMIS number 1007B3AN1COB010 and so both were used (samples ONS/QA/NUT/26 and 27). MMIS number 23210244N was received as a nut and bolt pair so the bolt is sample ONS/QA/BOLT/5 and the nut is ONS/QA/NUT/22. Mr. Economos and Mr. Wert both reviewed the diversity of materials and manufacturers and agreed that the adjusted sample selection was acceptable. Len Wert later notified us that MMIS number 1007B1AS1COG007050 was not a Safety Related fastener and it was exchanged for a QA fastener from the non-QA list.

Sample Testing

Chemical analysis for all fastener samples was performed by Chicago Spectro Service Laboratory, Inc. 4848 South Kedzie Ave. Chicago IL 60632. This company is an approved vendor for providing analytical services under the Duke Power QA program. Hardness and tensile testing was performed in and under the QA program of the metallurgy laboratory of the Production Support Department of Duke Power Company. It has been proposed that Law Engineering Services, Charlotte NC perform the Charpy impact property tests. Law Engineering also has Duke QA approval for material testing.

Oconee List of Fastener Samples (As of January 5, 1988)

Safety Related Bolts

| Sample Number | MMIS Description | MMIS Number |
|---------------|---|-----------------|
| ONS/QA/BOLT/1 | Bolt,Mach Hex SS 3/4-10X3 1/2 SA-193/B8 | 02624012N |
| ONS/QA/BOLT/2 | Bolt,Mach Hex HD SS 5/8-11X6 SA193/B8 | 02624017N |
| ONS/QA/BOLT/3 | Bolt,Mach HVY HD CS 7/8-9 X 6-1/2 A325 | 02623399N |
| ONS/QA/ROD/4 | Rod,THRD Alloy Steel 3/4-10 SA193 GR B7 | 1007B1AR1COB006 |
| ONS/QA/BOLT/5 | Bolt,Hex Head RV 1-8X3 1/2 193 B7 | 23210244N |
| ONS/QA/STUD/6 | Stud,CS 112T 1-8X7-1/4 OTSG PRI INSPECT | 23240157N |
| ONS/QA/STUD/7 | Stud,Load Pipe Clamp .750 X 10UNCX6.50 | 0298EE04FN |
| ONS/QA/STUD/8 | Stud,1006688-001 MK#145 3/4" OTSG SEC | 02691449N |
| ONS/QA/CAP/9 | Capscrew,Hex HD 1-1/8-7X8 1/4 CD SA193 | 02653107N |
| ONS/QA/CAP/10 | Capscrew,Soc HD 1-1/2-6X4 A574 LIMITOR | 02655186N |

Non Safety Bolts

| | | |
|----------------|---|--------------------|
| ONS/NQ/BOLT/11 | Bolt Machine Hex HD CS 7/8-9 X 4 GR 8 | 02623157 |
| ONS/NQ/BOLT/12 | Bolt Mach HVY Hex HD CS 1/2-13 X 2 A325 | 02621252N |
| ONS/NQ/BOLT/13 | Bolt,Bracket 8348556 Diesel Generator | 29020732N |
| ONS/NQ/STUD/14 | Stud,B7 CL G 7/8-9 5 SA193 | 1007B1AS1COG007050 |
| ONS/NQ/BOLT/15 | Bolt,Hex HD 1 1/4 X 6 A325 RCP Motor | 20110249 |
| ONS/NQ/BOLT/16 | Bolt,Shell Mnwy Cvr 1-1/4-8 X 10 MSRH | N205023453 |
| ONS/NQ/BOLT/17 | Bolt,023 5/16 X 4 Fuel & Lube Oil Pmp | 20391186N |
| ONS/NQ/SCRW/18 | Screw,Assy HH 1/2-13X2 306/307 10 KIP | 0298C*55FN |
| ONS/NQ/SCRW/19 | Screw,Cap Hex HD SS 3/8-16 X 2 B8M | 02652100N |
| ONS/NQ/CAP/20 | Capscrew,Soc HD 20 1X3-1/4 RCP Bingham | 20110389N |

Safety Related Nuts

| | | |
|---------------|--|-----------------|
| ONS/QA/NUT/21 | Nut,Hex AS 3/8-16 SA194 GR 8 CL B | 1007C1AM1COB003 |
| ONS/QA/NUT/22 | Nut,Hex 1-8 194 B7 CS (with bolt) | 23210244N |
| ONS/QA/NUT/23 | Nut,Hex CD 7/16-20 GRADE 8 | 02640007N |
| ONS/QA/NUT/24 | Nut,Hex SS 3/8-16 A194 GRADE B8M | 02642083N |
| ONS/QA/NUT/25 | Nut,HVY Hex SS 3/4-10 SA194 GR 8 | 02642061N |
| ONS/QA/NUT/26 | Nut,Hex 1-8 SA194 2H QA Tag 39323 Mfg"J" | 1007B3AN1COB010 |
| ONS/QA/NUT/27 | Nut,Hex 1-8 SA194 GR7 QA Tag 46009 Mfg"CU" | 1007B3AN1COB010 |
| ONS/QA/NUT/28 | Nut,HVY Hex CS 3/4-10 A563 GR A | 02641784N |
| ONS/QA/NUT/29 | Nut,HVY Hex CS 5/8-11 A325 GR A | 02641237N |
| ONS/QA/NUT/30 | Nut,Jam CS 2-3/4-4 A563 CL B | 02641740N |

Non Safety Nuts

| | | |
|---------------|---|-----------------|
| ONS/NQ/NUT/31 | Nut,HVY Hex CS 1-1/8-7 A307 GR A | 02641179N |
| ONS/NQ/NUT/32 | Nut,Hex CS 1-3/8-6 SURE LOC | 02641397 |
| ONS/NQ/NUT/33 | Nut,Hex CS 2-4-1/2 2H SURE LOC | 02641398 |
| ONS/NQ/NUT/34 | Nut,Hex CS 7/8-9 GR8 | 02641864 |
| ONS/NQ/NUT/35 | Nut,HVY Hex AS 3/4-10 A194 GR 8M CL E | 1007C5AN1COE006 |
| ONS/NQ/NUT/36 | Nut,HVY Hex CS 1-8 A307 GRADE A | 02641211N |
| ONS/NQ/NUT/37 | Nut,HVY Hex CS 1-8 A325 GRADE A | 02641210N |
| ONS/NQ/NUT/38 | Nut,HVY Hex CS 1-8 A563 GRADE A | 02641301N |
| ONS/NQ/NUT/39 | Nut,Hex CS 1-1/4-8 SA194 GR 7 MOIST SEP | N205023473 |
| ONS/NQ/NUT/40 | Nut,Manway 1006118-001 MK#160 OTSG SEC | N232001153Q |

Catawba List of Fastener Samples (As of December 11, 1987)

Safety Related Bolts

| Sample Number | MMIS Description | MMIS Number |
|----------------|--|--------------------|
| CNS/QA/BOLT/1 | Bolt,Machine Hex HD CS 3/8-16X5 A-307/A | 02623970N |
| CNS/QA/BOLT/2 | Bolt,Machine Hex HD CS 7/16-14X5 J429/5 | 02623903N |
| CNS/QA/BOLT/3 | Bolt,Machine Hex HD CS 7/16-14X5 SA449 | 02623902N |
| CNS/QA/BOLT/4 | Bolt,Machine HVY Hex HD Alloy 3/4-10X4 | 02624010N |
| CNS/QA/BOLT/5 | Bolt,Machine HVY Hex HD CS 3/4-10X6 A325 | 02622100N |
| CNS/QA/BOLT/6 | Bolt,Secondary Handholds S/G 1 1/4-8X5 | 23240072N |
| CNS/QA/STUD/7 | Stud,Alloy Steel 3/4-10X6 SA193 GR B7 | 1007BIAS1COB006060 |
| CNS/QA/SCRW/8 | Screw,CAP 3/4-10X4 Camshaft Bearing Cap | 29020956N |
| CNS/QA/SCRW/9 | Screw,Cap Hex HD CS 3/4-10X4 J429/8 | 02653998N |
| CNS/QA/STUD/10 | Stud,Vlv 3/4-10X5 3/4 ASME SA564 T630 | 244401851N |

Non Safety Bolts

| | | |
|----------------|--|-----------|
| CNS/NQ/BOLT/11 | Bolt,Hex HD Silicon Bron 3/8-16X1 F468 | 02621207N |
| CNS/NQ/SCRW/12 | Screw,Cap Hex HD CS 7/16-20X2 GR 2 | 02652451 |
| CNS/NQ/BOLT/13 | Bolt,Mach Hex HD CS 1 1/8-7X6 A193 GRB7 | 02622111 |
| CNS/NQ/BOLT/14 | Bolt,Machine W/Nut Hex HD STL 5/16-18X2 | 02621014 |
| CNS/NQ/BOLT/15 | Bolt,Machine W/Nut Hex HD STL 3/8-16X4 | 02621030 |
| CNS/NQ/SCRW/16 | Screw,Cap Hex HD SS 1/2-20X1 | 02654553 |
| CNS/NQ/SCRW/17 | Screw,Cap Hex HD CS 7/16-20x4 GR2 | 02652453 |
| CNS/NQ/BOLT/18 | Bolt,Lftng Lug Hex HD CS 1 1/2X6X14 A325 | 02624000 |
| CNS/NQ/SCRW/19 | Screw,Cap Soc HD STL 1/2-13X2 | 02651809 |
| CNS/NQ/SCRW/20 | Screw,Set SQ HD Alloy STL 1/2-13X3 | 02654488 |

Safety Related Nuts

| | | |
|---------------|--|------------------|
| CNS/QA/NUT/21 | Nut,G1 Vlv 6,3/4-10 SA194 GR 3M Borg W | 244403773N |
| CNS/QA/NUT/22 | Nut,HVY Hex 1 1/4-12X1 7/32X2 SA194/2H | 02641775N |
| CNS/QA/NUT/23 | Nut,Hex Alloy Stl 5/16-18 SA194 GR8 CL A | 1007CIAM1COA0005 |
| CNS/QA/NUT/24 | Nut,Hex BR 5/16-18 X 1/4 X 1/2 | 02641923N |
| CNS/QA/NUT/25 | Nut,Hex GT VLV 6&8,5/8-11 SA194 GRADE 8M | 244103251N |
| CNS/QA/NUT/26 | Nut,Hex HD CS 5/8-11 X 9/16 X 15/16 | 02641915N |
| CNS/QA/NUT/27 | Nut,Special Hex 1 1/2-6 A563 GR B | 02642095N |
| CNS/QA/NUT/28 | Nut,Hex SS 3/8-16 A194/B8 | 02641990N |
| CNS/QA/NUT/29 | Nut,Hex Jam 1 1/4-20 ASTM A194 GR 2H G | 244102420N |
| CNS/QA/NUT/30 | Nut,Hex Jam 3/4-10 ASTM A194 GR 8M CK V | 235100925N |

Non Safety Nuts

| | | |
|---------------|--|-----------------|
| CNS/NQ/NUT/31 | Nut,HVY Hex CS 3/4-10 SA194 GR 7 CL B | 1007B3AN1COB006 |
| CNS/NQ/NUT/32 | Nut,Hex HVY STL 3/4-10X47/64X1 1/4 2B | 02641027 |
| CNS/NQ/NUT/33 | Nut,Hex Silicon Bron 3/8-16X9/16X21/64 | 02641835 |
| CNS/NQ/NUT/34 | Nut,Hex STL 7/8-14X3/4X1 5/16 ZN CH | 02641011 |
| CNS/NQ/NUT/35 | Nut,HVY Hex Alloy Stl 7/8-8 SA453 GR 660 | 1007B5AG1LOA013 |
| CNS/NQ/NUT/36 | Nut,HVY Hex CS 1 1/4-8 SA194 GR 2H CL B | 1007B2AN1LO8012 |
| CNS/NQ/NUT/37 | Nut,HVY Hex CS 1-8 A563/A | 02641301N |
| CNS/NQ/NUT/38 | Nut,HVY Hex CS 7/8-9 SA194 GR 2H CL B | 1007B2AN1COB007 |
| CNS/NQ/NUT/39 | Nut,Hex CS 5/8-18 SA194/2H | 02641764N |
| CNS/NQ/NUT/40 | Nut,Hex Manhole Cover D/G Engine | 29021177N |

-5-

McGuire List of Fastener Samples (As of December 11, 1987)

Safety Related Bolts

| Sample Number | MMIS Description | MMIS Number |
|----------------|---|--------------------|
| MNS/QA/BOLT/1 | Bolt,Hex Head A-325 1 1/2-6X8 UNRC-2A | 02622016N |
| MNS/QA/BOLT/2 | Bolt,Hex Head A-325 3/4-10X6 UNRC-2A | 02621982N |
| MNS/QA/ROD/3 | Rod,Threaded CS 3/4-10 SA193-B7 GR A | 1007B1AR1COA006 |
| MNS/QA/STUD/4 | Stud,3/4-10X5 SA193 GR B7 | 1007B1AS1COA006050 |
| MNS/QA/STUD/5 | Stud,3/4-10X5 1/4 SA193 GR B7 | 1007B1AS1COB006052 |
| MNS/QA/CAP/6 | Capscrew,Hex Head 7/16-14X4 SA-193GR B7 | 02652967N |
| MNS/QA/SCRW/7 | Screw,CS Hex HD J429 Gr.8 1/2-13X3 1/2 | 02651885N |
| MNS/QA/SCRW/8 | Screw,CS Hex HD 3/8-16X4 SA193 GR B7 | 02652950N |
| MNS/QA/BOLT/9 | Bolt,Hex HD 1/2-13X7 3/4 SA307 GR A | 1007A7AD1COA004076 |
| MNS/QA/BOLT/10 | Bolt,Hex HD 1/2-13X6 SA193 B8M | 1007C9AD1COA004060 |

Non Safety Bolts

| | | |
|----------------|--|--------------------|
| MNS/NQ/BOLT/11 | Bolt,Carriage Oval HD CS 3/8-16X6 | 02621512 |
| MNS/NQ/SCRW/12 | Screw Cap 1/2X8 UC | 02654092 |
| MNS/NQ/BOLT/13 | Bolt,Hex Head 1-8X4 A193 GR B7 For MSRs | Non-Stock 5-L-1-1 |
| MNS/NQ/BOLT/14 | Bolt,Machine CS Hex HD 1/2-13X4 A307/A | 02623336 |
| MNS/NQ/SCRW/15 | Screw Cap 3/4X2 UC "Black Bethlehem St1" | 02653580 |
| MNS/NQ/SCRW/16 | Screw Cap 3/4X2 UC "Plated KS Brand" | 02653580 |
| MNS/NQ/BOLT/17 | Bolt,Hex Head A-325 3/4-10X3 UNRC-2A | 02621979N |
| MNS/NQ/BOLT/18 | Bolt,Hex 5/8-11X3 1/4 SA193 GR B8M | 1007C9AD1COA005032 |
| MNS/NQ/SCRW/19 | Screw,Cap 3/4X8 | 02655071 |
| MNS/NQ/SCRW/20 | Screw,CS Hex Head Cap 1/2-13X1 GR 5 | 02653189 |
| MNS/NQ/SCRW/21 | Screw,CS Hex HD 3/4-10X4 1/2 A325 GR 5 | 02653196 |

Safety Related Nuts

| | | |
|---------------|---|-----------------|
| MNS/QA/NUT/22 | Nut,3/4-10 SA194 GR B7 CLASS A | 1007B3AN1COA006 |
| MNS/QA/NUT/23 | Nut,HVY Hex CS 3/4-8 A194 GR2H STRUCTRL | 02641674N |
| MNS/QA/NUT/24 | Nut,Hex 3/8-16 A307/A | 02641513N |
| MNS/QA/NUT/25 | Nut,Hex 5/16-18 SA194 GR 2H CL B | 02641748N |
| MNS/QA/NUT/26 | Nut,Hexagon 7/16-14 ASTM A194 GR 8M | 244102525N |
| MNS/QA/NUT/27 | Nut,Hex CS 1/2-13X7/16X3/4 A307/A | 02641512N |
| MNS/QA/NUT/28 | Nut,Hex CS 1 1/2-8 A307 | 02641492N |
| MNS/QA/NUT/29 | Nut,HVY Hex CS 3/4-10 SA194 GR 2H | 1007B2AN1COA006 |
| MNS/QA/NUT/30 | Nut,Hex 1/2-13 SA563 GRADE A | 1007C7AM1COA004 |
| MNS/QA/NUT/31 | Nut,Cap CS 1/2-13 SA194 GR 2H CL A | 1007B2AZ1COA004 |

Non Safety Nuts

| | | |
|---------------|--|------------------|
| MNS/NQ/NUT/32 | Nut Hexagon 3/4 UNC | 02641976 |
| MNS/NQ/NUT/33 | Nut SS Hex 1/2-13 | 02641082 |
| MNS/NQ/NUT/34 | Nut SS Hex 3/4-10 | 02641085 |
| MNS/NQ/NUT/35 | Nut,Hex Head,1/2-13X7/16 J429 GR8 | 02641076N |
| MNS/NQ/NUT/36 | Nut,Jam CS 3/8-16 A307 GR A STRUCTURAL | 02641587N |
| MNS/NQ/NUT/37 | Nut,2D035 1-8UNC A582-GR416 | P202635253 |
| MNS/NQ/NUT/38 | Nut,Hex 7/16-14 SA563 GR A | 1007C7AM1COA0007 |
| MNS/NQ/NUT/39 | Nut,Hex 3/4-10 SA194 GRADE 8M | 1007C5AM1COA006 |
| MNS/NQ/NUT/40 | Nut,Hex SS ANSI B18.6.3-1975 3/8-16 | 02641944N |
| MNS/NQ/NUT/41 | Nut,Cap CS 9/16-12 SA194 GR 2H CL A | 1007B2AZ1COA0009 |

Duke Power Company
Response to NRC Compliance Bulletin 87-02
"Status and Schedule of the Evaluation
of Fastener Testing Results"

The evaluation of fastener testing results is not complete as of January 12, 1988. Status of this effort is as follows:

- All samples have been selected and forwarded to the lab.
- All testing has been completed unless we determine that some of the samples require impact testing.
- We have completed the review of approximately 70% of the test results at this time.
- Up to this point, we have not discovered any significant deviation from the material specifications.
- Barring any significant findings, we expect to complete our review, compilation, and submittal of the test results by February 11, 1988.
- Any deviations requiring engineering or safety evaluation would extend this period.