

Public Service™

Public Service
Company of Colorado

2420 W. 26th Avenue, Suite 100D, Denver, Colorado 80211

February 11, 1988
Fort St. Vrain
Unit No. 1
P-88032

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Docket No. 50-267

SUBJECT: NRC Inspection 86-09

REFERENCE: 1) NRC Letter
Gagliardo to
Walker dated
07/25/86 (G-
86407).
2) PSC Letter Gahm
to Gagliardo
dated 09/10/86
(P-86543).

Gentlemen:

As a result of a notice of violation (Reference 1) PSC committed to an indepth review of design documents (Reference 2) to ensure set point information is current on approximately 2400 drawings. PSC had originally planned to have this project completed by January 31, 1988. The backfit process of updating hard copy design documents has been slower than originally envisioned. Extensive resources dedicated to plant restart following the circulator failure and fire have impacted the review of the design documents. Documentation change notices have been approved to encompass all needed changes, but drafting work is not complete. PSC will have all drawing changes complete by October 31, 1988, thus closing out this issue.

8802170264 880211
PDR ADOCK 05000267
Q PDR


IE01
1/0

February 11, 1988

Until the project is complete, procedure revisions have been implemented which specify that setpoints on drawings are for information only and may not reflect current setpoint values.

Should you have any questions concerning this issue, please contact Mr. M. H. Holmes at (303) 480-6960 for further information.

Very truly yours,



H. L. Brey
Manager, Nuclear Licensing
and Fuels Division

HLB/DCG:brc

cc: Regional Administrator, Region IV
ATTN: Mr. T. F. Westerman, Chief
Projects Section B

Mr. Robert Farrell
Senior Resident Inspector
Fort St. Vrain