



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-327

SEQUOYAH NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 63  
License No. DPR-77

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 22, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8801140411 871231  
PDR ADOCK 05000327  
P PDR

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-77 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 63, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director  
for Projects  
TVA Projects Division  
Office of Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 31, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 63

FACILITY OPERATING LICENSE NO. DPR-77

DOCKET NO. 50-327

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages\* are provided to maintain document completeness.

REMOVE

3/4 3-11  
3/4 3-12  
3/4 3-15  
3/4 3-16  
3/4 3-17  
3/4 3-18  
3/4 3-19  
3/4 3-20  
3/4 3-21a  
3/4 3-22  
3/4 3-23  
3/4 3-24  
3/4 3-25  
3/4 3-26  
3/4 3-28  
3/4 3-31  
3/4 3-32  
3/4 3-35  
3/4 3-36  
3/4 3-37a

INSERT

3/4 3-11\*  
3/4 3-12  
3/4 3-15\*  
3/4 3-16  
3/4 3-17  
3/4 3-18\*  
3/4 3-19  
3/4 3-20\*  
3/4 3-21a  
3/4 3-22  
3/4 3-23  
3/4 3-24\*  
3/4 3-25\*  
3/4 3-26  
3/4 3-28  
3/4 3-31  
3/4 3-32\*  
3/4 3-35\*  
3/4 3-36  
3/4 3-37a

TABLE 4.3-1

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
1. Manual Reactor Trip	N.A.	N.A.	S/U(1) and R(9)	1, 2, and *
2. Power Range, Neutron Flux	S	D(2), M(3) and Q(6)	Q	1, 2
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R(6)	Q	1, 2
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R(6)	Q	1, 2
5. Intermediate Range, Neutron Flux	S	R(6)	S/U(1)	1, 2, and *
6. Source Range, Neutron Flux	S(7)	R(6)	M and S/U(1)	2, 3, 4, 5, and *
7. Overtemperature Delta T	S	R	M	1, 2
8. Overpower Delta T	S	R	M	1, 2
9. Pressurizer Pressure--Low	S	R	Q	1, 2
10. Pressurizer Pressure--High	S	R	Q	1, 2
11. Pressurizer Water Level--High	S	R	Q	1, 2
12. Loss of Flow - Single Loop	S	R	Q	1
13. Loss of Flow - Two Loops	S	R	N.A.	1
14. Main Steam Generator Water Level--Low-Low	S	R	Q	1, 2

SEQUOYAH - UNIT 1

3/4 3-11

Amendment No. 54

TABLE 4.3-1 (Continued)  
 REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
15. Steam/Feedwater Flow Mismatch and Low Steam Generator Water Level	S	R	Q	1, 2
16. Undervoltage - Reactor Coolant Pumps	N.A.	R	M	1
17. Underfrequency - Reactor Coolant Pumps	N.A.	R	M	1
18. Turbine Trip				
A. Low Fluid Oil Pressure	N.A.	N.A.	S/U(1)	1
B. Turbine Stop Valve Closure	N.A.	N.A.	S/U(1)	1
19. Safety Injection Input from ESF	N.A.	N.A.	M(4)	1, 2
20. Reactor Trip Breaker	N.A.	N.A.	M(5) and S/U(1)	1, 2, and *
21. Automatic Trip Logic	N.A.	N.A.	M(5)	1, 2, and *
22. Reactor Trip System Interlocks				
A. Intermediate Range Neutron Flux, P-6	N.A.	R	S/U(8)	2, and *
B. Power Range Neutron Flux, P-7	N.A.	R	S/U(8)	1
C. Power Range Neutron Flux, P-8	N.A.	R	S/U(8)	1
D. Power Range Neutron Flux, P-10	N.A.	R	S/U(8)	1, 2
E. Turbine Impulse Chamber Pressure, P-13	N.A.	R	S/U(8)	1
F. Power Range Neutron Flux, P-9	N.A.	R	S/U(8)	1
G. Reactor Trip, P-4	N.A.	N.A.	S/U(8)	1, 2, and *
23. Reactor Trip Bypass Breaker	N.A.	N.A.	M(10)R(11)	1, 2, and *

SEQUOYAH - UNIT 1

3/4 3-12

Amendment No. BA, 63

TABLE 3.3-3

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
1. SAFETY INJECTION, TURBINE TRIP AND FEEDWATER ISOLATION					
a. Manual Initiation	2	1	2	1, 2, 3, 4	20
b. Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15
c. Containment Pressure-High	3	2	2	1, 2, 3	16*
d. Pressurizer Pressure - Low	3	2	2	1, 2, 3#	16*
e. Differential Pressure Between Steam Lines - High				1, 2, 3	
Four Loops Operating	3/steam line	2/steam line any steam line	2/steam line		16*
f. Steam Flow in Two Steam Lines-High				1, 2, 3##	
Four Loops Operating	2/steam line	1/steam line any 2 steam lines	1/steam line		16*

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
COINCIDENT WITH EITHER T <sub>avg</sub> --Low-Low				1, 2, 3 <sup>##</sup>	
Four Loops Operating	1 T <sub>avg</sub> /loop	2 T <sub>avg</sub> any loops	1 T <sub>avg</sub> any 3 loops		16*
OR, COINCIDENT WITH Steam Line Pressure-Low				1, 2, 3 <sup>##</sup>	
Four Loops Operating	1 pressure/loop	2 pressures any loops	1 pressure any 3 loops		16*
2. CONTAINMENT SPRAY					
a. Manual	2	1*	2	1, 2, 3, 4	20
b. Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15
c. Containment Pressure--High-High	4	2	3	1, 2, 3	18
3. CONTAINMENT ISOLATION					
a. Phase "A" Isolation					
1) Manual	2	1	2	1, 2, 3, 4	20
2) From Safety Injection Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15

\*Two switches must be operated simultaneously for actuation.

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

SEQUOYAH - UNIT 1

3/4 3-17

Amendment No. 41, 63

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
b. Phase "B" Isolation					
1) Manual	2	1*	2	1, 2, 3, 4	20
2) Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15
3) Containment Pressure-High-High	4	2	3	1, 2, 3	18
c. Containment Ventilation Isolation					
1) Manual	2	1	2	1, 2, 3, 4	19
2) Automatic Isolation Logic	2	1	2	1, 2, 3, 4	15
3) Containment Gas Monitor Radioactivity-High	2	1	1	1, 2, 3, 4	19
4) Containment Purge Air Exhaust Monitor Radioactivity-High	2	1	1	1, 2, 3, 4	19
5) Containment Particulate Activity High	2	1	1	1, 2, 3, 4	19

\*Two switches must be operated simultaneously for actuation.



TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
4. STEAM LINE ISOLATION					
a. Manual	1/steam line	1/steam line	1/operating steam line	1, 2, 3	25
b. Automatic Actuation Logic	2	1	2	1, 2, 3	23
c. Containment Pressure--High-High	4	2	3	1, 2, 3	18
d. Steam Flow in Two Steam Lines--High				1, 2, 3	
Four Loops Operating	2/steam line	1/steam line any 2 steam lines	1/steam line		16*
COINCIDENT WITH EITHER T <sub>avg</sub> --Low-Low Four Loops Operating	1 T <sub>avg</sub> /loop	2 T <sub>avg</sub> any loop	1 T <sub>avg</sub> any 3 loops	1, 2, 3	16*
OR, COINCIDENT WITH Steam Line Pressure--Low				1, 2, 3	
Four Loops Operating	1 pressure/loop	2 pressures any loops	1 pressure any 3 loops		16*

SEQUOYAH - UNIT 1

3/4 3-18

Amendment No. 41

TABLE 3.3-3 (Continued)

## ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
5. TURBINE TRIP & FEEDWATER ISOLATION					
a. Steam Generator Water Level--High-High	3/loop	2/loop in any operating loop	2/loop in each operating loop	1, 2, 3	16*
b. Automatic Actuation Logic	2	1	2	1, 2, 3	23
6. AUXILIARY FEEDWATER					
a. Manual Initiation	2	1	2	1, 2, 3	24
b. Automatic Actuation Logic	2	1	2	1, 2, 3	23
c. Main Stm. Gen. Water Level-Low-Low					
i. Start Motor Driven Pumps	3/stm. gen.	2/stm. gen. any stm gen.	2/stm. gen.	1, 2, 3	16*
ii. Start Turbine-Driven Pump	3/stm. gen.	2/stm. gen. any 2 stm. gen.	2/stm. gen.	1, 2, 3	16*
d. S.I. Start Motor-Driven Pumps and Turbine Driven Pump					See 1 above (all S.I. initiating functions and requirements)

SEQUOYAH - UNIT 1

3/4 3-19

Amendment No. 41, 63

SEQUOYAH - UNIT 1

3/4 3-20

Amendment No. 41

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
e. Station Blackout Start Motor-Driven Pump associated with the shutdown board and Turbine Driven Pump	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3	20
f. Trip of Main Feedwater Pumps Start Motor-Driven Pumps and Turbine Driven Pump	1/pump	1/pump	1/pump	1, 2	20*
g. Auxiliary Feedwater Suction Pressure-Low	3/pump	2/pump	2/pump	1, 2, 3	20*
**7. LOSS OF POWER					
a. 6.9 kv Shutdown Board --Loss of Voltage					
1. Start Diesel Generators	2/shutdown board	1 loss of voltage on any shutdown board	2/shutdown board	1, 2, 3, 4	20*
2. Load Shedding	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3, 4	20*

\*\*NOTE: This technical specification is to be implemented during the startup following the 2nd refueling outage or following completion of the modification, whichever is earlier.

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS					
a. Pressurizer Pressure - Not P-11	3	2	2	1, 2, 3	22a
b. T <sub>avg</sub> - P-12	4	2	3	1, 2, 3	22b
c. Steam Generator Level P-14	3/loop	2/loop any loop	3/loop	1, 2	22c
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP					
a. RWST Level - Low COINCIDENT WITH Containment Sump Level - High AND Safety Injection	4 4 (See 1 above for Safety Injection Requirements)	2 2	3 3	1, 2, 3, 4 1, 2, 3, 4	18 18
b. Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15

TABLE 3.3-3 (Continued)

TABLE NOTATION

- # Trip function may be bypassed in this MODE below P-11 (Pressurizer Pressure Block of Safety Injection) setpoint.
- ## Trip function may be bypassed in this MODE below P-12 ( $T_{avg}$  Block of Safety Injection) setpoint.
- ### The channel(s) associated with the protective functions derived from the out of service Reactor Coolant Loop shall be placed in the tripped mode.
- \* The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 15 - With the number of OPERABLE Channels one less than the Total Number of Channels, be in at least HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1 provided the other channel is OPERABLE.
- ACTION 16 - With the number of OPERABLE Channels one less than the Total Number of Channels, operation may proceed until performance of the next required CHANNEL FUNCTIONAL TEST, provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 17 - With a channel associated with an operating loop inoperable, restore the inoperable channel to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the following 12 hours; however, one channel associated with an operating loop may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 18 - With the number of OPERABLE Channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is demonstrated within 1 hour; one additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 19 - With less than the Minimum Channels OPERABLE, operation may continue provided the containment ventilation isolation valves are maintained closed.
- ACTION 20 - With the number of OPERABLE Channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

TABLE 3.3-3 (Continued)

- ACTION 21 - With the number of OPERABLE Channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 1 hour.
  - b. The Minimum Channels OPERABLE requirements is met; however, one additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 22 - With less than the Minimum Number of Channels OPERABLE, declare the interlock inoperable and verify that all affected channels of the functions listed below are OPERABLE or apply the appropriate ACTION statement(s) for those functions. Functions to be evaluated are:
- a. Safety Injection  
Pressurizer Pressure
  - b. Safety Injection  
High Steam Line Flow  
Steam Line Isolation  
High Steam Line Flow  
Steam Dump
  - c. Turbine Trip  
Steam Generator Level High-High  
Feedwater Isolation  
Steam Generator Level High-High
- ACTION 23 - With the number of OPERABLE channels one less than the Total Number of Channels, be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.
- ACTION 24 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours.
- ACTION 25 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.7.1.5.

TABLE 3.3-4

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. SAFETY INJECTION, TURBINE TRIP AND FEEDWATER ISOLATION		
a. Manual Initiation	Not Applicable	Not Applicable
b. Automatic Actuation Logic	Not Applicable	Not Applicable
c. Containment Pressure--High	$\leq 1.54$ psig	$\leq 1.7$ psig
d. Pressurizer Pressure--Low	$\geq 1870$ psig	$\geq 1860$ psig
e. Differential Pressure Between Steam Lines--High	$\leq 100$ psi	$\leq 112$ psi
f. Steam Flow in Two Steam Lines--High Coincident with $T_{avg}$ --Low-Low or Steam Line Pressure--Low	<p><math>&lt;</math> A function defined as follows: A <math>\Delta p</math> corresponding to 40% of full steam flow between 0% and 20% load and then a <math>\Delta p</math> increasing linearly to a <math>\Delta p</math> corresponding to 110% of full steam flow at full load</p> <p><math>T_{avg} \geq 540^{\circ}\text{F}</math>  <math>\geq 600</math> psig steam line pressure</p>	<p><math>&lt;</math> A function defined as follows: A <math>\Delta p</math> corresponding to 44% of full steam flow between 0% and 20% load and then a <math>\Delta p</math> increasing linearly to a <math>\Delta p</math> corresponding to 111.5% of full steam flow at full load</p> <p><math>T_{avg} \geq 538^{\circ}\text{F}</math>  <math>\geq 580</math> psig steam line pressure</p>



TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
2. CONTAINMENT SPRAY		
a. Manual Initiation	Not Applicable	Not Applicable
b. Automatic Actuation Logic	Not Applicable	Not Applicable
c. Containment Pressure--High-High	≤ 2.81 psig	≤ 2.97 psig
3. CONTAINMENT ISOLATION		
a. Phase "A" Isolation		
1. Manual	Not Applicable	Not Applicable
2. From Safety Injection Automatic Actuation Logic	Not Applicable	Not Applicable
b. Phase "B" Isolation		
1. Manual	Not Applicable	Not Applicable
2. Automatic Actuation Logic	Not Applicable	Not Applicable
3. Containment Pressure--High-High	≤ 2.81 psig	≤ 2.97 psig
c. Containment Ventilation Isolation		
1. Manual	Not Applicable	Not Applicable
2. Automatic Isolation Logic	Not Applicable	Not Applicable



TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
3. Containment Gas Monitor Radioactivity-High	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$
4. Containment Purge Air Exhaust Monitor Radioactivity-High	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$
5. Containment Particulate Activity-High	$\leq 1.5 \times 10^{-5} \mu\text{Ci/cc}$	$\leq 1.5 \times 10^{-5} \mu\text{Ci/cc}$
4. STEAM LINE ISOLATION		
a. Manual	Not Applicable	Not Applicable
b. Automatic Actuation Logic	Not Applicable	Not Applicable
c. Containment Pressure--High-High	$\leq 2.81 \text{ psig}$	$\leq 2.97 \text{ psig}$
d. Steam Flow in Two Steam lines--High Coincident with $T_{\text{avg}}$ --Low-Low Or Steam Line Pressure--Low	$\leq$ A function defined as follows: A $\Delta p$ corresponding to 40% of full steam flow between 0% and 20% load and then a $\Delta p$ increasing linearly to a $\Delta p$ corresponding to 110% of full steam flow at full load.  $T_{\text{avg}} \geq 540^{\circ}\text{F}$ $> 600 \text{ psig steam line pressure}$	$\leq$ A function defined as follows: A $\Delta p$ corresponding to 44% of full steam flow between 0% and 20% load and then a $\Delta p$ increasing linearly to a $\Delta p$ corresponding to 111.5% of full steam flow at full load.  $T_{\text{avg}} \geq 538^{\circ}\text{F}$ $> 580 \text{ psig steam line pressure}$
5. TURBINE TRIP AND FEEDWATER ISOLATION		
a. Steam Generator Water level--High-High	$< 75\%$ of narrow range instrument span each steam generator	$< 76\%$ of narrow range instrument span each steam generator
b. Automatic Actuation Logic	N.A.	N.A.

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS (Continued)		
b. $T_{avg}$ Prevents Manual Block of Safety Injection P-12	$\leq 540^{\circ}\text{F}$	$\leq 542^{\circ}\text{F}$
c. $T_{avg}$ Manual Block of Safety Injection, Steam Line Isolation, Block Steam Dump	$\geq 540^{\circ}\text{F}$	$\geq 538^{\circ}\text{F}$
d. Steam Generator Level Turbine Trip, Feedwater Isolation P-14	(See 5. above)	
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP		
a. RWST Level - Low COINCIDENT WITH Containment Sump Level - High AND Safety Injection	130" from tank base 30" above elev. 680' (See 1 above for all Safety Injection Setpoints/Allowable Valves)	130" $\pm$ 4" from tank base 30" $\pm$ 2.5" above elev. 680'
b. Automatic Actuation Logic	N.A.	N.A.

SEQUOYAH - UNIT 1

3/4 3-28

Amendment No. 14, 63

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
6. <u>Steam Flow in Two Steam Lines-High</u> <u>Coincident with Steam Line Pressure-Low</u>	
a. Safety Injection (ECCS)	≤ 28.0 <sup>(7)</sup> /28.0 <sup>(1)</sup>
b. Reactor Trip (from SI)	≤ 3.0
c. Feedwater Isolation	≤ 8.0 <sup>(2)</sup>
d. Containment Isolation-Phase "A" <sup>(3)</sup>	≤ 18.0 <sup>(8)</sup> /28.0 <sup>(9)</sup>
e. Containment Ventilation Isolation	Not Applicable
f. Auxiliary Feedwater Pumps	≤ 60
g. Essential Raw Cooling Water System	≤ 65.0 <sup>(8)</sup> /75.0 <sup>(9)</sup>
h. Steam Line Isolation	≤ 8.0
i. Emergency Gas Treatment System	≤ 38.0 <sup>(9)</sup>
7. <u>Containment Pressure--High-High</u>	
a. Containment Spray	≤ 208 <sup>(9)</sup>
b. Containment Isolation-Phase "B"	≤ 65 <sup>(8)</sup> /75 <sup>(9)</sup>
c. Steam Line Isolation	≤ 7.0
d. Containment Air Return Fan	≥ 540.0 and ≤ 660
8. <u>Steam Generator Water Level--High-High</u>	
a. Turbine Trip	≤ 2.5
b. Feedwater Isolation	≤ 11.0 <sup>(2)</sup>
9. <u>Main Steam Generator Water Level -</u> <u>Low-Low</u>	
a. Motor-driven Auxiliary Feedwater Pumps <sup>(4)</sup>	≤ 60.0
b. Turbine-driven Auxiliary Feedwater Pumps <sup>(5)</sup>	≤ 60.0

TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
10. <u>Station Blackout</u>	
a. Auxiliary Feedwater Pumps	≤ 60
11. <u>Trip of Main Feedwater Pumps</u>	
a. Auxiliary Feedwater Pumps	≤ 60
*12. <u>Loss of Power</u>	
a. 6.9 kv Shutdown Board - Degraded Voltage or Loss of Voltage	≤ 10 <sup>(10)</sup>
13. <u>RWST Level-Low Coincident with Containment Sump Level-High and Safety Injection</u>	
a. Automatic Switchover to Containment Sump	≤ 250
14. <u>Containment Purge Air Exhaust Radioactivity - High</u>	
a. Containment Ventilation Isolation	≤ 10 <sup>(6)</sup>
15. <u>Containment Gas Monitor Radioactivity High</u>	
a. Containment Ventilation Isolation	≤ 10 <sup>(6)</sup>
16. <u>Containment Particulate Activity High</u>	
a. Containment Ventilation Isolation	≤ 10 <sup>(6)</sup>

\*NOTE: This technical specification to be implemented at the startup following the second refueling outage or following completion of the modification, whichever is earlier.

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
3. CONTAINMENT ISOLATION				
a. Phase "A" Isolation				
1) Manual	N.A.	N.A.	R	1, 2, 3, 4
2) From Safety Injection Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4
b. Phase "B" Isolation				
1) Manual	N.A.	N.A.	R	1, 2, 3, 4
2) Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4
3) Containment Pressure - High-High	S	R	Q	1, 2, 3
c. Containment Ventilation Isolation				
1) Manual	N.A.	N.A.	R	1, 2, 3, 4
2) Automatic Isolation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4
3) Containment Gas Monitor Radioactivity-High	S	R	M	1, 2, 3, 4

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES IN WHICH SURVEILLANCE REQUIRED
4) Containment Purge Air Exhaust Monitor Radio-activity-High	S	R	N	1, 2, 3, 4
5) Containment Particulate Activity-High	S	R	M	1, 2, 3, 4
4. STEAM LINE ISOLATION				
a. Manual	N.A.	N.A.	R	1, 2, 3
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
c. Containment Pressure--High-High	S	R	Q	1, 2, 3
d. Steam Flow in Two Steam Lines--High Coincident with $T_{avg}$ --Low-Low or Steam Line Pressure--Low	S	R	Q	1, 2, 3
5. TURBINE TRIP AND FEEDWATER ISOLATION				
a. Steam Generator Water Level--High-High	S	R	Q	1, 2, 3
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
6. AUXILIARY FEEDWATER				
a. Manual	N.A.	N.A.	R	1, 2, 3
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3

SEQUOYAH - UNIT 1

3/4 3-36

Amendment No. 47, 63

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES IN WHICH SURVEILLANCE REQUIRED</u>
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS				
a. Pressurizer Pressure, P-11	N.A.	R(2)	N.A.	1, 2, 3
b. T <sub>avg</sub> , P-12	N.A.	R(2)	N.A.	1, 2, 3
c. Steam Generator Level, P-14	N.A.	R(2)	N.A.	1, 2
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP				
a. RSWT Level - Low	S	R	M	1, 2, 3, 4
COINCIDENT WITH Containment Sump Level - High AND Safety Injection	S	R	M	1, 2, 3, 4
	(See 1 above for all Safety Injection Surveillance Requirements)			
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4

SEQUOYAH - UNIT 1

3/4 3-37a

Amendment No. 47, 63





UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

TENNESSEE VALLEY AUTHORITY  
DOCKET NO. 50-328  
SEQUOYAH NUCLEAR PLANT, UNIT 2  
AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 55  
License No. DPR-79

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 22, 1987, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.



2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-79 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 55, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Gary G. Zech, Assistant Director  
for Projects  
TVA Projects Division  
Office of Special Projects

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: December 31, 1987

ATTACHMENT TO LICENSE AMENDMENT NO. 55

FACILITY OPERATING LICENSE NO. DPR-79

DOCKET NO. 50-328

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Overleaf pages\* are provided to maintain document completeness.

REMOVE

3/4 3-11  
3/4 3-12  
3/4 3-17  
3/4 3-18  
3/4 3-19  
3/4 3-20  
3/4 3-21a  
3/4 3-22  
3/4 3-23  
3/4 3-24  
3/4 3-25  
3/4 3-26  
3/4 3-28  
3/4 3-31  
3/4 3-32  
3/4 3-35  
3/4 3-36  
3/4 3-37  
3/4 3-37a  
3/4 3-38

INSERT

3/4 3-11\*  
3/4 3-12  
3/4 3-17  
3/4 3-18\*  
3/4 3-19  
3/4 3-20\*  
3/4 3-21a  
3/4 3-22  
3/4 3-23  
3/4 3-24\*  
3/4 3-25\*  
3/4 3-26  
3/4 3-28  
3/4 3-31  
3/4 3-32\*  
3/4 3-35\*  
3/4 3-36  
3/4 3-37\*  
--  
3/4 3-38

TABLE 4.3-1  
REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
1. Manual Reactor Trip	N.A.	N.A.	S/U(1)and R(9)	1, 2, and *
2. Power Range, Neutron Flux	S	D(2), M(3) and Q(6)	Q	1, 2
3. Power Range, Neutron Flux, High Positive Rate	N.A.	R(6)	Q	1, 2
4. Power Range, Neutron Flux, High Negative Rate	N.A.	R(6)	Q	1, 2
5. Intermediate Range, Neutron Flux	S	R(6)	S/U(1)	1, 2, and *
6. Source Range, Neutron Flux	S(7)	R(6)	M and S/U(1)	2, 3, 4, 5, and *
7. Overtemperature $\Delta T$	S	R	M	1, 2
8. Overpower $\Delta T$	S	R	M	1, 2
9. Pressurizer Pressure--Low	S	R	Q	1, 2
10. Pressurizer Pressure--High	S	R	Q	1, 2
11. Pressurizer Water Level--High	S	R	Q	1, 2
12. Loss of Flow - Single Loop	S	R	Q	1
13. Loss of Flow - Two Loops	S	R	N.A.	1
14. Steam Generator Water Level-- Low-Low	S	R	Q	1, 2

TABLE 4.3-1 (Continued)

## REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
15. Steam/Feedwater Flow Mismatch and Low Steam Generator Water Level	S	R	Q	1, 2
16. Undervoltage - Reactor Coolant Pumps	N.A.	R	M	1
17. Underfrequency - Reactor Coolant Pumps	N.A.	R	M	1
18. Turbine Trip				
A. Low Fluid Oil Pressure	N.A.	N.A.	S/U(1)	1
B. Turbine Stop Valve Closure	N.A.	N.A.	S/U(1)	1
19. Safety Injection Input from ESF	N.A.	N.A.	M(4)	1, 2
20. Reactor Trip Breaker	N.A.	N.A.	M(5) and S/U(1)	1, 2, and *
21. Automatic Trip Logic	N.A.	N.A.	M(5)	1, 2, and *
22. Reactor Trip System Interlocks				
A. Intermediate Range Neutron Flux, P-6	N.A.	R	S/U (8)	2, and *
B. Power Range Neutron Flux, P-7	N.A.	R	S/U (8)	1
C. Power Range Neutron Flux, P-8	N.A.	R	S/U (8)	1
D. Power Range Neutron Flux, P-10	N.A.	R	S/U (8)	1, 2
E. Turbine Impulse Chamber Pressure, P-13	N.A.	R	S/U (8)	1
F. Power Range Neutron Flux, P-9	N.A.	R	S/U (8)	1
G. Reactor Trip, P-4	N.A.	N.A.	S/U (8)	1, 2, and *
23. Reactor Trip Bypass Breaker	N.A.	N.A.	M(10)R(11)	1, 2, and *

SEQUOYAH - UNIT 2

3/4 3-12

Amendment No. 16, 46, 55

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>TOTAL NO. OF CHANNELS</u>	<u>CHANNELS TO TRIP</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE MODES</u>	<u>ACTION</u>
2. CONTAINMENT SPRAY					
a. Manual	2	1*	2	1, 2, 3, 4	20
b. Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15
c. Containment Pressure-- High-High	4	2	3	1, 2, 3	18
3. CONTAINMENT ISOLATION					
a. Phase "A" Isolation					
1) Manual	2	1	2	1, 2, 3, 4	20
2) From Safety Injection Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15
b. Phase "B" Isolation					
1) Manual	2	1*	2	1, 2, 3, 4	20
2) Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15
3) Containment Pressure-High-High	4	2	3	1, 2, 3	18

\*Two switches must be operated simultaneously for actuation.

TABLE 3.3-3 (Continued)  
ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
c. Containment Ventilation Isolation					
1) Manual	2	1	2	1, 2, 3, 4	19
2) Automatic Isolation Logic	2	1	2	1, 2, 3, 4	15
3) Containment Gas Monitor Radioactivity-High	2	1	1	1, 2, 3, 4	19
4) Containment Purge Air Exhaust Monitor Radioactivity-High	2	1	1	1, 2, 3, 4	19
5) Containment Particulate Activity High	2	1	1	1, 2, 3, 4	19
4. STEAM LINE ISOLATION					
a. Manual	1/steam line	1/steam line	1/operating steam line	1, 2, 3	25
b. Automatic Actuation Logic	2	1	2	1, 2, 3	23
c. Containment Pressure--High-High	4	2	3	1, 2, 3	18
d. Steam Flow in Two Steam Lines--High				1, 2, 3	
Four Loops Operating	2/steam line	1/steam line any 2 steam lines	1/steam line		16*

TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
COINCIDENT WITH EITHER T <sub>avg</sub> --Low-Low Four Loops Operating	1 T <sub>avg</sub> /loop	2 T <sub>avg</sub> any loop	1 T <sub>avg</sub> any 3 loops	1, 2, 3	16*
OR, COINCIDENT WITH Steam Line Pressure- Low				1, 2, 3	
Four Loops Operating	1 pressure/ loop	2 pressures any loops	1 pressure any 3 loops		16*
5. TURBINE TRIP & FEEDWATER ISOLATION					
a. Steam Generator Water Level-- High-High	3/loop	2/loop in any oper- ating loop	2/loop in each oper- ating loop	1, 2, 3	16*
b. Automatic Actuation Logic	2	1	2	1, 2, 3	23



TABLE 3.3-3 (Continued)

## ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
6. AUXILIARY FEEDWATER					
a. Manual Initiation	2	1	2	1, 2, 3	24
b. Automatic Actuation Logic	2	1	2	1, 2, 3	23
c. Main Stm. Gen. Water Level-Low-Low					
i. Start Motor Driven Pumps	3/stm. gen.	2/stm. gen. any stm gen.	2/stm. gen.	1, 2, 3	16*
ii. Start Turbine-Driven Pump	3/stm. gen.	2/stm. gen. any 2 stm. gen.	2/stm. gen.	1, 2, 3	16*
d. S.I. Start Motor-Driven Pumps and Turbine Driven Pump	See 1 above (all S.I. initiating functions and requirements)				
e. Station Blackout Start Motor-Driven Pump associated with the shutdown board and Turbine Driven Pump	2/shutdown board	1/shutdown board	2/shutdown board	1, 2, 3	20
f. Trip of Main Feedwater Pumps Start Motor-Driven Pumps and Turbine Driven Pump	1/pump	1/pump	1/pump	1, 2	20*
g. Auxiliary Feedwater Suction Pressure-Low	3/pump	2/pump	2/pump	1, 2, 3	20*

SEQUOYAH - UNIT 2

3/4 3-20

Amendment No. 29



TABLE 3.3-3 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	TOTAL NO. OF CHANNELS	CHANNELS TO TRIP	MINIMUM CHANNELS OPERABLE	APPLICABLE MODES	ACTION
6. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS					
a. Pressurizer Pressure - Not P-11	3	2	2	1, 2, 3	22a
b. T <sub>avg</sub> - P-12	4	2	3	1, 2, 3	22b
c. Steam Generator Level P-14	3/loop	2/loop any loop	3/loop	1, 2	22c
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP					
a. RWST Level - Low COINCIDENT WITH Containment Sump Level - High AND Safety Injection	4	2	3	1, 2, 3, 4	18
	4	2	3	1, 2, 3, 4	18
	(See 1 above for Safety Injection Requirements)				
b. Automatic Actuation Logic	2	1	2	1, 2, 3, 4	15

SEQUOYAH - UNIT 2

3/4 3-21a

Amendment No. 18, 55

TABLE 3.3-3 (Continued)

TABLE NOTATION

- # Trip function may be bypassed in this MODE below P-11 (Pressurizer Pressure Block of Safety Injection) setpoint.
- ## Trip function may be bypassed in this MODE below P-12 ( $T_{avg}$  Block of Safety Injection) setpoint.
- ### The channel(s) associated with the protective functions derived from the out of service Reactor Coolant Loop shall be placed in the tripped mode.
- \* The provisions of Specification 3.0.4 are not applicable.

ACTION STATEMENTS

- ACTION 15 - With the number of OPERABLE Channels one less than the Total Number of Channels, be in HOT STANDBY within 6 hours and in COLD SHUTDOWN within the following 30 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1 provided the other channel is OPERABLE.
- ACTION 16 - With the number of OPERABLE Channels one less than the Total Number of Channels, operation may proceed until performance of the next required CHANNEL FUNCTIONAL TEST, provided the inoperable channel is placed in the tripped condition within 1 hour.
- ACTION 17 - With a channel associated with an operating loop inoperable, restore the inoperable channel to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the following 12 hours; however, one channel associated with an operating loop may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 18 - With the number of OPERABLE Channels one less than the Total Number of Channels, operation may proceed provided the inoperable channel is placed in the bypassed condition and the Minimum Channels OPERABLE requirement is demonstrated within 1 hour; one additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 19 - With less than the Minimum Channels OPERABLE, operation may continue provided the containment ventilation isolation valves are maintained closed.
- ACTION 20 - With the number of OPERABLE Channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within the next 6 hours and in COLD SHUTDOWN within the following 30 hours.

TABLE 3.3-3 (Continued)

- ACTION 21 - With the number of OPERABLE Channels one less than the Total Number of Channels, STARTUP and/or POWER OPERATION may proceed provided the following conditions are satisfied:
- a. The inoperable channel is placed in the tripped condition within 1 hour.
  - b. The Minimum Channels OPERABLE requirements is met; however, one additional channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 22 - With less than the Minimum Number of Channels OPERABLE, declare the interlock inoperable and verify that all affected channels of the functions listed below are OPERABLE or apply the appropriate ACTION statement(s) for those functions. Functions to be evaluated are:
- a. Safety Injection  
Pressurizer Pressure
  - b. Safety Injection  
High Steam Line Flow  
Steam Line Isolation  
High Steam Line Flow  
Steam Dump
  - c. Turbine Trip  
Steam Generator Level High-High  
Feedwater Isolation  
Steam Generator Level High-High
- ACTION 23 - With the number of OPERABLE channels one less than the Total Number of Channels, be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours; however, one channel may be bypassed for up to 2 hours for surveillance testing per Specification 4.3.2.1.1.
- ACTION 24 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or be in at least HOT STANDBY within 6 hours and in at least HOT SHUTDOWN within the following 6 hours.
- ACTION 25 - With the number of OPERABLE channels one less than the Total Number of Channels, restore the inoperable channel to OPERABLE status within 48 hours or declare the associated valve inoperable and take the ACTION required by Specification 3.7.1.5.

TABLE 3.3-4

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
1. SAFETY INJECTION, TURBINE TRIP AND FEEDWATER ISOLATION		
a. Manual Initiation	Not Applicable	Not Applicable
b. Automatic Actuation Logic	Not Applicable	Not Applicable
c. Containment Pressure--High	$\leq 1.54$ psig	$\leq 1.7$ psig
d. Pressurizer Pressure--Low	$\geq 1870$ psig	$\geq 1860$ psig
e. Differential Pressure Between Steam Lines--High	$\leq 100$ psi	$\leq 112$ psi
f. Steam Flow in Two Steam Lines--High Coincident with $T_{avg}$ --Low-Low or Steam Line Pressure--Low	<p><math>\leq</math>A function defined as follows: A <math>\Delta p</math> corresponding to 40% of full steam flow between 0% and 20% load and then a <math>\Delta p</math> increasing linearly to a <math>\Delta p</math> corresponding to 110% of full steam flow at full load</p> <p><math>T_{avg} \geq 540^{\circ}\text{F}</math>  <math>\geq 600</math> psig steam line pressure</p>	<p><math>\leq</math>A function defined as follows: A <math>\Delta p</math> corresponding to 44% of full steam flow between 0% and 20% load and then a <math>\Delta p</math> increasing linearly to a <math>\Delta p</math> corresponding to 111.5% of full steam flow at full load</p> <p><math>T_{avg} \geq 538^{\circ}\text{F}</math>  <math>\geq 580</math> psig steam line pressure</p>

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
2. CONTAINMENT SPRAY		
a. Manual Initiation	Not Applicable	Not Applicable
b. Automatic Actuation Logic	Not Applicable	Not Applicable
c. Containment Pressure--High-High	<2.81 psig	<2.97 psig
3. CONTAINMENT ISOLATION		
a. Phase "A" Isolation		
1. Manual	Not Applicable	Not Applicable
2. From Safety Injection Automatic Actuation logic	Not Applicable	Not Applicable
b. Phase "B" Isolation		
1. Manual	Not Applicable	Not Applicable
2. Automatic Actuation Logic	Not Applicable	Not Applicable
3. Containment Pressure--High-High	<2.81 psig	<2.97 psig
c. Containment Ventilation Isolation		
1. Manual	Not Applicable	Not Applicable
2. Automatic Isolation Logic	Not Applicable	Not Applicable

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TRIP SETPOINT	ALLOWABLE VALUES
3. Containment Gas Monitor Radioactivity-High	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$
4. Containment Purge Air Exhaust Monitor Radioactivity-High	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$	$\leq 8.5 \times 10^{-3} \mu\text{Ci/cc}$
5. Containment Particulate Activity-High	$\leq 1.5 \times 10^{-5} \mu\text{Ci/cc}$	$\leq 1.5 \times 10^{-5} \mu\text{Ci/cc}$
4. STEAM LINE ISOLATION		
a. Manual	Not Applicable	Not Applicable
b. Automatic Actuation Logic	Not Applicable	Not Applicable
c. Containment Pressure--High-High	$\leq 2.81 \text{ psig}$	$\leq 2.97 \text{ psig}$
d. Steam Flow in Two Steam Lines--High Coincident with $T_{\text{avg}}$ --Low-Low Or Steam Line Pressure--Low	<p><math>\leq</math> A function defined as follows: A <math>\Delta p</math> corresponding to 40% of full steam flow between 0% and 20% load and then a <math>\Delta p</math> increasing linearly to a <math>\Delta p</math> corresponding to 110% of full steam flow at full load.</p> <p><math>T_{\text{avg}} \geq 540^\circ\text{F}</math>  <math>&gt; 600 \text{ psig steam line pressure}</math></p>	<p><math>\leq</math> A function defined as follows: A <math>\Delta p</math> corresponding to 44% of full steam flow between 0% and 20% load and then a <math>\Delta p</math> increasing linearly to a <math>\Delta p</math> corresponding to 111.5% of full steam flow at full load</p> <p><math>T_{\text{avg}} \geq 538^\circ\text{F}</math>  <math>&gt; 580 \text{ psig steam line pressure}</math></p>
5. TURBINE TRIP AND FEEDWATER ISOLATION		
a. Steam Generator Water level--High-High	<p><math>&lt; 75\%</math> of narrow range Instrument span each steam generator</p>	<p><math>&lt; 76\%</math> of narrow range Instrument span each steam generator</p>
b. Automatic Actuation Logic	N.A.	N.A.

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUES</u>
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS (Continued)		
b. $T_{avg}$ Prevents Manual Block of Safety Injection P-12	$\leq 540^{\circ}\text{F}$	$\leq 542^{\circ}\text{F}$
c. $T_{avg}$ Manual Block of Safety Injection, Steam Line Isolation, Block Steam Dump	$\geq 540^{\circ}\text{F}$	$\geq 538^{\circ}\text{F}$
d. Steam Generator Level Turbine Trip, Feedwater Isolation P-14	(See 5. above)	
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP		
a. RWST Level - Low COINCIDENT WITH Containment Sump Level - High AND Safety Injection	130" from tank base 30" above elev. 680' (See 1 above for all Safety Injection Setpoints, Allowable Valves)	130" $\pm$ 4" from tank base 30" $\pm$ 2.5" above elev. 680'
b. Automatic Actuation Logic	N.A.	N.A.



TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
6. <u>Steam Flow in Two Steam Lines-High</u>	
<u>Coincident with Steam Line Pressure-Low</u>	
a. Safety Injection (ECCS)	≤ 28.0 <sup>(7)</sup> /28.0 <sup>(1)</sup>
b. Reactor Trip (from SI)	≤ 3.0
c. Feedwater Isolation	≤ 8.0 <sup>(2)</sup>
d. Containment Isolation-Phase "A" <sup>(3)</sup>	≤ 18.0 <sup>(8)</sup> /28.0 <sup>(9)</sup>
e. Containment Ventilation Isolation	Not Applicable
f. Auxiliary Feedwater Pumps	≤ 60
g. Essential Raw Cooling Water System	≤ 65.0 <sup>(8)</sup> /75.0 <sup>(9)</sup>
h. Steam Line Isolation	≤ 8.0
i. Emergency Gas Treatment System	≤ 38.0 <sup>(9)</sup>
7. <u>Containment Pressure--High-High</u>	
a. Containment Spray	≤ 208 <sup>(9)</sup>
b. Containment Isolation-Phase "B"	≤ 65 <sup>(8)</sup> /75 <sup>(9)</sup>
c. Steam Line Isolation	≤ 7.
d. Containment Air Return Fan	≥ 54.0 and ≤ 660
8. <u>Steam Generator Water Level--High-High</u>	
a. Turbine Trip	≤ 2.5
b. Feedwater Isolation	≤ 11.0 <sup>(2)</sup>
9. <u>Main Steam Generator Water Level -</u>	
<u>Low-Low</u>	
a. Motor-driven Auxiliary Feedwater Pumps <sup>(4)</sup>	≤ 60.0
b. Turbine-driven Auxiliary Feedwater Pumps <sup>(5)</sup>	≤ 60.0



TABLE 3.3-5 (Continued)

ENGINEERED SAFETY FEATURES RESPONSE TIMES

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME IN SECONDS</u>
10. <u>Station Blackout</u>	
a. Auxiliary Feedwater Pumps	≤ 60
11. <u>Trip of Main Feedwater Pumps</u>	
a. Auxiliary Feedwater Pumps	≤ 60
*12. <u>Loss of Power</u>	
a. 6.9 kv Shutdown Board - Degraded Voltage or Loss of Voltage	≤ 10 <sup>(10)</sup>
13. <u>RWST Level-Low Coincident with Containment Sump Level-High and Safety Injection</u>	
a. Automatic Switchover to Containment Sump	≤ 250
14. <u>Containment Purge Air Exhaust Radioactivity - High</u>	
a. Containment Ventilation Isolation	≤ 10 <sup>(6)</sup>
15. <u>Containment Gas Monitor Radioactivity High</u>	
a. Containment Ventilation Isolation	≤ 10 <sup>(6)</sup>
16. <u>Containment Particulate Activity High</u>	
a. Containment Ventilation Isolation	≤ 10 <sup>(6)</sup>

\*NOTE: This technical specification is to be implemented during the startup following the first refueling outage.

TABLE 4.3-2 (Continued)  
ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
3. CONTAINMENT ISOLATION				
a. Phase "A" Isolation				
1) Manual	N.A.	N.A.	R	1, 2, 3, 4
2) From Safety Injection Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4
b. Phase "B" Isolation				
1) Manual	N.A.	N.A.	R	1, 2, 3, 4
2) Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4
3) Containment Pressure-- High-High	S	R	Q	1, 2, 3
c. Containment Ventilation Isolation				
1) Manual	N.A.	N.A.	R	1, 2, 3, 4
2) Automatic Isolation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4
3) Containment Gas Monitor Radioactivity-High	S	R	M	1, 2, 3, 4

TABLE 4.3-2 (Continued)  
ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
4) Containment Purge Air Exhaust Monitor Radio-activity-High	S	R	M	1, 2, 3, 4
5) Containment Particulate Activity-High	S	R	M	1, 2, 3, 4
4. STEAM LINE ISOLATION				
a. Manual	N.A.	N.A.	R	1, 2, 3
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
c. Containment Pressure--High-High	S	R	Q	1, 2, 3
d. Steam Flow in Two Steam Lines--High Coincident with T <sub>avg</sub> -- Low-Low or Steam Line Pressure--Low	S	R	Q	1, 2, 3
5. TURBINE TRIP AND FEEDWATER ISOLATION				
a. Steam Generator Water Level--High-High	S	R	Q	1, 2, 3
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3
6. AUXILIARY FEEDWATER				
a. Manual	N.A.	N.A.	R	1, 2, 3
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	CHANNEL FUNCTIONAL TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
c. Main Steam Generator Water Level-Low-Low	S	R	Q	1, 2, 3
d. S.I.	See 1 above (all SI surveillance requirements)			
e. Station Blackout	N.A.	R	N.A.	1, 2, 3
f. Trip of Main Feedwater Pumps	N.A.	N.A.	R	1, 2
g. Auxiliary Feedwater Suction	N.A.	R	M	1, 2, 3
*7. LOSS OF POWER				
a. 6.9 kv Shutdown Board - Loss of Voltage				
1. Start Diesel Generators	S	R	M	1, 2, 3, 4
2. Load Shedding	S	R	N.A.	1, 2, 3, 4
b. 6.9 kv Shutdown Board - Degraded Voltage				
1. Voltage sensors	S	R	M	1, 2, 3, 4
2. Diesel Generators Start and Load Shedding Timer	N.A.	R	N.A.	1, 2, 3, 4
3. SI/Degraded Voltage Logic Timer	N.A.	R	N.A.	1, 2, 3, 4

\*NOTE: This technical specification is to be implemented during the startup following the 1st refueling outage.

TABLE 4.3-2 (Continued)

ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION  
SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>MODES FOR WHICH SURVEILLANCE IS REQUIRED</u>
8. ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INTERLOCKS				
a. Pressurizer Pressure, P-11	N.A.	R (2)	N.A.	1, 2, 3
b. T <sub>avg</sub> , P-12	N.A.	R (2)	N.A.	1, 2, 3
c. Steam Generator Level, P-14	N.A.	R (2)	N.A.	1, 2
9. AUTOMATIC SWITCHOVER TO CONTAINMENT SUMP				
a. RSWT Level - Low COINCIDENT WITH Containment Sump Level - High AND Safety Injection	S	R	M	1, 2, 3, 4
	S	R	M	1, 2, 3, 4
	(See 1 above for all Safety Injection Surveillance Requirements)			
b. Automatic Actuation Logic	N.A.	N.A.	M(1)	1, 2, 3, 4

SEQUOYAH - UNIT 2

3/4 3-38

Amendment No. 29, 55