



South Carolina Electric & Gas Company
P.O. Box 88
Jenkinsville, SC 29065
(803) 345-4001

John L. Skolds
Senior Vice President
Nuclear Operations

September 20, 1994
Refer to: RC-94-0248

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Attention: Mr. G. F. Wunder

Gentlemen:

Subject: VIRGIL C. SUMMER NUCLEAR STATION
DOCKET NO. 50/395
OPERATING LICENSE NO. NPF-12
REVISION TO TSP 930019 -
CHARGING PUMP RUNOUT FLOW LIMIT

On March 11, 1994, South Carolina Electric & Gas Company (SCE&G) submitted a Technical Specification Change Request (TSCR) for Section 4.5.2.h.1. This TSCR proposed an increase in the charging pump runout flow limit from 680 gpm to 700 gpm based on pump testing performed in the Spring of 1993. The change allows an increase in the system's operating margin by providing a greater difference between minimum and maximum flow limits.

On September 1, 1994, a telecon was held with the NRC (Mr. George Wunder and Mr. Frank Orr) to discuss the charging pump test results. The NRC stated that they could not support the increase in pump runout to 700 gpm since pump "C" was not tested to that value. The NRC indicated willingness to accept a TSCR for up to 688 gpm. SCE&G agreed to resubmit the TSCR page reflecting a pump runout limit of 688 gpm. The NRC stated that once "C" pump is tested to 700 gpm, SCE&G can request the higher runout limit. SCE&G also noted that the Small Break Loss of Coolant Accident analysis results submitted on March 11, 1994, are not affected by a change in pump runout to 688 gpm. In addition, this revision does not affect the safety evaluation and no significant hazards determination previously submitted for this TSCR.

Accordingly, SCE&G submits the attached, revised Technical Specification page 3/4 5-6 which reflects a change to the charging pump runout limit to 688 gpm.

I declare that the statements and matters set forth herein are true and correct to the best of my knowledge, information, and belief.

If you have any questions, please contact April Rice at (803) 345-4232.

Very truly yours,

John L. Skolds

ARR/JLS/nkk
Attachment

c: See Page 2



9409300159 940920
PDR ADDCK 05000395
PDR

ADD

c: O. W. Dixon
R. R. Mahan (w/o attachments)
R. J. White
S. D. Ebnetter
NRC Resident Inspector
J. B. Knotts Jr.
M. K. Batavia
J. J. Nesbitt
L. R. Cartin
R. B. Clary
NSRC
Central File System
RTS (TSP 930019, REM 6000-10)
File (810.39, 813.20)