VIRGINIA POWER COMPANY

NORTH ANNA POWER STATION

MONTHLY OPERATING REPORT

January MONTI

1988 YEAR

APPROVED:

880131 8802180297 800217 PDR ADOCK 05000338 R DCD

## OPERATING DATA REPORT

DOCKET NO. 50-338

DATE 02-01-88

COMPLETED BY Brenda Garner
TELEPHONE 703) 894-5151 X2527

## OPERATING STATUS

1.	Unit Name: North Anna 1			
2.	Reporting Period: January 1988			
3.	Licensed Thermal Power (MWt):	2893		
4.	Nameplate Rating (Gross MWe):	947		
5.	Design Electrical Rating (Net MWe):	907		
6.	Maximum Dependable Capacity (Gross MWe):	963		
7.	Maximum Dependable Capacity (Net MWe):	915		
8.	If Changes Occur in Capacity Ratings (It Give Reasons:		u 7) Since Last Re	port,
	N/A			
9.	Power Level To Which Restricted, If Any	(Net MWe):	N/A	
10.	Reasons For Restrictions, If Any:		N/A	
		Th/- V	Y- t- D-t-	
11.	Hours In Reporting Period	This Month	Yrto-Date	Cumulative
12.	Number of Hours Reactor Was Critical	744 256.2	744	84,252
13.	Reactor Reserve Shutdown Hours	27.6	256.2	58,456.1
14.	Hours Generator On-Line	172.7	27.8	6,302.3
15.	Unit Reserve Shutdown Hours	0	172.7	55,924.9
16.	Gross Thermal Energy Generated (MWH)	497,018	WATER CONTRACTOR CONTR	0
17.	Gross Electrical Energy Generated (MWH)	161,825	497,018	146,669,673
18.	Net Electrical Energy Generated (MWH)	153,512	161,825	48,065,717
19.	Unit Service Factor		153,512	45,448,106
20.	Unit Availability Factor	23.2	23.2	66.4
21.	Unit Capacity Factor (Using MDC Net)	23.2	23.2	66.4
22.		22.6	22.6	55.8
23.	Unit Capacity Factor (Using DER Net) Unit Forced Outage Rate	22.7	22.7	59.5
24.		76.8	76.8	15.8
64.	Shutdowns Scheduled Over Next 6 Months	(Type, Date,	and Duration of Eac	ch):
		Later Terr		
25. 26.	If Shut Down At End Of Report Period, E. Units In Test Status (Prior to Commercial	al Operation):		bruary 5, 1988
		1	Forecast	Achieved
	INITIAL CRITICALITY			
	INITIAL ELECTRICITY			
	COMMERCIAL OPERATION			-
			-	-

## AVERAGE DAILY UNIT POWER LEVEL

		DOCKET NO. 50-338	
		UNIT NA-1	
		DATE 02-01-88	
		COMPLETED BY Brenda Garne	r
		TELEPHONE 703-894-5151	X2527
MONTH	January 1988		
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY AVERAGE DAILY POWER (MWe-Net)	LEVEL
1	917	17 0	
2	916	180	
3	916	190	-
4	855	200	
5	799	210	
6	898	220	
7	920	230	
8	177	240	
9	0	250	-
10	0	260	
11	0	270	
12	0	280	
13	0	290	
14	0	300	
15	0	310	
16	0		

### INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawart.

Page	1	of	1

#### UNIT SHUTDOWN AND POWER REDUCTIONS

EXPLANATION SE	EET DOCKET	NO.	50	-338
REPORT MONTH	January	UNIT	NAME _	NA-1
YEAR	1988	DATE	02	-01-88
cc	MPLETED BY	Brei	nda Gar	ner

- 88-01 1) January 8, 1988, at 0438 reactor manually tripped from 100% power 968 MW, due to loss of circulating water pumps. Repairs were completed and Unit returned on line January 13, 1988 at 0307.
- January 13, 1988 at 0313, reactor trip occurred at 100 MW 15% power, due to Hi Hi level on "B" steam generator. Corrective action was taken and January 13, 1988 at 1125 reactor was taken critical. Approximately eight hours later, the reactor was manually shutdown due to resin intrusion in the steam generator. Ended the month with Unit in Mode 5, repairing the 1-RC-P-1A reactor coolant pump seal and flushing the steam generator after powdex resin intrusion. Approximately February 5, 1988, the Unit will return on line.

#### UNIT SHUTDOWNS AND POWER REDUCTIONS DOCKET NO. 50 - 338UNIT NAME North Anna 1 DATE 02-01-88 REPORT MONTH January COMPLETED BY Brenda Carner TELEPHONE (703) 894-5151 X2527 Duration Reason<sup>2</sup> Method of Licensee System Component Cause & Corrective Code 5 (Hours) Shutting Code 4 Event Action to Down Reactor Report # Prevent Recurrence 88-01 880108 118.5 Α LER-N1-88-002 KE P Reactor manually tripped from 100% power, due to loss of circulating water pumps. Unit returned on line January 13. 1988 at 0307. 88-02 880113 452.8 H 3 LER-N1-88-005 SG Reactor trip occurred at 15% power, due to Hi Hi level on "B" steam generator. Reactor taken critical at 1125. A LER-N1-88-004 KD N/A Approximately eight hours later at 1916 the reactor was manually shutdown due to resin intrusion in the steam generator. Ended the month with Unit in Mode 5. Approximately February 5, 1988 Unit will return on line. 3 F: Forced Reason: Method: Exhibit F - Instructions A-Equipment Failure (Explain) S: Scheduled 1-Manual for Preparation of Data B-Maintenance or Test 2-Manual Scram. Entry Sheets for Licensee C-Refueling 3-Automatic Scram Event Report (LER) File D-Regulatory Restriction 4-Continuations (NUREG-0161) E-Operator Training & License Examination 5-Load Reduction F-Administrative 9-Other G-Operational Error (Explain)

Exhibit H - Same Source

H-Other (Explain)

### NORTH ANNA POWER STATION

UNIT	NO.	1

MONTH January

## SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reductions or resulted in significant non-load related incidents.

DATE	TIME	DATA
January 1, 1988	0000	Began the month with the Unit at 968 MW - $100\%$ power.
January 4, 1988	1103	Commenced rampdown of 100 MW, to perform work on "A" waterbox.
	1158	Unit holding at 868 MW - 89% power, to perform work on "A" waterbox.
January 6, 1988	0340	Commenced ramp up to 98% power, repairs completed on "A" waterbox.
	0445	Unit holding at 950 MW - 98% power, for 1-PT-24 calorimetric.
	0455	Commenced ramp up to 100% power, 1PT-24 calorimetric completed.
	0518	Unit stabilized at 965 MW - 100% power.
January 8, 1988	0438	Reactor manually tripped from 100% power - 968 MW, due to loss of circulating water pumps.
January 9, 1988	2332	Reactor critical.

## NORTH ANNA POWER STATION

U	NIT	NO. 1	_
HTHOM		January	
SUMMARY	OF	OPERATING	EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reductions or resulted in significant non-load related incidents.

DATE			TIME	DATA
January	13,	1988	0307	Unit on line.
January	13,	1988	0313	Reactor trip occurred at 100 MW - 15% power, due to Hi Hi level on "B" steam generator.
			1125	Reactor critical.
			1916	Reactor manually shutdown, due to resin intrusion in the steam generator.
January	31,	1988	2400	Ended the month with Unit in Mode 5, repairing 1-RC-P-1A reactor coolant pump seal and flushing the steam generator after powdex resin intrusion. Approximately February 5, 1988, the Unit will return on line.

#### OPERATING DATA REPORT

DOCKET NO.

COMPLETED BY

DATE

50-339

02-01-88

Brenda Garner

TELEPHONE 703) 894-5151 X2527 OPERATING STATUS Unit Name: North Anna 2 2. Reporting Period: January 1988 Licensed Thermal Power (MWt): 2893 4. Nameplate Rating (Gross MWe): 947 5. Design Electrical Rating (Net MWe): 907 6. Maximum Dependable Capacity (Gross MWe): 963 7. Maximum Dependable Capacity (Net MWe): 915 8. If Changes Occur in Capacity Ratings (Items No. 3 thru 7) Since Last Report, Give Reasons: N/A 9. Power Level To Which Restricted, If Any (Net MWe): N/A 10. Reasons For Restrictions, If Any: This Month Yr.-to-Date Cumulative 11. Hours In Reporting Period 744 744 62,520 12. Number of Hours Reactor Was Critical 744 744 49,212.3 13. Reactor Reserve Shutdown Hours 0 0 5,653 14. Hours Generator On-Line 744 744 48,400 15. Unit Reserve Shutdown Hours 0 0 16. Gross Thermal Energy Generated (MWH) 2,151,711 2,151,71 126,470,492 17. Gross Electrical Energy Generated (MWH) 41,921,716 716,595 716,595 18. Net Electrical Energy Generated (MWH) 681,949 681,949 39,740,296 19. Unit Service Factor 100.0 100.0 77.4 20. Unit Availability Factor 100.0 100.0 77.4 21. Unit Capacity Factor (Using MDC Net) 100.2 100.2 64.3 22. Unit Capacity Factor (Using DER Net) 101.1 101.1 70.1 23. Unit Forced Outage Rate 0 0 9.1 24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): 25. If Shut Down At End Of Report Period, Estimated Date of Startup: 26. Units In Test Status (Prior to Commercial Operation): Forecast Achieved INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION

## AVERAGE DAILY UNIT POWER LEVEL

		DOC	KET NO.	50-339
			UNIT	NA-2
			DATE	02-01-88
		COMPL	ETED BY	Brenda Garner
		TE	LEPHONE	703-894-5151X2527
MONTH	January 1988			
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE	DAILY POWER LEVEL (MWe-Net)
1	919	17		918
2	917	18		918
3	910	19		917
4	919	20		917
5	919	21		917
6	920	22		917
7	920	23		917
8	919	24		916
9	919	25		915
10	918	26		914
11	919	27		915
12	919	28		913
13	917	29		912
14	917	30		911
15	918	31	CONTRACTOR DESCRIPTION AND ADDRESS OF THE PARTY OF THE PA	911
16	918			

## INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

		Page _	1 (	of _1	
UNIT SHO	TTOWN AN	ND POWE	R REDU	CTIONS	
EXPLANATION SE	IEET	DOCKET	NO.	50-	-339
REPORT MONTH	Janua	ry	UNIT	NAME _	NA-2
YEAR	1988		DATE	02-	-01-88
CO	MPLETED	BY	Brer	da Garr	ner

No entry this month.

#### UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-339 UNIT NAME North Anna 1 DATE 02-01-88 COMPLETED BY Brenda Garner

REPORT MONTH January

TELEPHONE

(703) 894-5151 X2527

Type Duration Reason Z (Hours)

Method of Shutting Down Reactor

Licensee Event Report #

System Code 4

Code 5

Component Cause & Corrective Action to Prevent Recurrence

No entry this month.

F: Forced S: Scheduled

Reason:

A-Equipment Failure (Explain)

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training & License Examination 5-Load Reduction

F-Administrative

G-Operational Error (Explain)

H-Other (Explain)

Method:

1-Manual 2-Manual Scram.

3-Automatic Scram

4-Continuations

9-Other

Exhibit F - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

Exhibit H - Same Source

# NORTH ANNA POWER STATION

UNI	T	NO.	2
			the season season season

MONTH January

# SUMMARY OF OPERATING EXPERIENCE

Listed below in chronological sequence is a summary of operating experiences for this month which required load reductions or resulted in significant non-load related incidents.

DATE			TIME	DATA
January	1,	1988	0000	Began the month with the Unit at 961 MW - $100\%$ power.
January	2,	1988	2325	Commenced rampdown of 100 MW, to perform Turbine Valve Freedom Test.
January	3,	1988	0011	Unit holding at 865 MW - 89% power, to perform Turbine Valve Freedom Test.
			0150	Commenced ramp up to 100% power, Turbine Valve Freedom Test completed.
			0220	Unit stabilized at 960 MW - 100% power.
January :	31,	1988	2400	Ended the month with Unit at 958 MW 100% power.

## VIRGINIA ELECTRIC AND POWER COMPANY RICHMOND, VIRGINIA 23261

W. L. STEWART VICE PRESIDENT NUCLEAR OPERATIONS

February 11, 1988

U.S. Nuclear Regulatory Commission Attention: Document Control Desk Washington, D.C. 20555

Serial No. 88-062 NO/DJV:jmj Docket Nos. 50-338 50-339 License Nos. NPF-4 NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY NORTH ANNA POWER STATION UNITS 1 AND 2 MONTHLY OPERATING REPORT

Enclosed is the Monthly Operating Report for North Anna Power Station Units 1 and 2 for the month of January 1988.

Very truly yours,

W. L. Stewart

Enclosures

cc: U.S. Nuclear Regulatory Commission 101 Marietta Street, NW Suite 2900 Atlanta, GA 30323

> Mr. J. L. Caldwell NRC Senior Resident Inspector North Anna Power Station

> > IE24