

FEB 11 1988

Docket No. 50-254
Docket No. 50-265

Commonwealth Edison Company
ATTN: Mr. Cordell Reed
Senior Vice President
Post Office Box 767
Chicago, IL 60690

Gentlemen:

Thank you for your letter of January 22, 1988, in response to our inspection reports 50-254/87030 and 50-265/87030 for the Quad Cities facility. After our review of your response, and the telephone conversations between Messrs. F. Jablonski and T. Tella of our staff and Mr. L. Butterfield of your staff on February 9 and 10, 1988, the following was determined:

1. We concluded and you agreed that the violation is valid. The basis for our determination is that computer programs "ANOM" and "ANOMUP" in use since 1981 did not appear to be adequately controlled to preclude temporary or permanent changes to the software.
2. Based on your response and other data which you provided, we are satisfied that programs "ANOM" and "ANOMUP" were developed and validated using Quad Cities Station Procedure QTP 1113-2.
3. It is our understanding that you will validate current results of computer programs "ANOM" and "ANOMUP", and also verify by hand calculations the accuracy of results obtained since 1981.

We will review results of your actions taken, and those to correct the violation and prevent recurrence during a future inspection of the Quad Cities facility. Thank you for your cooperation.

Sincerely,

J. J. Harrison, Chief
Engineering Branch

See Attached Distribution

RIII

Tella/jk
02/10/88

RIII^{yes}
ack for
Ring
02/11/88

RIII

Jablonski
02/11/88

RIII
JH
Harrison
02/11/88

yes

8802190020 830211
PDR ADOCK 05000254
Q DCD

FEB 11 1988

Distribution

cc: D. Butterfield, Nuclear
Licensing Manager
R. L. Bax, Plant Manager

cc w/ltr dtd 1/22/88:
DCD/DCB (RIDS)
Licensing Fee Management Branch
Resident Inspector, R111
Richard Hubbard
J. W. McCaffrey, Chief, Public
Utilities Division