



Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61727
Tel 217 935-6220
Fax 217 935-4632

Wayne D. Romberg
Assistant Vice President - Nuclear

U-602783

2C.220

July 16, 1997

Docket No. 50-461

10CFR50.73

Document Control Desk
Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: Clinton Power Station - Unit 1
Licensee Event Report No. 97-016-00

Dear Madam or Sir:

Enclosed is Licensee Event Report (LER) No. 97-016-00: Failure to Provide Emergency Lighting for Safe Shutdown Equipment as Required by the Plant Design Basis. This report is being submitted in accordance with the requirements of 10CFR50.73.

The enclosure to this letter contains the following commitments:

- A modification will be installed, prior to plant startup from the current refueling outage, to de-energize valve 1E12-F006B during power operation (i.e., modes 1, 2, and 3 with reactor pressure greater than approximately 97 psig).
- Administrative controls will be established to ensure valve 1E12-F006B is kept de-energized when required.

Sincerely yours,

Wayne D. Romberg
Assistant Vice President

MRS/krk

Enclosure



9707240162 970716
PDR ADOCK 05000461
S PDR

1/1
JL22

cc: NRC Clinton Licensing Project Manager
NRC Resident Office, V-690
Regional Administrator, Region III, USNRC
Illinois Department of Nuclear Safety
INPO Records Center