



A Centerior Energy Company

EDISON PLAZA
300 MADISON AVENUE
TOLEDO, OHIO 43652-0001

July 15, 1997

Ms. Elizabeth Wick, Group Leader
Ohio Environmental Protection Agency
Northwest District Office
347 North Dunbridge Road
Bowling Green, Ohio 43402

Dear Ms. Wick:

Subject: Submittal of the June 1997 Telecommunicated Hardcopy Wastewater
Report

Attached is a hardcopy of the telecommunicated June 1997 Wastewater Report for the
Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1, Permit Number
2IB00011*FD.

If you have any questions, please contact Mr. James L. Freels,
Manager - Regulatory Affairs, at (419) 321-8466.

Sincerely yours,

James H. Lash
Plant Manager
Davis-Besse Nuclear Power Station

AMP/lkm

Attachments

cc: Z. A. Clayton, Ohio Environmental Protection Agency
U. S. Nuclear Regulatory Commission Document Control Desk

1/1
Le 25

9707240260 970630
PDR ADOCK 05000346
R PDR



TOLEDO EDISON/DAVIS-BESSE

2IB00011001 JUN 1997

1 1 07/09/97 2IB00

300 MADISON AV. MSTOP 2101 001 DISCHARGE TO LAKE ERIE
TOLEDO 43652 OTTAWA

FORM

TOLEDO EDISON

A. M. Percival

	1 999	3 001	1 999	3 001	3 001
	WATER TEMP. F	PH S.U.	CONDUI FLOW MGD	CHLORI TOT RE MG/L	COPPER TOT RE UG/L
	00011	00400	50050	50060	01119
01	64.3	AN	26.6	AN	
02	63.2	8.7	29.7	AA	
03	62.0	8.7	32.7	AA	
04	62.2	8.6	28.2	AA	
05	64.3	8.6	26.4	AA	
06	65.3	8.6	26.5	AA	
07	65.8	AN	26.9	AN	
08	65.6	AN	26.6	AN	
09	66.4	8.7	26.9	AA	
10	67.8	8.7	27.2	AA	
11	68.8	8.7	26.8	AA	
12	68.3	8.7	28.2	AA	
13	69.1	8.7	28.0	AA	
14	68.8	AN	28.1	AN	
15	69.4	AN	28.5	AN	
16	71.2	8.8	28.8	AA	AA
17	69.7	8.7	28.8	AA	
18	70.0	8.6	28.1	AA	
19	71.4	3.6	28.1	AA	
20	73.9	8.8	28.1	AA	
21	74.9	AN	28.5	AN	
22	75.2	AN	25.3	AN	
23	75.4	8.6	28.2	AA	
24	78.3	8.7	27.4	AA	
25	79.4	8.7	29.5	AA	
26	77.5	8.6	29.8	AA	
27	77.1	8.6	30.0	AA	
28	77.7	AN	30.0	AN	
29	78.7	AN	31.7	AN	
30	79.2	8.6	30.5	AA	
31					
	2120.9	182.00	850.10	AA	AA
	70.697	8.6667	28.337	AA	AA
	79.400	8.8000	32.700	AA	AA
	62.000	8.6000	25.300	AA	AA

Copper detection limit is 20 ug/L.
Total residual chlorine limit is 0.05mg/L.

REPORTER

7/16/97

COMPLETED

REPORTER

AH Clark

PLANT MANAGER

2IB00011001



TOLEDO EDISON/DAVIS-BESSE

2IB00011003 JUN 1997

1 1 07/09/97 2IB000

300 MADISON AV. MSTOP 2101 003 OUTFALL NAVARRE MARSH
TOLEDO 43652 OTTAWA

FORM

TOLEDO EDISON

A. M. Percival

3 1
001 999

RESIDU CONDUI
TOT NF FLOW
MG/L MGD

00530 50050

01	.222
02	.222
03	.222
04	.222
05	.222
06	.222
07	.222
08	.222
09	.222
10	.222
11	.222
12	.222
13	.222
14	.222
15	.222
16	.222
17	.222
18	.222
19	.222
20	.222
21	.222
22	.222
23	.222
24	.222
25	.222
26	.222
27	.222
28	.222
29	.222
30	.222
31	.222

65.000 6.6600
65.000 0.2220
65.000 0.2220
65.000 0.2220

REPORTER

7/16/97

Handwritten signature

PLANT MANAGER

2IB00011003



TOLEDO EDISON/DAVIS-BESSE 2IB00011601 JUN 1997 1 1 07/09/97 2IB000

300 MADISON AV. MSTOP 2101 601 DISCHARGE STP
TOLEDO 43652 OTTAWA

FORM

TOLEDO EDISON

A. M. Percival

3 3 3 1 3 3 3
001 001 001 999 001 001 001

COLOR SEVERI UNITS ODOR SEVERI UNITS TURBID SEVERI UNITS CONDUI FLOW MGD BOD 5 DAY MG/L RESIDU TOT NF MG/L CHLORI TOT RE MG/L

00083 01330 01350 50050 00310 00530 50060

01	AN	AN	AN	.019			
02	1	1	1	.019			
03	1	1	1	.028	AA		
04	1	1	1	.028		4	
05	1	1	1	.028			
06	1	1	1	.017			
07	AN	AN	AN	.011			
08	AN	AN	AN	.011			
09	1	1	1	.011			AA
10	1	1	1	.021	AA		
11	1	1	1	.021		4	
12	1	1	1	.021			
13	1	1	1	.018			
14	AN	AN	AN	.008			
15	AN	AN	AN	.008			
16	1	0	1	.011			AA
17	1	0	1	.011	5		
18	1	0	1	.011		5	
19	1	0	1	.010			
20	1	0	1	.010			
21	AN	AN	AN	.010			
22	AN	AN	AN	.010			
23	2	1	2	.010	25		AA
24	2	1	2	.008			
25	2	1	2	.008		2	
26	2	1	2	.008			
27	2	1	2	.008			
28	AN	AN	AN	.008			
29	AN	AN	AN	.008			
30	1	1	0	.008			AA
31							

26.000 16.000 25.000 0.4080 30.000 15.000 AA
 1.2381 0.7619 1.1905 0.0136 7.5000 3.7500 AA
 2.0000 1.0000 2.0000 0.0280 25.000 5.0000 AA
 1.0000 0.0000 0.0000 0.0080 AA 2.0000 AA

BOD detection limit is 4 mg/L.
Total residual chlorine detection limit is 0.05 mg/L.

REPORTER

7/11/07

COMPLETED

H. Christ

REPORTER

Plant Manager

2IB00011601



TOLEDO EDISON/DAVIS-BESSE

2IB00011801 JUN 1997

1 1 07/09/97 2IB000

300 MADISON AV. MSTOP 2101 801 INTAKE PRIOR COOLING OPERATION
TOLEDO 43652 OTTAWA

FORM

TOLEDO EDISON

A. M. Percival

1
999

WATER
TEMP.
F

00011

01	57.9
02	57.1
03	57.1
04	56.9
05	57.4
06	57.9
07	59.5
08	59.7
09	60.7
10	61.3
11	61.0
12	61.2
13	61.9
14	63.4
15	65.2
16	65.7
17	65.7
18	65.6
19	65.3
20	66.3
21	68.2
22	70.2
23	70.2
24	71.8
25	72.7
26	73.4
27	73.8
28	74.2
29	74.8
30	75.1
31	

1951.2
65.040
75.100
56.900

REPORTER

7/16/97

A. M. Percival

PLANT MANAGER

1 1 07 09 97 2IB00011801

2IB00011801

