

July 17, 1997

LICENSEE: Union Electric Company

FACILITY: Callaway Plant, Unit 1

SUBJECT: MEETING WITH UNION ELECTRIC COMPANY AND FRAMATOME TECHNOLOGIES REGARDING INSTALLATION OF FRAMATOME ELECTROSLEEVEES IN THE CALLAWAY PLANT, UNIT 1 STEAM GENERATORS

On May 13 through 15, 1997, a meeting was held with Union Electric Company (UEC), Framatome Technologies, Inc. (FTI), and the Nuclear Regulatory Commission (NRC) staff, at FTI, Lynchburg, Virginia, to discuss the FTI steam generator electrosleeving process. The FTI electrosleeving process is being reviewed by the staff as part of a UEC Technical Specification Amendment request that would allow installation of FTI electrosleeves in the Callaway Plant, Unit 1 steam generators.

The focus of the meeting was the review of analysis methods and ultrasonic testing equipment pertaining to FTI's electrosleeving process.

Attachment 1 is the list of attendees. Attachment 2 is the nonproprietary version of the handout material presented at the meeting.

ORIGINAL SIGNED BY

Barry C. Westreich, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Attachments: 1. List of Meeting Attendees  
2. Meeting Slides  
(nonproprietary version)

DISTRIBUTION: (w/atts 1 and 2)  
Docket File PDIV-2 Reading  
PUBLIC OGC  
ACRS WJohnson, RIV  
PGWynn, RIV

cc w/atts: See next page

DISTRIBUTION: (w/att 1)  
SCollins (SJC1) KThomas (KMT)  
FMiraglia (FJM) EPeyton (ESP)  
RZimmerman (RPZ) CBeardslee (CDB)  
JRoe (JWR) GHornseth (GPH)  
EAdensam (EGA1) TSullivan (EJS)  
WBateman (WHB) JStrosnider (JRS2)

DOCUMENT NAME: CALFTI.MTS \*See Previous Concurrence

OFC	PDIV-2/PM	PDIV-2/LA	NRR:EMCB*
NAME	BWestreich:ye	EPeyton	JStrosnider
DATE	7/17/97	7/18/97	5/28/97

OFFICIAL RECORD COPY

9707240303 970717  
PDR ADOCK 05000483  
P PDR

**NRC FILE CENTER COPY**



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

July 17, 1997

LICENSEE: Union Electric Company  
FACILITY: Callaway Plant, Unit 1  
SUBJECT: MEETING WITH UNION ELECTRIC COMPANY AND FRAMATOME TECHNOLOGIES  
REGARDING INSTALLATION OF FRAMATOME ELECTROSLEEVES IN THE CALLAWAY  
PLANT, UNIT 1 STEAM GENERATORS

On May 13 through 15, 1997, a meeting was held with Union Electric Company (UEC), Framatome Technologies, Inc. (FTI), and the Nuclear Regulatory Commission (NRC) staff, at FTI, Lynchburg, Virginia, to discuss the FTI steam generator electrosleeving process. The FTI electrosleeving process is being reviewed by the staff as part of a UEC Technical Specification Amendment request that would allow installation of FTI electrosleeves in the Callaway Plant, Unit 1 steam generators.

The focus of the meeting was the review of analysis methods and ultrasonic testing equipment pertaining to FTI's electrosleeving process.

Attachment 1 is the list of attendees. Attachment 2 is the nonproprietary version of the handout material presented at the meeting.

A handwritten signature in black ink, appearing to read "B. Westreich", written over a horizontal line.

Barry C. Westreich, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

Docket No. 50-483

Attachments: 1. List of Meeting Attendees  
2. Meeting Slides  
(nonproprietary version)

cc w/atts: See next page

cc w/atts:

Professional Nuclear  
Consulting, Inc.  
19041 Raines Drive  
Derwood, Maryland 20855

Gerald Charnoff, Esq.  
Thomas A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Mr. H. D. Bono  
Supervising Engineer,  
Site Licensing  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

U.S. Nuclear Regulatory Commission  
Resident Inspector Office  
8201 NRC Road  
Steedman, Missouri 65077-1302

Mr. J. V. Laux, Manager  
Quality Assurance  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

Manager - Electric Department  
Missouri Public Service Commission  
301 W. High  
Post Office Box 360  
Jefferson City, Missouri 65102

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
Harris Tower & Pavilion  
611 Ryan Plaza Drive, Suite 400  
Arlington, Texas 76011-8064

Mr. Ronald A. Kucera, Deputy Director  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, Missouri 65102

Mr. Otto L. Maynard  
President and Chief Executive Officer  
Wolf Creek Nuclear Operating Corporation  
P.O. Box 411  
Burlington, Kansas 65839

Mr. Dan I. Bolef, President  
Kay Drey, Representative  
Board of Directors Coalition  
for the Environment  
6267 Delmar Boulevard  
University City, Missouri 63130

Mr. Lee Fritz  
Presiding Commissioner  
Callaway County Court House  
10 East Fifth Street  
Fulton, Missouri 65151

Mr. Alan C. Passwater, Manager  
Licensing and Fuels  
Union Electric Company  
Post Office Box 66149  
St. Louis, Missouri 63166-6149

Mr. Garry L. Randolph  
Vice President - Chief Nuclear Officer  
Union Electric Company  
Post Office Box 620  
Fulton, Missouri 65251

ATTENDEES AT MEETING ON MAY 13-15, 1997  
ELECTROBLEEDING OF STEAM GENERATOR TUBES

Union Electric Company

E. Kahl  
T. Herrmann

Framatome Technologies, Inc.

S. Wilson  
R. Pugh  
R. Schaefer

Duquesne Light Company

G. Kammerdeiner

NRC

C. Beardslee  
G. Hornseth

## NRC Meetings/RAIs

- Union Electric Tech Spec, April 12, 1996
- Topical overview with NRC May 28, 1996
- Demonstration in Lynchburg, July 2, 1996
- Presentation Material as RAI, July 18, 1996
- BG&E Tech Spec, July 26, 1996
- RAI Response, September 24, 1996
- HL&P Tech Spec, October 28, 1996
- UT Qual. Presentation , January 15, 1997
- Response to RAI on UT, February 5, 1997
- Maine Yankee Tech Spec, March 5, 1997
- Duquesne Light Co. Tech Spec, March 10, 1997
- NRC Meeting, Maine Yankee UT Issues, March 26, 1997
- NRC Telecon, NDE/UT Review, April 14, 1997
- NRC RAI, 10 Questions, April 28, 1997
- NRC Visited OHT, May 6 - 7, 1997
- NRC Visit, NDE Discussion, FTI, May 13 - 15, 1997


Non-Proprietary Version

# Development of Electro sleeving as a Tube Repair for Pickering NGS 'B'

A. Brennenstuhl - Presented May 6/97 at OHT to U.S.A. NRC Staff

Page 1 of 40

NON-PROPRIETARY



**NON-PROPRIETARY**

# Description of PNGS SG's

- 4 unit station - 500 Mw
- 12 SG/unit - 2753 tubes
- Alloy 400 - 1/2" OD

## SG Design parameters

### PRIMARY SIDE

- Pressure 1450 psig
- Temperature 521 F

### SECONDARY SIDE

- Pressure 800 psig
- Temperature 521 F



# Description of PNGS SG's

(cont'd)

- SG - Operating Conditions

## PRIMARY SIDE

- D<sub>2</sub>O - pH 10.5 (LiOH)
- H<sub>2</sub> - 20 cc/kg

## SECONDARY SIDE


- Cu bearing feedtrain
- Mechanical de-aeration
- Morpholine/hydrazine treatment
- ph - (8.5 - 9.5) 9.2

- SG - Radiation Fields


- Operation 200 R/hr
- Shutdown ~ 300 mR/hr

## **Background**

- Pickering NGS "B"
- Unit 5 - SG tube leaks (1992)
- Localized attack
- High degree of fouling
- Operating chemistry practices
- Additional leaks - Units 5 and 6
- Large # of tubes plugged
- Need to de-rate




OD pit in the 'B' Monel 400




Cross-section through the pit in the 'B' alloy.



Detail of the degradation inside the pit, metal loss appears to be partly due to intergranular Corrosion.



## Conventional Kinetically Bonded Sleeves



## Electroformed Integral Sleeves



## Results

- Total of 46 electro sleeves
- 28 Witness
- 18 In-steam generator
- 44 sleeves acceptable (95% success rate)
- 2 dispositioned (<5% total sleeved area disbonded)
- Witness samples were tested and met or exceeded mechanical and chemical requirements
- The remaining 14 in-steam generator sleeves possessed required properties for satisfactory service performance
- 14 electro sleeves have been in steam generator for 1 year and upon re-inspection have been found acceptable

after 1 yr

## General Corrosion Testing

- ASTM G28 - "Susceptibility to JGA"
  - *No cracking*
- ASTM G35 - "Susceptibility to SCC-Polythionic"
  - *No cracking*
- ASTM G36 - "Susceptibility to SCC-Mg Cl<sub>2</sub>"
  - *No cracking*
- ASTM G44 - "Susceptibility to SCC-NaCl"
  - *No cracking*
- ASTM G48 - "Susceptibility to pitting & crevice"
  - *No pitting*
  - *Slight C.C.*

# Why 'Electrosleeve' M400 Boiler Tubes

1. Corrosion Damaged Tubes
  - Under-deposit pitting
  - Caused by aggressive ( $\text{Cl}^-$ ,  $\text{SO}_4^{2-}$ ) ion impurities, oxidizers
  - Leaks  $\rightarrow$  forced outages
2. Life Management Remedial Measures
  - Cleaning
  - Cu removal
  - Optimized water chemistry
  - Enhanced inspection
  - 'cannot guarantee long life for all boiler tubes'
3. Options
  - Tube plugging
  - Reduce power
  - Replace boilers
  - Repair tubes



# Why 'Electrosleeve' M400 Boiler Tubes

(cont'd)

4. Conventional Repair
  - 'Welded' sleeves (fusion, kinetic)
  - Established technology for (Fe-Ni-Cr) alloys
  - No experience with M400
5. Conventional Sleeving of M400
  - Kinetic: tube bulging, grain growth
  - Welding: burn-through, coring
  - Dissimilar metal welding: heterogeneity
  - Natural crevice formed: crevice corrosion
6. Pickering Monel Experience
  - P-A: 20 years service - (no serious degradation)
  - P-B: 6 years service - (leaks due to UDC)
  - UDC: deposits (CPT)
    - : lake water contaminants
    - : oxidizing conditions
    - : alloy corrosion resistance

A. International Mfg. Co.

## Advantages of Electro sleeving

- Electro sleeving can be done on small diameter tubing (1/2") as well as larger tubing.
- Electro sleeving has no adverse physical effects on tubes being sleeved (benign process).
- Electro sleeving is a continuous bond process, leaving no crevice at the ends of the sleeve between the tube and the sleeve and is therefore not vulnerable to crevice corrosion (smooth transition).
- Electro sleeving can be applied beyond (i.e. through) existing sleeves.
- Electro sleeving should be applicable in the U-bends of the tube.
- Electro sleeving can be applied in deformed tubing locations.
- Thinner sleeves can be used as a result of the superior properties of the electroformed material.





Figure 7 Electro sleeved™ specimen supplied by Ontario Hydro using a pure Nickel sleeve. (a,b) OD and ID surface appearance. (c) Optical micrograph of an axial section. Magnification: 50X.



# Structural Integrity of Electroformed Ni Sleeves (Mechanical Properties)

## Microhardness

Monel:

128-132

Ni Electroleeve:

250-400+

## Yield Strength (300°C)

Monel:

< 30 ksi

Ni Electroleeve

> 60 ksi

## Tensile Strength (300°C)

Monel:

< 80 ksi

Ni Electroleeve:

> 100 ksi

## Elongation

Monel:

40%

Ni Electroleeve:

> 15%

## Adhesion (shear)

Failure occurs at Monel

side of couple, not interface

50 ksi

## Fatigue Strength (10<sup>6</sup> cycles)

(In air at 20°)

> 40,000 psi

## Thermal cycling/aging

600 cycles/305°C

NON-PROPRIETARY

# Process Description:

## **Process Description**

- **Electrosleeve™ Technology based on the in-situ electroformation of a full structural/bonded sleeve on the ID of the tube spanning the defect location(s)**
- **Descaling and cleaning are an integral part of the process**









## P8 Trial Objectives

- Develop practical in-situ boiler experience
- Assess quality, reliability, repeatability under field conditions

→ *field harden the process*

- Obtain operating field experience

Determine what can go wrong in field?

## P8 Trial Results

- Installed 3 sets of 4 sleeves in 2 boilers
  - *9 in boiler*
  - *200' from rig*
  - *45' elevation*
- UT inspection capability viable and verified by destructive examinations in lab
- All sleeves were defect free, showed some thickness variation and patches of surface roughness
- Target sleeve thickness (0.018") attained
- Three sleeves were well bonded to the tubes

## What Did We Learn from P8?

- Need to stiffen probe alignment
- Need to improve production rate
- Need to simplify probe installation/removal
- Local post weld heat treatment produced a very stable and adherent surface oxide layer

→ *rigorous honing required*

# P1 Trial Objectives

- To demonstrate production capability
  - *rate*
  - *sleeve quality*
  - *equipment reliability and robustness*
- To validate UT measurements with destructive lab evaluations

## P1 Trial Results

- Installed 2 sets of 4 sleeves in 1 boiler  
Pulled 1 tube containing 1 sleeve from each batch
- Probe installation < 15 min.  
Process time < 6 hrs.
- UT inspection of I/B tubes
  - *good plating uniformity*
  - *defect free*
  - *continuous metallurgical bond in 2nd set*
- Tubing in older generators has a thicker magnetite deposit which is more difficult to remove
- Lab inspection of pulled tube confirmed UT results

## P1 Trial Conclusions

- Sleeve quality such that we could have left the tubes (2nd set) in service
- Process times consistent with production rate requirements for P5
- Tube cleaning requirements for P5 expected to lay between P8 and P1



## Pickering NGS 'B'

### - Electrosleeving Qualification -

- Electrosleeving was qualified as a repair for Pickering NGS Unit 5

- ASME B&PV code was followed

- Testing addressed

- *mechanical properties*

- *corrosion resistance*

- *inspection capability*

- Special approval from MCCR & AECB was obtained to leave electrosleeves<sup>TM</sup> in service

- Large database produced which established variability of critical process parameters

## Electrosleeve Design Requirements

(Qualification Program)

- Produced to ASTM B689, ASTM B322 and ASTM B450
- Chem. comp. (99.5% Ni with Co, Si & C each < 0.01%)
- Dimension, surface finish and deposit character (thickness > 0.012", target 0.018")
- Yield strength (> 60 ksi at RT and 305°C)
- U.T.S. (> 120 ksi at RT and 305°C)
- Elongation (> 10% elongation in bending)
- Hardness (> 200 VHN)
- Adhesion (> 8% tensile elongation)

## Electrosleeve Design Requirements (Qualification Program)

(cont'd)

- Fatigue (high & low cycle endurance  $\geq$  M400 ASME B & PV code, Section III)
- Thermal cycling ( $> 600$  cycles)
- Helium leak test ( $< 10^{-4}$  atm cc/s He with 1 bar He pressure in contact with the external surface at 305°C)
- Corrosion (ASTM G28-85, G35-88, G36-87, G44-88, G48-93, G61-48, capsule tests, refreshed autoclave tests)

# Structural Integrity of Electroformed Ni Sleeves (Corrosion Tests)

## SCC

- ASTM G35 (perchloric acid)
- ASTM G36 (boiling MgCl<sub>2</sub>)
- ASTM G44 (NaCl)
- ASTM G48 (Fe Cl<sub>2</sub>)
- ASTM G61 (cyclic polarization)

## Pitting/Crevices

## IGA

- ASTM G28 (H<sub>2</sub>SO<sub>4</sub> + Fe Cl<sub>2</sub>)

## Capsule

- Excellent resistance to neutral and alkaline environments

## Autoclave

- Excellent resistance to:
  - 1) non-oxidizing low pH environments
  - 2) oxidizing & non-oxidizing neutral environments
  - 3) oxidizing & non-oxidizing caustic environments

# Corrosion Testing

(Secondary Side)

- Sludge & faulted chemistries
  - Bulk fluid
    - Condenser leakage
    - Acid excursion
    - Caustic excursion
  - Sludge
    - $\text{Cl}^-$ ,  $\text{SO}_4^{2-}$ ,  $\text{Na}^+$ ,  $\text{HN}_4^+$ ,  $\text{Cu}^{++}$ , Magnetics
    - 12 combinations tested
- Capsule tests
  - 24 tests
  - Various combinations
    - $\text{C}_{11}\text{Cl}_2$ ,  $\text{NaCl}$ ,  $\text{Na}_2\text{SO}_4$ ,  $\text{NaOH}$ ,  $\text{H}_2\text{SO}_4$ ,  $\text{NH}_3$ ,  $\text{Ph. O}_2$

ION-PROPRIETARY

## P5 Sleeve Qualification

- Chemical composition will be established prior to and after installing each batch of sleeves
- The process parameters will be monitored independently for each sleeve during the installation
- Each sleeve will undergo non-destructive testing to determine the quality of the sleeve and its bond integrity with the host surface
- One witness tube will be produced with each batch of I/B sleeves and will undergo prompt mechanical analysis

## Other Qualifications

- Application to the CSA N285.6 Materials Standards Committee to include micrograin nickel as an alternative Class 1 pressure boundary material.
- Stress/fatigue analysis to demonstrate the sleeved tubes satisfy ASME Boiler and Pressure Vessel Code, Section III for the Design, Normal and Upset and Hydrostatic conditions expected in the boiler.

# Process Qualification

## Purpose:

- To form electrosleeves with reproducible material/corrosion resistance properties
- To eliminate the need to test the sleeves destructively

## Approach

1. To correlate changes in sleeve properties with changes in process parameters.
2. To produce sleeves under QA with fixed process parameters and subject these samples to a broad spectrum of tests using independent and certified facilities.
3. To confirm material properties using one witness sample for every 7 tubes deposited in the boiler.



# Corrosion Tests

## Guiding principles

- Standard ASTM tests selected to simulate expected corrosion conditions in boiler
- Tests selected to accelerate possible corrosion processes using high temperature and aggressive chemical conditions
- Tests to simulate geometry, fouling and thermohydraulic conditions in a S/G

# Corrosion Tests

- Six standard ASTM tests:  
ASTM G28, G35, G36, G44, G48, G61
- 18 high temperature aqueous environmental tests investigating REDOX, stress, & chemistry known to be detrimental to nickel
- Three long term corrosion tests simulating in-boiler conditions
- Sample size
  - standard ASTM test: 20
  - capsule furnace tests: 18
  - refreshed autoclave tests: 9

## **Other P5 Sleeve Qualifications**

- **Operators will be trained and qualified on a full scale prototypic delivery system in accordance with the Sleeving Procedure Document**
- **Consumable supplies will be provided under the CSA Z299.2 QA Program**
- **I/B tube preparation will be in accordance with a qualified honing specification**

## Corrosion Testing (Conclusions)

- Primary side
  - *No attack expected*
- Secondary side
  - *No attack expected*
  - *Acidic & oxidizing caused corrosion*  
*(not expected in S/G)*

# Pickering NGS Unit 5 SG 12 Campaign

- April 25th - May 4th, 1994
- Campaign originally scheduled for 500-600 electrosleeves
- ECT examination results led to a reduced campaign (20 sleeves)
- Two electrosleeving rigs each capable of up to eight electrosleeves was available
- Electrosleeving rig used to half its available capability
- Full scale production of 18 electrosleeves per day
- Witness and in-steam generator electrosleeves were produced

*Non-Proprietary  
Version*



Ontario Hydro  
TECHNOLOGIES

# *Ultrasonic Inspection of Electrosleeves using TRUSTIE*

*D.P.Jansen, W.K.Chan,  
M.D.C.Moles*

*Ontario Hydro Technologies*

*E.Choi, J.Huggins*

*Ontario Hydro Nuclear*

05-97

1

NON-PROPRIETARY

## *The TRUSTIE\* System*

### *Tiny Rotating UltraSonic Tube Inspection Equipment*

- *OHT developed and operated*
- *Designed for 0.5" OD CANDU  
steam generators*
- *External rotary drive / driveshaft*
- *Windows 95 based data  
acquisition and analysis*




## *TRUSTIE Specifications*

- *tube IDs from 0.310" to 1.3"*
- *tube lengths up to 50'*
- *ultrasonic inspection frequencies from 5 to 25 MHz*
- *rotation speeds up to 1000 rpm*
- *typical data collection speeds:*
  - *600 rpm for 4 gate C-scans*
  - *600 rpm for full waveform scans (at 0.2 mm by 1.5 deg. resolution)*
- *U-bend inspection on 16" radius for 0.5" OD tubes*
- *remote operation to 600'*






# System Overview



05-97

# TRUSTIE



05-97

## *Inspection capability*


### ■ *probe types :*

- *normal beam  
(wall thickness/ profilometry)*
- *axial facing shear wave  
(circumferential cracking+ ID  
profilometry)*
- *multiple mode combination (normal  
beam + circ and axial shear waves)*
- *others*

### ■ *analysis methods:*

- *A, B, C and waveform scans*
- *line plots, colour plots, isometrics*
- *echodynamics*
- *integrated signal processing  
(e.g. filtering, spectral analysis)*


# Winspect™



- *integrated motion control, data acquisition and data analysis*



# Electrosleeve Inspection



05-97

## *Inspection Requirements*

### **Nickel sleeve:**

- Thickness > 0.014"
- Defects > 20% TW reported, any defect > 40% TW dispositioned
- Disbonding < 5mm square in area
- OD defect located in this region

### ■ **Overlap area of Monel Tube:**



- Defects > 20% TW reported, any defect > 40% TW dispositioned
- No OD pits > 71% TW
- No detectable disbonds

### ■ **Damaged area of Monel Tube:**

- OD defects monitored
- Through wall defects acceptable

05-97

# Normal beam ultrasonics



05-97

## *Inspection technique*

- *RF signal split into two channels, one 10 dB attenuated*
- *4 gates:*
  - *OD TOF (wall thickness)*
  - *OD amplitude (defect detection)*
  - *ID TOF (ID profilometry)*
  - *ID amplitude (surface finish)*
- *Scan resolution: 1.5 degree by 0.2 mm*



## *Inspection Procedure*


- Axial B-scan encompassing sleeve and upper rolled joint*
- C-scan inspection encompassing entire sleeve plus 15 mm either side*
  - *Locate and record sleeve and parent tube defect locations*
  - *Collect full waveforms over all noted defects*
  - *Calibration scans at start and finish of each shift*
  - *analysis: CGSB Level II in UT*



## *Inspection Qualification*

- *Verify size and depth of machined defects on calibration tube*
- *DE to verify sleeve thickness*
- *Cross-check of visual - UT - mechanical testing of sleeve test runs*
- *Independent 3rd party review: of inspection system*

05-97




Calibration tube



Ontario Hydro  
TECHNOLOGIES

# Calibration tube C-scan



05-97

15

NON-PROPRIETARY



# Inspection Records

Clicking NGS Unit 3 Microformed Sleeving VI Report Sheet

Date: MAY 3 1994

File Number (Ref): 33043  
Deck ID number: AGCS BARCH 4

Lot #	Top, upper and lower (33')		Area		Microforming name		Seed file name
	Upper (top)	Lower (bot)	Top type	Measurement	Top type	Measurement	
1					yes	0.051023	021023
2					yes		021023
							021023
							021023

TOP OF SLEEVE - 599  
SLEEVE LENGTH - 206

Inspected by: W.K.L.

Crew Supervisor:

Is this sleeve acceptable? (Y/N): YES  
If not acceptable, which indication(s) caused the rejection:


- Notes:
1. End type description includes: ID, ID, ID, ID (end of hole), outside
  2. Indicate any irregularities and description of surface: area (mm<sup>2</sup>), W, SW (1/4" max), W ST (1/4" max)
  3. If any 1/2" or more diameter irregularities are found, e.g. 0.15"
  4. SCT pit measurements should indicate location from top of electrodeless base.



Ontario Hydro  
TECHNOLOGIES

# *Sleeve Re-inspection*

---



# *Formation of Unbonded Area*

---

# *Unbonds Left in Service*

---



May 13-14, 1997 Meeting Information