

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

February 5, 1988

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: McGuire Nuclear Station
Docket Nos. 50-369, 50-370
Proposed Technical Specifications Changes
Borated Water Sources (T.S.'s 3.1.2.5/3.1.2.6)

Gentlemen:

Attached (pursuant to 10CFR 50.4 and 50.90) are proposed license amendments to facility operating licenses NPF-9 and NPF-17 for McGuire Nuclear Station Units 1 and 2, respectively. The proposed amendments revise the minimum contained borated water volume requirements (RE T.S.'s 3.1.2.5/3.1.2.6) of the Boric Acid Storage system to reflect an adjustment to the zero percent level of the Boric Acid Tanks. This correction resulted from a recent re-evaluation of the piping associated with the tanks and transfer pumps. The adjusted values are presently being administratively implemented since they are more conservative than the current technical specifications.

Attachment 1 contains the proposed technical specification changes. Attachment 2 discusses the justification and safety analysis to support the proposed changes. Pursuant to 10CFR 50.91, Attachment 3 provides the analysis performed in accordance with the standards contained in 10CFR 50.92 which concludes that the proposed amendments do not involve a significant hazards consideration, and Duke is forwarding a copy of this amendment request application and no significant hazards consideration analysis to the North Carolina Department of Human Resources. The proposed amendments have been reviewed and have been determined to have no adverse safety or environmental impact.

Pursuant to 10CFR 170.3(y), 170.12(c), and 170.21, a check for the License Amendment application fee is enclosed in the amount of \$150.00.

Should there be any questions concerning this matter or if additional information is required, please advise.

Very truly yours,



Hal B. Tucker

PBN/72/jgc
Attachments
Enclosure

8802220023 880205
PDR ADOCK 05000369
F DCD

REC'D W/CHUCK
#18476314

ADD
1/1

Document Control Desk
February 5, 1988
Page 2

xc: Dr. J. Nelson Grace, Regional Administrator
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St. NW, Suite 2900
Atlanta, Georgia 30323

Mr. Darl Hood, Project Manager
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Dayne Brown, Chief
Radiation Protection Branch
Division of Facility Services
Department of Human Resources
P.O. Box 12200
Raleigh, NC 27605

Mr. W.T. Orders
NRC Resident Inspector
McGuire Nuclear Station

Document Control Desk
February 5, 1988
Page 3

bx: P.M. Abraham
R.F. Banner
K.S. Canady
A.V. Carr
Mike Edwards (TTC)
R.C. Futrell
W.S. Kitlan
L. McConnell
E.O. McCraw
T.W. Miralia
J.R. Pring
J.E. Snyder
QA Tech. Services Manager (EC 1255)
QA Tech. Services NRC Coordinator (EC 1258)
N.A. Rutherford
R.L. Gill
S.A. Gewehr
J.B. Day
S.E. LeRoy
MC-801.01
MC-813.20
(21)

Document Control Desk
February 5, 1988
Page 4

HAL B. TUCKER, being duly sworn, states that he is Vice President of Duke Power Company; that he is authorized on the part of said Company to sign and file with the Nuclear Regulatory Commission this revision to the McGuire Nuclear Station License Nos. NPF-9 and NPF-17 and that all statements and matters set forth therein are true and correct to the best of his knowledge.



Hal B. Tucker, Vice President

Subscribed and sworn to before me this 5th day of February, 1988.

Notary Public

My Commission Expires:

ATTACHMENT 1

Proposed McGuire Unit 1 and 2
Technical Specification Changes