



Northern States Power Company

Prairie Island Nuclear Generating Plant

1717 Wakonade Dr. East
Welch, Minnesota 55089

December 19, 1994

10 CFR Part 50
Section 50.73

U S Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

PRAIRIE ISLAND NUCLEAR GENERATING PLANT
Docket Nos. 50-282 License Nos. DPR-42
50-306 DPR-60

Discovery That No. 121 Cooling Water Pump
Was Inoperable for Safeguards Operation

The Licensee Event Report for this occurrence is attached. In the report, we made one new NRC commitment:

Controls were established to prevent aligning No. 121 CLP for safeguards operation per Technical Specification 3.3.D.1.a until a thorough review is performed to qualify it as a safeguards pump.

This event was reported via the Emergency Notification System in accordance with 10 CFR Part 50, Section 50.72, on November 18, 1994. Please contact us if you require additional information related to this event.

Mike Wadley for

Roger O Anderson
Director
Licensing and Management Issues

c: Regional Administrator - Region III, NRC
NRR Project Manager, NRC
Senior Resident Inspector, NRC
Kris Sanda, State of Minnesota

Attachment

9412290128 941219
PDR ADOCK 05000282
S PDR

*IEPP
11*