



Log # TXX-83231
File # 10110
903.8
Ref. # 10CFR50.55(e)

William G. Council
Executive Vice President

February 18, 1988

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)
DOCKET NOS. 50-445 AND 50-446
POLAR CRANE SUPPORT STRUCTURE
SDAR: CP-86-62 (SUPPLEMENTAL REPORT)

Gentlemen:

On October 3, 1986, we notified you by our letter, logged TXX-6011, of a deficiency involving a misinterpretation of the polar crane load cases, which we deemed reportable under the provisions of 10CFR50.55(e). Our most recent report submitted to status the implementation of corrective action was logged TXX-88123 dated January 18, 1988.

The additional polar crane rail hold down clips for Unit 2 are now installed. This completes our reporting on the subject SDAR.

Very truly yours,

W. G. Council

RWH/grr

c - Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

8802220252 880218
PDR ADOCK 050003445
S PDR

IFB7
1/0