## UNITED STATES OF AMERICA

## NUCLEAR REGULATORY COMMISSION

In the Matter of

UNIT NO. 2 Docket No. 50-412 License No. NPF-73

Duquesne Light Company ) Beaver Valley Power Station)

## APPLICATION FOR AMENDMENT TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications set forth in Appendix A to the license be amended to revise the steam generator low-low level reactor trip and the steam generator low-low level auxiliary feedwater actuation setpoints from > 15.5% to > 11.5%.

The proposed technical specification change is set forth in Attachments A to this Application. A Safety Evaluation is set forth in Attachment B. A No Significant Hazard Evaluation is set forth in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.

WHEREFORE, Applicant respectfully requests that Appendix A to this Operating License be amended in the form attached hereto as Attachment A.

Duquesne Light Company

Vice President, Nuclear

subscribed and sworn to before me on this //th day of Albunay, 190

SHERLA C. FATTORIC, DEVINT PLANC SHEPHICAPPER 5080, BLARES C. OKIY BY COMMINSION FREIRIS 967, 15, 1997

