

OPERATING DATA REPORT

DOCKET 50-369

DATE 2-15-88

OPERATING STATUS

COMPLETED BY J. A. Reavis

TELEPHONE 704/373-7567

1. Unit Name: McGUIRE 1
2. Reporting Period: JANUARY 1, 1988-JANUARY 31, 1988
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1305*
5. Design Electrical Rating (Net MWe): 1180
6. Maximum Dependable Capacity (Gross MWc):
7. Maximum Dependable Capacity (Net MWe): 1129
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons: _____

Notes *Nameplate Rating (Gross MWe) calculated as 1450,000 MVA x .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____
10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.0	744.0	54,072.0
12. Number Of Hours Reactor Was Critical	729.4	729.4	37,593.0
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	726.8	726.8	37,070.0
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	2,379,899	2,379,899	107,449,478
17. Gross Electrical Energy Generated (MWH)	829,803	829,803	37,225,960
18. Net Electrical Energy Generated (MWH)	799,538	799,538	35,465,036
19. Unit Service Factor	97.7	97.7	68.6
20. Unit Availability Factor	97.7	97.7	68.6
21. Unit Capacity Factor (Using MDC Net)	95.2	95.2	56.1
22. Unit Capacity Factor (Using DER Net)	91.1	91.1	55.6
23. Unit Forced Outage Rate	2.3	2.3	12.8
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each): None			

25. If Shut Down At End Of Report Period, Estimated Date of Startups: _____

26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	-----	-----
INITIAL ELECTRICITY	-----	-----
COMMERCIAL OPERATION	-----	-----

8802230019 880131
PDR ADOCK 05000369
R DCD

1324/1

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-369

 UNIT McGuire 1

 DATE February 15, 1988

 COMPLETED BY J. A. Reavis

 TELEPHONE 704-373-7567

MONTH JANUARY, 1988

DAY ---	AVERAGE DAILY POWER LEVEL (MWE-Net)
1	1007
2	1115
3	1115
4	1111
5	1115
6	1063
7	238
8	683
9	1099
10	1096
11	1115
12	1114
13	1117
14	1115
15	1117
16	1115

DAY ---	AVERAGE DAILY POWER LEVEL (MWE-Net)
17	1117
18	1113
19	1118
20	1136
21	1137
22	1132
23	1134
24	1138
25	1135
26	1134
27	1136
28	1136
29	1136
30	1141
31	1137

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-369
 UNIT NAME MCGUIRE 1
 DATE 02/15/88
 COMPLETED BY J. A. REAVIS
 TELEPHONE (704)-373-7567

REPORT MONTH January 1988

NO.	DATE	(1)	DURATION HOURS	(2)	(3)	LICENSE EVENT REPORT NO.	(4)	(5)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
		T Y P E		R E A S O N	MET- HOD OF SHUT DOWN R/X		SYS- TEM CODE	COMPONENT CODE	
1-p	88- 1- 1	S	--	F	--		ZZ	ZZZZZZ	DISPATCHER REQUEST
2-p	88- 1- 1	F	--	A	--		HB	VALVEX	#4 GOVERNOR VALVE PROBLEMS
3-p	88- 1- 6	F	--	A	--		HA	GENERA	GENERATOR VOLTAGE REGULATOR PROBLEMS
1	88- 1- 7	F	17.20	A	3		HA	GENERA	REACTOR TRIP DUE TO GENERATOR VOLTAGE REGULATOR PROBLEMS
4-p	88- 1- 8	F	--	B	--		IE	INSTRU	HOLD FOR NUCLEAR INSTRUMENTATION CALIBRATION
5-p	88- 1- 8	F	--	B	--		IE	INSTRU	HOLD FOR NUCLEAR INSTRUMENTATION CALIBRATION
6-p	88- 1- 8	F	--	A	--		HB	VALVEX	#4 GOVERNOR VALVE PROBLEMS

(1)
 F Forced
 S Scheduled

(2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

(3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

(4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

(5)
 Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-369
 UNIT NAME MCGUIRE 1
 DATE 02/15/88
 COMPLETED BY J. A. REAVIS
 TELEPHONE (704)-373-7567

REPORT MONTH January 1988

NO.	DATE	(1)	DURATION HOURS	(2)	(3)	LICENSE EVENT REPORT NO.	(4)	(5)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
		T Y P E		R E A S O N	MET- HOD OF SHUT DOWN R/X		SYS- TEM CODE	COMPONENT CODE	
7-p	88- 1- 8	F	--	A	--		HB	VALVEX	REMOVED #4 GOVERNOR VALVE FROM SERVICE
8-p	88- 1- 9	F	--	A	--		HB	VALVEX	#4 GOVERNOR VALVE PROBLEMS
9-p	88- 1- 9	F	--	A	--		HJ	PUMPXX	REMOVE 'C3' HEATER DRAIN PUMP FROM SERVICE
10-p	88- 1- 9	F	--	A	--		HB	VALVEX	#4 GOVERNOR VALVE PROBLEMS

- (1)
 F Forced
 S Scheduled

- (2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

- (3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

- (4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

- (5)
 Exhibit i - Same Source

DOCKET NO: 50-369

UNIT: McGuire 1

DATE: 02/15/88

NARRATIVE SUMMARY

Month: January, 1988

McGuire Unit 1 began the month of January operating at 78% power, reduced in power per Dispatcher request. At 0952 on 01/01, the unit began increasing power, reaching 96% at 1300 the same day. The unit remained at 96% power, limited by problems with the No. 4 Turbine Governor Valve, until 1822 on 01/06, when power was reduced to 76% due to generator voltage regulator problems. The reactor subsequently tripped at 0708 on 01/07, following a turbine trip caused by continued generator voltage regulator problems. The unit was returned to service at 0020 on 01/08, and following two power holds for nuclear instrumentation calibration, reached 95% power at 1745 on 01/08, limited in power by problems with the No. 4 Turbine Governor Valve. At 1815 on 01/08, power was reduced to 86% in order to remove the No. 4 Governor Valve from service. The unit was returned to 96% power at 0330 on 01/09. On 01/09 at 1601, power was reduced to 93% in order to remove the "C3" Heater Drain Pump from service. The unit then returned to 96% power where it operated until 1513 on 01/19, when the unit was returned to 100% power. The unit then operated at 100% full power for the remainder of the month.

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire, Unit 1
2. Scheduled next refueling shutdown: November, 1988
3. Scheduled restart following refueling: January, 1989
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? N

If yes, what will these be? -----

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions? N/A

5. Scheduled date(s) for submitting proposed licensing action and supporting information: N/A
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of fuel assemblies (a) in the core: 193
(b) in the spent fuel pool: 293
8. Present licensed fuel pool capacity: 1463
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present licensed capacity: August, 2010

DUKE POWER COMPANY

DATE: February 15, 1988

Name of Contact: J. A. Reavis

Phone: 704-373-7567

OPERATING DATA REPORT

DOCKET 50-370

DATE 2-15-88

COMPLETED BY J. A. Reavis

TELEPHONE 704/373-7567

OPERATING STATUS

1. Unit Name: McGUIRE 2
2. Reporting Period: JANUARY 1, 1988-JANUARY 31, 1988
3. Licensed Thermal Power (Mwt): 3411
4. Nameplate Rating (Gross MWe): 1305*
5. Design Electrical Rating (Net MWe): 1180
6. Maximum Dependable Capacity (Gross MWe):
7. Maximum Dependable Capacity (Net MWe): 1129
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report. Give Reasons: _____

Notes *Nameplate Rating (Gross MWe) calculated as 1450.000 MVA x .90 power factor per Page iii, NUREG-0020.

9. Power Level To Which Restricted, If Any (Net MWe): _____

10. Reason For Restrictions, If any: _____

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	744.0	744.0	34,368.0
12. Number Of Hours Reactor Was Critical	726.1	726.1	25,172.0
13. Reactor Reserve Shutdown Hours	--0--	--0--	--0--
14. Hours Generator On-Line	721.2	721.2	24,548.5
15. Unit Reserve Shutdown Hours	--0--	--0--	--0--
16. Gross Thermal Energy Generated (MWH)	2,375,936	2,375,936	79,615,887
17. Gross Electrical Energy Generated (MWH)	830,271	830,271	27,906,074
18. Net Electrical Energy Generated (MWH)	799,386	799,386	26,735,388
19. Unit Service Factor	96.9	96.9	71.4
20. Unit Availability Factor	96.9	96.9	71.4
21. Unit Capacity Factor (Using MDC Net)	92.4	95.2	66.9
22. Unit Capacity Factor (Using DER Net)	91.1	91.1	65.9
23. Unit Forced Outage Rate	3.1	3.1	14.6

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

Refueling - May 27, 1988 - 10 weeks

25. If Shut Down At End Of Report Period. Estimated Date of Startup: _____

26. Units In Test Status (Prior to Commercial Operation):

INITIAL CRITICALITY
INITIAL ELECTRICITY
COMMERCIAL OPERATION

Forecast Achieved

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-370

UNIT McGuire 2

DATE February 15, 1988

COMPLETED BY J. A. Reavis

TELEPHONE 704-373-7567

MONTH JANUARY, 1988

DAY AVERAGE DAILY POWER LEVEL
--- (MWE-Net)

1	1151
2	1151
3	1151
4	1151
5	1153
6	1153
7	1153
8	1153
9	1154
10	1154
11	1153
12	182
13	435
14	462
15	1101
16	1147

DAY AVERAGE DAILY POWER LEVEL
--- (MWE-Net)

17	1147
18	1147
19	1152
20	1157
21	1155
22	1154
23	1154
24	1158
25	1154
26	1154
27	1157
28	1153
29	1153
30	1156
31	1153

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-370
 UNIT NAME MCGUIRE 2
 DATE 02/15/88
 COMPLETED BY J. A. REAVIS
 TELEPHONE (704)-373-7567

REPORT MONTH January 1988

NO.	DATE	(1) TYPE	DURATION HOURS	(2) REASON	(3) METHOD OF SHUT DOWN R/X	LICENSE EVENT REPORT NO.	(4) SYSTEM CODE	(5) COMPONENT CODE	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
1	88- 1-12	F	21.78	A	1		HH	VALVEX	FAILURE OF AIR FILTER ON 'C' S/G FEED REG. VALVE
1-p	88- 1-13	F	--	B	--		HH	XXXXXX	HOLD FOR SECONDARY CHEMISTRY
2-p	88- 1-13	F	--	A	--		HH	VALVEX	REPAIR S/G 'C' FEEDWATER CONTAINMENT ISOLATION VALVE
3-p	88- 1-13	S	--	B	--		IE	INSTRU	HOLD FOR NUCLEAR INSTRUMENTATION CALIBRATION
4-p	88- 1-14	F	--	A	--		HA	XXXXXX	REPAIR LEAK ON ELECTRO-HYDRAULIC SYSTEM
2	88- 1-14	F	1.03	A	1		HA	XXXXXX	REPAIR LEAK ON ELECTRO-HYDRAULIC SYSTEM
5-p	88- 1-14	S	--	B	--		IE	INSTRU	HOLD FOR NUCLEAR INSTRUMENTATION CALIBRATION

- (1)
 F Forced
 S Scheduled
- (2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

- (3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

- (4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

- (5)
 Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-370
 UNIT NAME MCGUIRE 2
 DATE 02/15/88
 COMPLETED BY J. A. REAVIS
 TELEPHONE (704)-373-7567

REPORT MONTH January 1988

Page 2 of 2

N O .	DATE	(1)	DURATION HOURS	(2)	(3)	LICENSE EVENT REPORT NO.	(4)	(5)	CAUSE AND CORRECTIVE ACTION TO PREVENT RECURRENCE
		T Y P E		R E A S O N	MET- HOD OF SHUT DOWN R/X		SYS- TEM CODE	COMPONENT CODE	
6-p	88- 1-15	S	--	B	--		IE	INSTRU	HOLD FOR NUCLEAR INSTRUMENTATION CALIBRATION

- (1)
 F Forced
 S Scheduled

- (2)
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operator Error (Explain)
 H-Other (Explain)

- (3)
 Method:
 1-Manual
 2-Manual Scram
 3-Automatic Scram
 4-Other (Explain)

- (4)
 Exhibit G - Instructions
 for Preparation of Data
 Entry Sheets For Licensee
 Event Report (LER)
 File (NUREG-0161)

- (5)
 Exhibit I - Same Source

DOCKET NO: 50-370

UNIT: McGuire 2

DATE: 02/15/88

NARRATIVE SUMMARY

Month: January, 1988

McGuire Unit 2 began the month of January operating at 100% full power. On 01/12 at 0425, the unit was removed from service due to low steam generator level caused by an air filter failure on the "C" Steam Generator Feedwater Regulator valve. The unit was returned to service at 0211 on 01/13, and held power at 21% for Secondary Chemistry, at 23% to add hydraulic fluid to the "C" Feedwater Containment Isolation Valve, and at 50% for nuclear instrumentation calibration. The unit reached 90% power at 0010 on 01/14, and shortly thereafter began to shutdown due to a leak on the Electro-Hydraulic Turbine Control System. The unit was removed from service at 1051 on 01/14 and returned to service at 1153 the same day. Following two power holds for nuclear instrumentation calibration, the unit returned to 100% power at 0824 on 01/15, where it operated for the remainder of the month.

MONTHLY REFUELING INFORMATION REQUEST

1. Facility name: McGuire, Unit 2
2. Scheduled next refueling shutdown: May, 1988
3. Scheduled restart following refueling: July, 1988
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment? Yes

If yes, what will these be? Technical Specification Revision

If no, has reload design and core configuration been reviewed by Safety Review Committee regarding unreviewed safety questions? N/A
5. Scheduled date(s) for submitting proposed licensing action and supporting information: N/A
6. Important licensing considerations (new or different design or supplier, unreviewed design or performance analysis methods, significant changes in design or new operating procedures).
7. Number of fuel assemblies (a) in the core: 193
(b) in the spent fuel pool: 436
8. Present licensed fuel pool capacity: 1463
Size of requested or planned increase: ---
9. Projected date of last refueling which can be accommodated by present licensed capacity: August, 2010

DUKE POWER COMPANY

DATE: February 15, 1988

Name of Contact: J. A. Reavis

Phone: 704-373-7567

McGUIRE NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

1. Personnel Exposure

For the month of December, no individuals exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for December has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

TELEPHONE
(704) 373-4531

February 15, 1988


U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D. C. 20555

Re: McGuire Nuclear Station
Docket No. 50-369 and 50-370

Dear Sir:

Please find attached information concerning the performance and operating status of the McGuire Nuclear Station for the month of January, 1988.

Very truly yours,



Hal B. Tucker

JAR/1392/sbn

Attachment

xc: Dr. J. Nelson Grace
Regional Administrator/Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Phil Ross
U. S. Nuclear Regulatory Commission
MNBB-5715
Washington, D. C. 20555

Mr. Darl Hood, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Mr. Robert G. Rogers
Nuclear Assurance Corporation
6251 Crooked Creek Road
Norcross, Georgia 30092

American Nuclear Insurers
c/o Dottie Sherman, ANI Library
The Exchange, Suite 245
270 Farmington Avenue
Farmington, CT 06032

INPO Records Center
Suite 1500
1100 Circle 75 Parkway
Atlanta, Georgia 30323

Mr. Richard G. Oehl, NE-44
U. S. Department of Energy
19901 Germantown Road
Germantown, Maryland 20874

Mr. W. T. Orders
NRC Resident Inspector
McGuire Nuclear Station

1/11