



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

UNION ELECTRIC COMPANY

CALLAWAY PLANT, UNIT 1

DOCKET NO. STN 50-483

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 34
License No. NPF-30

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by Union Electric Company (the licensee) dated September 10, 1987 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-30 is hereby amended to read as follows:


8802230208 880217
PDR ADOCK 05000483
P PDR

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 34, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into the license. UE shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Kenneth E. Perkins, Director
Project Directorate III-3
Division of Reactor Projects

Attachment:
Changes to the Technical
Specifications

Date of Issuance: February 17, 1988

ATTACHMENT TO LICENSE AMENDMENT NO. 34

OPERATING LICENSE NO. NPF-30

DOCKET NO. 50-483

Revise Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change. Corresponding overleaf pages are provided to maintain document completeness.

REMOVE

3/4 3-11
3/4 3-12*
3/4 3-12a

INSERT

3/4 3-11
3/4 3-12*
3/4 3-12a

* Overleaf page

TABLE 4.3-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION SURVEILLANCE REQUIREMENTS

FUNCTIONAL UNIT	CHANNEL CHECK	CHANNEL CALIBRATION	ANALOG CHANNEL OPERATIONAL TEST	TRIP ACTUATING DEVICE OPERATIONAL TEST	ACTUATION LOGIC TEST	MODES FOR WHICH SURVEILLANCE IS REQUIRED
18. Reactor Trip System Interlocks (Continued)						
d. Power Range Neutron Flux, P-10	N.A.	R(4)	R	N.A.	N.A.	1,2
e. Turbine Impulse Chamber Pressure, P-13	N.A.	R	R	N.A.	N.A.	1
19. Reactor Trip Breaker	N.A.	N.A.	N.A.	M (7, 11)	N.A.	1,2,3*,4*,5*
20. Automatic Trip and Interlock Logic	N.A.	N.A.	N.A.	N.A.	M(7)	1,2,3*,4*,5*
21. Reactor Trip Bypass Breaker	N.A.	N.A.	N.A.	H(17), R(18)	N.A.	1,2,3*,4*,5*

TABLE 4.3-1 (Continued)

TABLE NOTATIONS

*Only if the Reactor Trip System breakers happen to be closed and the Control Rod Drive System is capable of rod withdrawal.

#The specified 18 month frequency may be waived for Cycle I provided the surveillance is performed prior to restart following the first refueling outage or June 1, 1986, whichever occurs first. The provisions of Specification 4.0.2 are reset from performance of this surveillance.

##Below P-6 (Intermediate Range Neutron Flux interlock) Setpoint.

###Below P-10 (Low Setpoint Power Range Neutron Flux interlock) Setpoint.

- (1) If not performed in previous 31 days.
- (2) Comparison of calorimetric to excore power indication above 15% of RATED THERMAL POWER. Adjust excore channel gains consistent with calorimetric power if absolute difference is greater than 2%. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (3) Single point comparison of incore to excore AXIAL FLUX DIFFERENCE above 15% of RATED THERMAL POWER. Recalibrate if the absolute difference is greater than or equal to 3%. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (4) Neutron detectors may be excluded from CHANNEL CALIBRATION.
- (5) Detector plateau curves shall be obtained, evaluated and compared to manufacturer's data. For the Intermediate Range and Power Range Neutron Flux channels the provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1.
- (6) Incore - Excore Calibration, above 75% of RATED THERMAL POWER. The provisions of Specification 4.0.4 are not applicable for entry into MODE 2 or 1. Determination of the loop specific vessel ΔT value should be made when performing the Incore/Excore quarterly recalibration, under steady state conditions.
- (7) Each train shall be tested at least every 62 days on a STAGGERED TEST BASIS. The TRIP ACTUATING DEVICE OPERATIONAL TEST shall independently verify the OPERABILITY of the Undervoltage and Shunt Trip Attachments of the Reactors Trip Breakers.
- (8) Deleted
- (9) Quarterly surveillance in MODES 3*, 4*, and 5* shall also include verification that permissives P-6 and P-10 are in their required state for existing plant conditions by observation of the permissive annunciator window. Quarterly surveillance shall include verification of the Boron Dilution Alarm Setpoint of less than or equal to an increase of twice the count rate within a 10-minute period.

TABLE 4.3-1 (Continued)

TABLE NOTATIONS

- (10) Setpoint verification is not required.
- (11) Following maintenance or adjustment of the Reactor trip breakers, the TRIP ACTUATING DEVICE OPERATIONAL TEST shall include independent verification of the Undervoltage and Shunt trips.
- (12) At least once per 18 months during shutdown, verify that on a simulated Boron Dilution Doubling test signal the normal CVCS discharge valves will close and the centrifugal charging pumps suction valves from the RWST will open within 30 seconds.
- (13) CHANNEL CALIBRATION shall include the RTD bypass loops flow rate.
- (14) Each channel shall be tested at least every 92 days on a STAGGERED TEST BASIS.
- (15) The surveillance frequency and/or MODES specified for these channels in Table 4.3-2 are more restrictive and, therefore, applicable.
- (16) The TRIP ACTUATING DEVICE OPERATIONAL TEST shall independently verify the OPERABILITY of the Undervoltage and Shunt Trip circuits for the Manual Reactor Trip function. The test shall also verify the OPERABILITY of the Bypass Breaker trip circuit.
- (17) Local manual shunt trip prior to placing breaker in service.
- (18) Automatic Undervoltage Trip.