


## ACCIDENT SEQUENCE PRECURSOR PROGRAM EVENT ANALYSIS

LER No: 333/89-020  
 Event Description: Reactor scram with HPCI system inoperable  
 Date of Event: November 5, 1989  
 Plant: Fitzpatrick

### Summary

The reactor scrammed from 100% power, and the high-pressure coolant injection (HPCI) system was inoperable. The conditional probability of core damage associated with this event is estimated to be  $1.3 \times 10^{-5}$ . The relative significance of this event compared with other potential events at Fitzpatrick is shown below.



### Event Description

Fitzpatrick was operating at 100% power on November 5, 1989, when the reactor scrammed due to an apparent failure in the electrohydraulic control (EHC) system of the main turbine. HPCI had been previously removed from service when a ground was discovered in the speed control circuit for the HPCI turbine. The plant scrammed on high neutron flux when closure of the turbine control valves caused a pressure spike in the reactor. The rapid pressure rise caused a collapse of voids in the reactor coolant, enhancing moderation and causing a flux increase. The turbine control valve closure was from an unknown signal source (or failure) that probably originated in the EHC system; however, no component failures were found. RCIC was used for reactor vessel makeup.

### **Additional Event-Related Information**

The HPCI system is a high-pressure injection system designed for small-break LOCAs that do not depressurize the reactor. HPCI is an independent system, uses a turbine-driven pump, and automatically initiates on reactor low water level. HPCI can deliver ~5000 gpm of makeup water to the vessel through the feedwater piping.

Closure of the turbine control valves will ordinarily generate an anticipatory scram signal. Low EHC oil pressure, about 850 psi to the control valves, will indicate that the valves are about to begin closing and will initiate a scram. This provides a margin to core thermal-hydraulic limits during the subsequent transient. During this event, the turbine control valve fast closure relays apparently failed to operate, and the reactor subsequently scrammed on high flux.

### **ASP Modeling Assumptions and Approach**

This event has been modeled as a reactor scram with HPCI unavailable during the scram and subsequent recovery actions.

### **Analysis Results**

The conditional probability of severe core damage for this event is  $1.3 \times 10^{-5}$ . The dominant sequence, highlighted on the following event tree, involves a reactor scram with failure of the power conversion system, SRV challenge and subsequent failure of one of the valves to close, failure of main feedwater, failure to recover HPCI, and failure to depressurize using ADS.

Other LERs that involved HPCI and/or RCIC inoperability in conjunction with power operations at Fitzpatrick are: 333/89-002, -003, -005, -014, -019, -021, and -023. A chronology of HPCI-related events that occurred during 1989 is shown on the following page.

### Chronology of Fitzpatrick HPCI-related events in 1989

Date	Time	Power Level	LER	Remarks
3/2	1330	100	002	HPCI inoperable — failure during related speed test
3/6	1415	100	003	SRV opened momentarily during testing following HPCI inoperability
3/7	1930	100	002	HPCI declared operable
4/12	1225	100	005	HPCI inoperable — speed control circuit failure
4/13	2035	100	005	HPCI declared operable
8/17	0820	100	014	HPCI inoperable due to steam leak — lube oil replaced
8/18	0820	100	014	HPCI declared operable
10/3	0625	100	019	HPCI inoperable due to speed control circuit failure
10/31	1149	100	021, 019	RCIC inoperable — injection valve motor fails
10/31	1958	100	021, 019	RCIC declared operable
10/31	2110	100	019	HPCI declared operable
11/3	0300	100	019	HPCI inoperable due to speed control circuit failure
11/5	1523	100	020	Reactor scram with HPCI inoperable
11/8	----	0	019	HPCI mods complete — needs surveillance test
11/12	1734	10	023	Reactor scram at low power during relief valve testing
11/14	----	----	019	HPCI declared operable

B-227

TRANSIENT	Rx SHUT DOWN	PCS	SRV CHAL	SRV C	FW	HPCI OR HPCS	RCIC	CRD	SRV/ ADS	LPCS	LPCI (RHR)	RHR (SDC MODE)	RHR (SP COOLING MODE)	RHR SW or OTHER
-----------	--------------	-----	----------	-------	----	--------------	------	-----	----------	------	------------	----------------	-----------------------	-----------------

SEQ NO	END STATE
	OK
	OK
	OK
11	CORE DAMAGE
	OK
	OK
12	CORE DAMAGE
	OK
	OK
13	CORE DAMAGE
	OK
	OK
14	CORE DAMAGE
	OK
	OK
15	CORE DAMAGE
	OK
	OK
16	CORE DAMAGE
	OK
	OK
17	CORE DAMAGE
	OK
	OK
18	CORE DAMAGE
19	CORE DAMAGE
20	CORE DAMAGE
	OK
	OK
21	CORE DAMAGE
	OK
	OK
22	CORE DAMAGE
	OK
	OK
23	CORE DAMAGE
	OK
	OK
24	CORE DAMAGE
	OK
	OK
25	CORE DAMAGE
	OK
	OK
26	CORE DAMAGE
27	CORE DAMAGE
28	CORE DAMAGE
	OK
	OK
29	CORE DAMAGE
	OK
	OK
30	CORE DAMAGE
	OK
	OK
31	CORE DAMAGE
	OK
	OK
32	CORE DAMAGE
	OK
	OK
33	CORE DAMAGE
	OK
	OK
34	CORE DAMAGE
	OK
	OK
35	CORE DAMAGE
	OK
	OK
36	CORE DAMAGE
37	CORE DAMAGE
38	CORE DAMAGE
99	ATWS

Dominant core damage sequence for LER 333/89-020

# B-228

## CONDITIONAL CORE DAMAGE PROBABILITY CALCULATIONS

Event Identifier: 333/89-020  
 Event Description: Reactor scram with HPCI system inoperable  
 Event Date: 11/05/89  
 Plant: Fitzpatrick

### INITIATING EVENT

#### NON-RECOVERABLE INITIATING EVENT PROBABILITIES

TRANS 1.0E+00

#### SEQUENCE CONDITIONAL PROBABILITY SUMS

End State/Initiator	Probability
CD	
TRANS	1.3E-05
Total	1.3E-05
ATWS	
TRANS	3.0E-05
Total	3.0E-05

#### SEQUENCE CONDITIONAL PROBABILITIES (PROBABILITY ORDER)

Sequence	End State	Prob	N Rec**
28 trans -rx.shutdown pcs/trans srv.chall/trans.-scram srv.close fw/pcs.trans HPCI srv.ads	CD	1.2E-05	2.4E-01
11 trans -rx.shutdown pcs/trans srv.chall/trans.-scram -srv.close -fw/pcs.trans rhr(sdc) rhr(spcool)/rhr(sdc)	CD	7.6E-07	1.0E-01
99 trans rx.shutdown	ATWS	3.0E-05	1.0E+00

\*\* non-recovery credit for edited case

#### SEQUENCE CONDITIONAL PROBABILITIES (SEQUENCE ORDER)

Sequence	End State	Prob	N Rec**
11 trans -rx.shutdown pcs/trans srv.chall/trans.-scram -srv.close -fw/pcs.trans rhr(sdc) rhr(spcool)/rhr(sdc)	CD	7.6E-07	1.0E-01
28 trans -rx.shutdown pcs/trans srv.chall/trans.-scram srv.close fw/pcs.trans HPCI srv.ads	CD	1.2E-05	2.4E-01
99 trans rx.shutdown	ATWS	3.0E-05	1.0E+00

\*\* non-recovery credit for edited case

SEQUENCE MODEL: a:\1989\bwrcseal.cmp  
 BRANCH MODEL: a:\1989\fitzpatr.sll  
 PROBABILITY FILE: a:\1989\bwr\_csll.pro

No Recovery Limit

#### BRANCH FREQUENCIES/PROBABILITIES

Branch	System	Non-Recov	Opr Fail
trans	3.4E-04	1.0E+00	
loop	1.6E-05	3.6E-01	
loca	3.3E-06	5.0E-01	
rx.shutdown	3.0E-05	1.0E+00	
rx.shutdown/ep	3.5E-04	1.0E+00	
pcs/trans	1.7E-01	1.0E+00	
srv.chall/trans.-scram	1.0E+00	1.0E+00	

Event Identifier: 333/89-020

# B-229

srv.chall/loop.-scram	1.0E+00	1.0E+00	
srv.close	3.6E-02	1.0E+00	
emerg.power	2.9E-03	8.0E-01	
ep.rec	1.6E-01	1.0E+00	
fw/pcs.trans	4.6E-01	3.4E-01	
fw/pcs.loca	1.0E+00	3.4E-01	
HPCI	2.9E-02 > 1.0E+00	7.0E-01 > 1.0E+00	
Branch Model: 1.OF.1			
Train 1 Cond Prob:	2.9E-02 > Unavailable		
rcic	6.0E-02	7.0E-01	
crd	1.0E-02	1.0E+00	1.0E-02
srv.ads	3.7E-03	7.1E-01	1.0E-02
lpcs	3.0E-03	3.4E-01	
lpci(rhr)/lpcs	1.0E-03	7.1E-01	
rhr(sdc)	2.1E-02	3.4E-01	1.0E-03
rhr(sdc)/-lpci	2.0E-02	3.4E-01	1.0E-03
rhr(sdc)/lpci	1.0E+00	1.0E+00	1.0E-03
rhr(spcool)/rhr(sdc)	2.0E-03	3.4E-01	
rhr(spcool)/-lpci.rhr(sdc)	2.0E-03	3.4E-01	
rhr(spcool)/lpci.rhr(sdc)	9.3E-02	1.0E+00	
rhrsw	2.0E-02	3.4E-01	2.0E-03

\* branch model file  
\*\* forced

Minarick  
06-16-1990  
13:49:40