PRECURSOR DESCRIPTION AND DATA

NSIC Accession Number: 164703

Date: May 18, 1981

Title: Loss of offsite power at La Crosse

The failure sequence was:

1. The reactor was operating at 28% power.

- 2. The switchyard operator was directed to open a switch in response to another situation, but he opened the wrong switch, disconnecting the auxiliary transformer from the 69 kV transmission line. This resulted in a loss of all offsite power.
- The reactor scrammed and the diesel generators started automatically and supplied the required vital loads.

Corrective action:

- 1. Offsite power was restored within 14 min.
- Practices were revised to require outside switching order to be executed in the presence of a second person whenever possible.
- Additional practical training was to be provided on the switchyard for all operators.

Design purpose of failed system or component:

Offsite power provides the preferred source of power to plant loads when the unit generator is unavailable.

Reactor operating at 28% power	Operator switching error disconnecting offsite power networks	Emergency power operates	Potential Severe Core Damage		
			No		
			No - separate diesel- powered service water system avail- able for core cooling		

No

Loss of Offsite Power	Reactor Scram	Diesels Start and Load	Standby Liquid Control Initiated	One of Two HPSW or Three of Four ESW	One of Four ESW	Shutdown Condenser	HPCS	Manual Depressuri- zation	Potential Severe Core Damage	Sequence No.
									- No	1
						-	-		- No	2
							-{		- No	3
								<u> </u>	- Yes	4
									- No	5
						-			- No	6
]	L	┨		- Yes	7
					l				- No	8
	}				L		┧		- Yes	9
									- No	10
						-			- No	11
								L	- Yes	12
	1	L		1					- No	13
						<u> </u>			- Yes	14
					1				- Yes	15
-/-/-	1								- No	16
	1		•			4			- No	17
							┥		- Yes	18
	ľ			1					- No	19
						1			- No	20
					4	<u> </u>	1		- Yes	21
			1						- No	22
	L	_					<u> </u>		- Yes	23
									- Yes	24
		L							- Yes	25

NSIC 164703 - Sequence of Interest for LOOP at La Crosse

CATEGORIZATION OF ACCIDENT SEQUENCE PRECURSORS

NSIC ACCESSION NUMBER: 164703

LER NO.: 81-002 Rev. 1

DATE OF LER: May 18, 1981

DATE OF EVENT: February 1, 1981

SYSTEM INVOLVED: Offsite power

COMPONENT INVOLVED: Switch

CAUSE: Operator error

SEQUENCE OF INTEREST: LOOP

ACTUAL OCCURRENCE: LOOP

REACTOR NAME: La Crosse

DOCKET NUMBER: 50-409

REACTOR TYPE: BWR

DESIGN ELECTRICAL RATING: 50 MWe

REACTOR AGE: 13.6 years

VENDOR: Allis-Chalmers

ARCHITECT-ENGINEERS: Sargent & Lundy

OPERATORS: Dairyland Power Cooperative

LOCATION: 19 miles south of LaCrosse, Wisconsin

DURATION: 14 minutes

PLANT OPERATING CONDITION: 28% power

TYPE OF FAILURE: Made inoperable

DISCOVERY METHOD: Operational event

COMMENT: